

PINGTAN, China

WMO: 589440

Lat: 25.5048N

Lon: 119.7828E

Elev: 102

StdP: 14.64

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	43.2	44.8	29.2	23.2	47.6	32.3	26.9	48.3	20.8	49.0	19.5	48.7	12.5	20	0.409

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.9	89.7	79.1	88.6	79.1	87.5	79.1	81.4	85.7	80.9	85.1	80.4	84.6	8.8	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.1	157.0	83.7	79.7	154.9	83.5	79.2	151.9	83.3	45.3	85.8	44.7	85.3	44.2	84.8	83.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.6	17.8	16.3	41.2	92.2	3.3	0.9	38.8	92.9	36.8	93.4	35.0	93.9	32.5	94.6
			36.1	81.8	3.2	0.9	33.7	82.4	31.9	82.9	30.0	83.4	27.7	84.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	69.0	53.1	53.2	57.4	65.1	72.7	79.2	83.5	83.5	80.5	74.0	66.5	58.1	(6)
	DBStd	11.90	4.99	5.65	5.59	5.80	4.26	4.14	2.05	2.06	3.15	3.66	4.44	4.71	(7)
	HDD50	59	24	28	5	0	0	0	0	0	0	0	0	2	(8)
	HDD65	1270	369	333	243	70	2	0	0	0	0	1	33	219	(9)
	CDD50	6986	120	116	235	452	702	877	1039	1038	914	744	496	253	(10)
	CDD65	2721	0	1	8	71	239	427	574	573	464	280	80	4	(11)
	CDH74	24300	1	2	14	170	987	3861	6822	6781	4545	1050	66	1	(12)
	CDH80	7189	0	0	0	8	95	952	2488	2454	1112	78	2	0	(13)
(14) Wind	WSAvg	8.8	9.5	9.2	8.0	7.6	7.2	8.3	8.7	7.9	8.4	10.3	10.3	9.9	(14)
(15) Precipitation	PrecAvg	46.9	1.8	2.7	4.8	5.3	6.1	9.6	3.6	5.2	4.2	1.3	1.4	1.0	(15)
	PrecMax	73.3	7.7	10.4	12.6	11.1	9.8	28.0	14.1	21.9	13.3	4.3	6.0	3.3	(16)
	PrecMin	31.5	0.0	0.0	0.5	1.2	0.2	0.2	0.0	0.2	0.3	0.0	0.0	0.0	(17)
	PrecStd	8.7	1.7	2.3	3.4	2.4	2.3	6.6	3.5	5.2	4.0	1.3	1.5	1.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	69.2	72.2	75.9	81.2	85.1	89.6	91.5	91.0	89.8	84.9	79.1	71.9	(19)
		MCWB	62.2	65.1	67.8	72.5	77.6	79.2	78.4	78.8	78.3	76.8	71.8	65.1	(20)
	2%	DB	65.0	67.9	71.7	78.5	82.6	87.7	89.7	89.7	87.7	82.0	75.8	68.2	(21)
		MCWB	59.9	63.0	66.1	71.8	76.2	79.2	79.1	79.2	78.3	75.7	70.1	63.7	(22)
	5%	DB	62.3	64.2	68.6	75.8	80.7	86.2	88.6	88.4	86.2	80.2	73.8	66.1	(23)
		MCWB	57.7	59.4	64.0	70.8	75.1	79.0	79.2	79.2	78.0	74.2	69.1	62.4	(24)
	10%	DB	59.9	60.7	65.6	73.5	79.0	84.8	87.4	87.3	84.8	78.8	72.2	64.1	(25)
		MCWB	55.8	56.7	61.0	69.5	74.5	78.9	79.2	79.2	77.7	73.1	67.8	59.8	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	64.1	67.4	70.2	74.7	79.4	81.7	81.9	82.3	81.0	79.0	73.2	67.0	(27)
		MCDB	67.3	70.2	73.1	78.1	82.3	85.2	86.4	86.7	85.6	82.3	76.2	69.3	(28)
	2%	WB	60.9	64.0	67.6	73.2	78.0	80.8	81.1	81.4	80.1	77.5	71.6	64.9	(29)
		MCDB	64.2	67.1	71.1	76.1	80.9	84.5	85.5	85.8	84.5	80.7	74.8	67.5	(30)
	5%	WB	58.5	60.1	64.2	71.8	76.8	80.0	80.8	80.9	79.6	76.0	70.2	62.7	(31)
		MCDB	61.8	63.7	67.6	75.2	79.7	83.8	85.1	85.2	84.0	79.1	73.1	65.7	(32)
	10%	WB	56.2	57.1	61.5	70.2	75.4	79.4	80.3	80.3	78.9	73.9	68.7	60.6	(33)
		MCDB	59.3	60.0	65.1	73.4	78.4	83.2	84.7	84.7	83.3	78.0	71.7	63.7	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	5.5	6.5	7.7	8.0	7.0	6.3	6.9	6.6	5.6	4.4	4.9	5.2	(35)
		MCDBR	10.2	12.7	13.8	11.7	9.4	7.9	8.6	8.3	7.3	6.1	7.4	8.0	(36)
	5% WB	MCWBR	6.5	8.7	9.4	6.8	4.7	2.5	2.4	2.6	2.6	3.4	4.2	5.5	(37)
		MCWBR	9.8	12.5	13.2	10.5	8.3	7.2	6.9	7.0	6.5	5.7	7.0	7.6	(38)
(40) Clear-Sky Solar Irradiance	taub		0.583	0.635	0.718	0.717	0.614	0.558	0.533	0.568	0.568	0.572	0.567	0.564	(40)
		taud	1.766	1.690	1.563	1.615	1.872	2.039	2.111	2.000	1.973	1.891	1.870	1.826	(41)
	Ebn at Noon		208	209	201	207	229	240	246	237	233	222	211	206	(42)
		Edh at Noon	63	73	87	84	65	55	51	56	57	59	56	57	(43)
(44) All-Sky Solar Radiation	RadAvg		730	827	1085	1210	1379	1522	1952	1759	1479	1159	816	725	(44)
	RadStd		163	167	120	170	226	165	141	153	147	165	118	126	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	+0.67	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (15 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+140

Nomenclature: See separate page