

HECHI, China

WMO: 590230

Lat: 24.6939N

Lon: 108.0392E

Elev: 856

StdP: 14.25

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	39.3	41.7	24.1	18.8	48.8	27.8	22.4	48.9	11.7	55.8	10.0	53.6	3.9	40	0.298

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.6	95.0	78.2	93.3	77.9	91.7	77.6	80.9	89.0	80.2	88.2	79.6	87.3	5.0	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.1	156.2	83.9	78.3	151.9	83.6	77.7	148.6	83.2	45.6	89.5	44.8	88.5	44.1	87.6	86.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
10.5	9.1	7.7	DB	36.8	98.8	2.4	1.7	35.1	100.0	33.7	101.0	32.4	101.9	30.7	103.1
			WB	34.1	82.3	2.3	1.3	32.4	83.2	31.0	84.0	29.7	84.7	28.1	85.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	70.3	52.3	56.2	61.9	71.3	77.5	81.4	83.6	83.5	80.2	73.6	65.0	56.0	(6)
	DBStd	12.42	6.86	8.30	7.39	6.89	4.77	3.58	3.31	3.32	4.41	5.29	5.97	5.67	(7)
	HDD50	94	52	26	3	0	0	0	0	0	0	0	1	12	(8)
	HDD65	1204	397	270	151	22	0	0	0	0	0	5	72	287	(9)
	CDD50	7494	123	198	373	638	853	942	1041	1040	906	731	452	197	(10)
	CDD65	3131	3	22	56	211	388	492	576	575	456	272	73	7	(11)
	CDH74	29682	7	107	246	1375	3280	5046	6612	6509	4412	1742	323	23	(12)
	CDH80	11178	0	15	41	367	1117	1845	2789	2801	1697	465	39	2	(13)
(14) Wind	WSAvg	3.3	3.2	3.5	3.5	3.6	3.5	3.4	3.6	3.4	3.2	3.0	2.9	3.1	(14)
(15) Precipitation	PrecAvg	57.9	1.2	1.6	2.4	5.0	8.6	10.2	9.2	9.1	4.0	3.2	2.3	1.2	(15)
	PrecMax	81.0	3.3	4.8	7.3	10.5	17.1	20.2	20.6	19.8	10.6	11.3	6.9	4.6	(16)
	PrecMin	43.4	0.0	0.2	0.3	1.1	1.8	2.6	1.8	2.0	0.7	0.2	0.0	0.0	(17)
	PrecStd	9.3	0.8	1.0	1.5	2.2	4.1	4.1	4.1	4.3	2.4	2.0	1.9	1.1	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	74.2	82.6	84.5	90.9	92.7	94.3	97.4	97.2	95.3	90.5	83.9	77.4	(19)
		MCWB	63.6	67.2	71.6	75.8	77.9	78.1	78.9	78.1	76.1	72.1	71.0	66.8	(20)
	2%	DB	69.5	77.3	79.9	87.3	90.5	92.1	94.9	95.1	92.7	87.3	80.8	71.8	(21)
		MCWB	60.2	66.1	69.0	74.1	75.9	78.0	78.9	78.1	76.2	71.9	67.9	61.1	(22)
	5%	DB	65.8	73.2	76.3	84.2	88.5	90.3	92.9	93.2	90.8	84.9	77.9	68.2	(23)
		MCWB	58.3	64.3	67.4	72.9	75.2	77.8	78.6	78.0	75.9	71.0	66.2	58.2	(24)
	10%	DB	62.4	68.9	73.1	81.3	86.1	88.5	90.8	91.3	88.6	82.5	74.9	64.8	(25)
		MCWB	56.5	62.0	65.5	71.8	74.8	77.7	78.4	78.1	75.1	70.1	65.2	56.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	65.1	69.2	72.7	77.5	81.1	81.9	81.8	81.6	79.9	77.2	74.9	68.7	(27)
		MCDB	71.5	79.0	81.5	86.3	88.7	88.1	90.7	90.7	88.3	84.1	79.4	74.8	(28)
	2%	WB	62.9	67.2	70.9	76.0	79.4	80.8	80.8	80.6	79.0	75.6	71.9	64.4	(29)
		MCDB	67.9	75.6	78.1	84.2	86.4	87.2	89.6	89.7	87.2	82.4	77.6	70.5	(30)
	5%	WB	60.3	65.1	69.1	74.5	78.0	79.9	80.1	79.8	78.2	74.4	69.8	61.1	(31)
		MCDB	64.5	71.9	75.0	82.3	84.7	86.3	88.4	88.5	85.8	81.0	74.8	65.2	(32)
	10%	WB	57.5	62.8	67.1	73.3	76.9	79.1	79.4	79.1	77.4	73.0	67.5	57.9	(33)
		MCDB	61.2	68.2	71.9	80.0	83.3	85.3	87.2	87.4	84.4	79.2	72.4	62.8	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	8.9	9.7	9.8	10.9	11.7	10.6	11.6	12.7	12.9	12.2	12.2	11.1	(35)
		MCDBR	16.1	17.3	15.9	15.3	16.0	14.0	15.5	16.7	16.5	16.3	17.6	18.2	(36)
	5% WB	MCWBR	8.1	7.5	6.9	5.6	4.9	3.7	3.5	3.9	4.0	4.7	6.5	8.3	(37)
		MCWBR	12.3	15.8	14.1	13.5	12.4	11.1	12.5	14.1	13.3	12.1	12.3	12.8	(38)
(40) Clear-Sky Solar Irradiance	taub		0.653	0.668	0.790	0.759	0.612	0.588	0.552	0.614	0.651	0.731	0.634	0.660	(40)
		taud	1.564	1.577	1.405	1.503	1.840	1.917	2.015	1.829	1.719	1.521	1.655	1.573	(41)
	Ebn at Noon		190	201	186	198	229	233	242	227	214	185	194	181	(42)
		Edh at Noon	78	82	102	94	67	62	56	67	74	86	70	75	(43)
(44) All-Sky Solar Radiation	RadAvg		561	708	828	1075	1228	1198	1459	1440	1302	1032	851	675	(44)
	RadStd		143	159	124	149	154	155	119	99	120	117	155	133	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		N/A	N/A	N/A	+0.68	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page