

SHAOGUAN, China

WMO: 590820

Lat: 24.6703N

Lon: 113.6082E

Elev: 400

StdP: 14.48

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	36.2	38.3	22.2	16.9	48.9	26.6	20.9	48.6	16.6	48.6	15.2	49.6	4.5	0	0.335

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.0	95.6	78.6	94.0	78.4	92.4	78.1	81.2	90.2	80.6	89.1	79.9	88.0	6.8	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.1	153.3	84.6	78.4	149.5	84.1	77.9	147.0	83.7	45.5	91.0	44.7	89.4	44.0	88.2	84.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max			
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
15.8	13.8	12.0	DB	32.0	99.1	2.5	1.6	30.2	100.2	28.7	101.2	27.3	102.1	25.4	103.3	
			WB	30.6	82.2	2.7	1.3	28.7	83.1	27.2	83.9	25.7	84.6	23.8	85.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	69.9	51.3	55.5	61.0	70.4	77.1	81.8	84.7	84.1	80.3	73.4	63.7	54.0
	DBStd	13.16	7.12	9.15	7.81	6.57	4.76	3.75	3.04	3.09	4.47	5.25	6.57	6.20
	HDD50	145	68	41	7	0	0	0	0	0	0	0	2	27
	HDD65	1366	427	289	174	28	0	0	0	0	0	5	98	345
	CDD50	7391	109	194	348	611	840	954	1076	1058	908	727	414	152
	CDD65	3139	3	23	50	189	376	504	611	593	458	267	60	5
	CDH74	30256	8	103	201	1074	3013	5220	7278	6770	4376	1854	341	18
	CDH80	11770	0	8	16	208	946	1972	3313	2981	1721	549	56	0
Wind	WSAvg	4.8	4.7	5.0	4.8	5.0	4.8	5.3	5.4	4.6	4.2	4.5	4.4	4.6
Precipitation	PrecAvg	67.4	3.1	3.5	7.0	8.3	11.6	11.4	6.3	5.7	3.7	1.9	2.6	2.3
	PrecMax	95.8	12.5	9.0	18.7	14.9	32.8	20.8	18.9	13.1	7.6	7.8	9.4	9.2
	PrecMin	45.8	0.1	0.2	2.8	1.5	3.2	5.4	1.4	1.3	0.4	0.0	0.0	0.1
	PrecStd	12.3	2.6	2.2	3.2	3.6	6.1	4.9	4.2	3.0	2.0	2.2	2.4	2.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.1	81.3	81.9	87.7	92.5	95.1	98.0	97.8	95.7	91.8	85.3	76.6
		MCWB	63.8	68.0	69.0	73.9	76.9	79.3	78.8	78.5	78.5	75.6	70.7	66.7
	2%	DB	70.5	77.3	78.9	84.7	90.0	92.8	95.8	95.5	93.2	88.1	81.3	72.1
		MCWB	61.4	66.2	68.0	72.6	76.1	78.3	78.7	78.5	77.5	72.6	68.1	61.8
	5%	DB	66.9	73.8	76.1	82.4	87.8	90.9	93.9	93.8	91.1	85.7	78.2	68.0
		MCWB	59.0	64.8	67.1	71.8	75.4	78.0	78.8	78.4	77.2	71.2	65.9	58.4
	10%	DB	63.0	70.0	73.4	80.0	85.4	88.8	92.0	91.9	88.9	83.2	74.7	64.5
		MCWB	56.0	62.8	65.9	71.1	75.0	77.9	78.5	78.3	76.4	70.0	64.3	56.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.2	70.8	73.5	76.9	80.5	81.6	82.0	82.2	81.0	77.9	73.8	70.0
		MCDB	71.5	77.9	78.5	83.9	88.3	89.8	91.6	91.9	90.5	87.3	81.1	73.9
	2%	WB	63.5	68.0	70.9	75.2	78.8	80.6	81.2	81.1	80.0	76.2	71.6	64.7
		MCDB	68.6	74.8	76.1	81.8	85.9	88.2	90.4	90.1	88.6	83.4	77.7	68.2
	5%	WB	60.4	65.7	68.9	73.9	77.8	79.8	80.5	80.3	79.0	74.9	69.5	61.1
		MCDB	66.0	72.3	73.9	79.4	84.2	87.1	89.2	88.8	86.8	81.3	74.8	66.1
	10%	WB	57.2	63.3	66.9	72.9	76.8	79.1	79.8	79.6	78.1	73.5	67.1	57.7
		MCDB	61.7	69.5	72.0	77.9	82.6	86.0	88.0	87.5	85.2	79.4	72.1	62.9
Mean Daily Temperature Range	5% DB	MDBR	12.5	12.1	11.2	11.2	11.8	11.2	13.0	13.7	14.0	15.5	15.3	14.7
		MCDBR	20.4	18.9	17.4	15.9	16.1	14.6	16.2	17.1	17.4	19.1	21.0	21.3
		MCWBR	10.7	8.3	7.7	6.2	5.2	4.0	3.9	4.2	4.4	5.7	8.1	10.4
	5% WB	MCDBR	16.0	15.2	12.8	11.5	11.9	11.8	14.1	14.6	15.2	14.2	14.8	15.1
		MCWBR	9.5	8.2	7.9	6.0	5.1	4.6	4.5	4.7	4.6	5.2	7.5	8.9
Clear-Sky Solar Irradiance	taub	0.629	0.685	0.796	0.778	0.642	0.606	0.578	0.634	0.654	0.671	0.587	0.580	
	taud	1.643	1.583	1.429	1.497	1.784	1.876	1.945	1.789	1.724	1.637	1.778	1.757	
	Ebn at Noon	197	198	185	194	222	229	235	222	213	198	207	203	
	Edh at Noon	72	82	100	95	71	64	60	70	73	76	62	62	
All-Sky Solar Radiation	RadAvg	756	771	821	933	1151	1257	1579	1506	1358	1221	962	863	
	RadStd	152	163	138	167	176	178	157	114	103	164	154	176	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	+0.63	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	+0.61	N/A	N/A	N/A	N/A	N/A	+99

Nomenclature: See separate page