

XIAMEN, China

WMO: 591340

Lat: 24.4860N

Lon: 118.0798E

Elev: 139

StdP: 99.67

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.9	8.0	-4.0	2.7	11.8	-1.4	3.4	11.7	9.3	12.1	8.5	12.1	3.6	70	0.371

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.3	34.9	26.3	34.0	26.4	33.0	26.2	28.0	31.4	27.6	30.9	27.2	30.5	4.3	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.1	23.3	29.5	26.9	23.0	29.4	26.2	22.0	29.0	91.2	31.7	89.0	31.1	87.3	30.6	30.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.7	7.7	6.9	DB	4.8	37.3	1.6	1.1	3.6	38.1	2.7	38.7	1.8	39.3	0.6	40.1	
			WB	1.3	28.9	1.8	0.6	0.0	29.3	-1.1	29.7	-2.1	30.0	-3.5	30.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	22.3	14.2	14.5	16.6	20.9	24.6	27.5	29.5	29.2	27.9	24.8	20.9	16.3
	DBStd	6.12	2.87	3.35	3.41	3.28	2.58	2.14	1.50	1.66	1.87	2.21	2.62	2.87
	HDD10.0	7	3	3	1	0	0	0	0	0	0	0	0	1
	HDD18.3	417	131	114	76	13	1	0	0	0	0	0	7	76
	CDD10.0	4488	133	128	205	326	451	525	604	596	538	459	327	196
	CDD18.3	1857	3	6	22	90	193	275	346	337	288	201	84	12
	CDH23.3	17662	7	21	89	425	1315	2813	4281	4049	3032	1333	278	19
	CDH26.7	6649	0	2	13	97	357	981	1944	1767	1129	322	37	1
Wind	WSAvg	3.1	3.2	3.1	2.9	2.8	2.7	2.9	3.0	2.9	3.3	3.8	3.5	3.4
Precipitation	PrecAvg	1185	36	64	101	146	156	196	136	147	116	28	35	24
	PrecMax	1772	158	269	440	494	347	398	334	420	363	172	167	87
	PrecMin	840	1	2	9	30	23	38	11	3	5	0	0	0
	PrecStd	289	36	67	81	103	75	95	97	91	104	42	41	25
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.1	26.0	28.2	31.2	33.2	34.9	36.1	36.1	35.0	32.8	29.8	25.2
		MCWB	17.3	19.1	21.0	23.1	26.3	26.7	26.5	26.3	25.5	24.2	22.3	19.2
	2%	DB	21.8	23.1	25.9	29.2	31.2	33.1	35.0	34.9	33.3	31.0	27.8	23.2
		MCWB	16.5	17.9	19.9	22.7	25.3	26.5	26.4	26.2	25.5	23.4	21.0	17.8
	5%	DB	19.9	20.9	23.8	27.5	30.0	32.1	34.0	33.9	32.2	29.8	26.1	21.9
		MCWB	15.1	16.3	18.5	22.1	24.6	26.4	26.6	26.5	25.2	22.7	20.1	16.9
	10%	DB	18.2	19.1	21.4	25.9	28.8	31.0	33.0	32.8	31.2	28.2	24.9	20.5
		MCWB	14.4	15.3	17.2	21.2	23.7	26.1	26.4	26.3	24.8	21.8	19.7	16.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.0	21.0	22.6	25.3	27.8	28.4	28.6	28.6	27.9	26.1	23.8	20.8
		MCDB	22.2	24.4	26.8	28.8	30.9	31.8	33.0	32.5	31.5	29.3	27.1	23.5
	2%	WB	17.5	18.9	21.0	24.1	26.7	27.7	27.9	27.8	27.2	25.2	22.7	19.5
		MCDB	20.1	21.3	24.2	27.2	29.7	30.6	31.6	31.1	30.5	28.5	25.4	21.8
	5%	WB	16.3	17.4	19.7	23.2	25.9	27.2	27.5	27.4	26.6	24.4	21.9	18.4
		MCDB	18.9	19.9	22.3	26.0	28.5	30.1	31.1	30.8	29.8	27.9	24.6	20.9
	10%	WB	15.3	16.1	18.3	22.2	25.2	26.7	27.0	27.0	26.1	23.5	21.0	17.2
		MCDB	17.6	18.5	20.7	24.9	27.5	29.5	30.6	30.4	29.2	27.1	23.9	19.6
Mean Daily Temperature Range	5% DB	MDBR	7.1	7.2	7.6	7.7	7.1	6.5	7.3	7.2	7.2	7.2	7.2	7.3
		MCDBR	9.1	9.9	10.5	9.9	8.7	7.8	8.5	8.6	8.1	8.0	8.3	8.4
		MCWBR	4.8	5.5	5.7	4.9	4.0	3.1	3.2	3.3	3.5	3.9	4.1	4.7
	5% WB	MCDBR	8.0	9.2	9.8	9.1	8.0	7.0	7.7	7.6	7.3	7.1	7.1	7.3
		MCWBR	4.8	5.8	6.1	5.0	4.1	3.2	3.3	3.4	3.4	3.6	4.0	4.5
Clear-Sky Solar Irradiance	taub	0.543	0.608	0.706	0.706	0.594	0.542	0.517	0.573	0.591	0.575	0.534	0.522	
	taud	1.848	1.744	1.584	1.635	1.913	2.065	2.140	1.962	1.891	1.864	1.939	1.919	
	Ebn at Noon	699	685	644	660	736	769	789	746	720	703	704	698	
	Edh at Noon	185	219	269	261	197	168	156	186	195	191	168	166	
All-Sky Solar Radiation	RadAvg	2.93	3.04	3.49	3.93	4.31	4.72	5.76	5.21	4.75	4.10	3.22	2.93	
	RadStd	0.43	0.53	0.46	0.60	0.66	0.54	0.42	0.48	0.42	0.50	0.34	0.37	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.46	N/A	N/A	+0.35	+0.33	N/A	N/A	N/A	+121	+112
(47)	Regional (8 neighbors)	+0.36	N/A	N/A	+0.53	+0.18	+0.22	N/A	N/A	+136	+105

Nomenclature: See separate page