

NAPO, China

WMO: 592090

Lat: 23.4142N

Lon: 105.8200E

Elev: 794

StdP: 92.14

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.5	4.8	-1.6	3.6	8.0	0.0	4.1	7.2	5.5	15.3	4.7	14.9	1.1	290	0.256

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.4	32.2	23.0	31.2	23.0	30.3	22.7	24.6	29.5	24.2	28.8	23.8	28.1	2.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.2	19.9	26.5	23.0	19.5	26.2	22.6	19.1	25.9	79.6	29.6	78.0	29.1	76.4	28.3	28.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.5	3.9	3.4	DB	0.9	34.1	1.5	0.7	-0.2	34.7	-1.1	35.1	-2.0	35.5	-3.1	36.1	
			WB	0.1	25.5	1.3	0.8	-0.8	26.0	-1.6	26.5	-2.4	26.9	-3.3	27.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.0	11.8	14.2	17.6	21.7	24.0	25.3	25.6	25.2	23.5	20.7	17.1	12.9	
	DBStd	5.81	4.18	4.91	4.07	3.67	2.81	1.89	1.52	1.54	2.20	2.60	3.28	3.40	
	HDD10.0	54	29	14	1	0	0	0	0	0	0	0	1	9	
	HDD18.3	658	204	132	65	13	1	0	0	0	1	9	62	172	
	CDD10.0	3705	86	132	237	351	434	461	484	472	406	332	212	99	
	CDD18.3	1269	3	16	43	113	177	211	226	214	157	83	24	4	
	CDH23.3	7829	4	58	181	671	1236	1479	1552	1370	899	314	62	5	
	CDH26.7	2070	0	4	31	186	357	381	423	419	230	37	2	0	
Wind	WSAvg	1.5	1.6	1.8	1.9	1.9	1.7	1.5	1.4	1.2	1.2	1.3	1.4	1.4	
Precipitation	PrecAvg	1403	17	19	36	65	164	244	258	282	158	91	51	19	
	PrecMax	1875	40	59	170	127	385	416	514	592	291	221	136	110	
	PrecMin	996	1	0	2	7	41	66	121	102	64	17	4	0	
	PrecStd	215	11	15	41	35	69	97	99	117	55	49	41	23	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.8	27.3	29.4	32.5	33.4	32.4	32.7	33.0	31.8	29.1	26.9	23.9	
		MCWB	16.2	16.9	18.9	21.0	22.7	23.8	23.8	23.5	22.9	20.6	19.7	17.4	
	2%	DB	21.4	25.2	27.3	30.6	31.6	31.2	31.5	31.5	30.4	27.7	25.1	21.7	
		MCWB	15.7	17.1	19.1	21.2	22.6	23.6	23.6	23.3	22.2	20.5	18.6	16.1	
	5%	DB	19.6	23.2	25.4	28.9	30.1	30.1	30.3	30.4	29.3	26.5	23.7	20.0	
		MCWB	15.2	16.8	18.8	21.1	22.0	23.3	23.5	23.1	21.9	20.0	17.8	15.1	
	10%	DB	17.9	21.1	23.4	27.2	28.6	28.9	29.1	29.2	28.0	25.2	22.3	18.2	
		MCWB	14.6	16.4	18.4	20.8	21.8	23.2	23.3	22.9	21.7	19.7	17.6	14.4	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.5	18.7	20.7	23.0	24.4	25.0	25.1	25.0	24.2	22.7	20.8	18.4
			MCDB	20.7	24.2	26.2	28.9	30.1	29.9	30.3	30.3	29.0	26.0	24.6	22.3
		2%	WB	16.3	18.0	19.9	22.3	23.7	24.5	24.5	24.3	23.5	21.8	20.0	17.1
			MCDB	20.1	22.6	24.9	27.6	28.8	29.1	29.3	29.1	27.8	25.3	23.2	20.6
5%		WB	15.6	17.3	19.3	21.7	23.2	24.1	24.1	23.9	23.0	21.3	19.3	16.1	
		MCDB	19.1	21.7	24.0	26.7	27.8	28.4	28.5	28.4	26.8	24.5	22.4	19.0	
10%		WB	14.8	16.6	18.6	21.2	22.7	23.7	23.6	23.5	22.5	20.7	18.5	15.0	
		MCDB	17.9	20.6	22.9	25.9	27.0	27.6	27.6	27.5	26.0	23.8	21.4	17.8	
Mean Daily Temperature Range	5% DB	MDBR	5.6	6.0	6.6	6.9	7.0	6.3	6.4	7.3	7.7	6.8	7.3	6.7	
		MCDBR	8.4	9.7	9.4	9.4	9.3	8.1	8.7	9.8	10.0	9.4	9.5	9.5	
		MCWBR	3.7	3.3	3.3	2.8	2.5	2.4	2.5	2.9	2.9	3.2	3.7	4.2	
	5% WB	MCDBR	7.0	8.2	8.3	7.9	7.2	6.5	7.3	8.2	7.4	6.7	6.3	7.3	
		MCWBR	3.3	3.3	3.4	2.8	2.5	2.3	2.4	2.9	2.5	2.6	2.7	3.6	
Clear-Sky Solar Irradiance	taub	0.521	0.528	0.683	0.645	0.504	0.499	0.476	0.530	0.549	0.610	0.530	0.556		
	taud	1.836	1.859	1.554	1.690	2.116	2.157	2.211	2.035	1.948	1.735	1.864	1.752		
	Ebn at Noon	724	757	663	703	806	803	822	780	756	678	710	668		
	Edh at Noon	189	196	279	247	161	153	145	173	185	219	182	199		
All-Sky Solar Radiation	RadAvg	2.25	3.08	3.55	4.39	4.63	4.33	4.60	4.50	4.16	3.20	3.06	2.37		
	RadStd	0.46	0.58	0.33	0.43	0.50	0.44	0.30	0.29	0.31	0.33	0.40	0.30		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+0.53	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	+0.28	N/A	N/A	+0.56	N/A	N/A	N/A	N/A	N/A	+74

Nomenclature: See separate page