

BAISE, China

WMO: 592110

Lat: 23.9029N

Lon: 106.6065E

Elev: 581

StdP: 14.39

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	43.2	45.5	30.7	25.4	54.0	34.1	29.4	53.5	12.0	67.6	10.4	66.2	2.2	0	0.297

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.2	97.0	78.2	95.2	78.2	93.7	78.0	81.8	90.7	81.0	89.8	80.3	88.8	6.4	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.9	158.4	84.9	78.9	153.3	84.7	78.1	149.4	84.2	46.3	91.4	45.4	89.8	44.6	89.1	85.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.6	9.8	8.5	38.9	101.0	2.1	2.0	37.4	102.4	36.2	103.6	35.1	104.7	33.5	106.2		
(5)			37.7	83.0	2.0	1.1	36.3	83.9	35.1	84.5	34.0	85.2	32.5	86.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	73.2	57.1	61.5	67.6	76.2	80.7	83.2	84.1	83.8	80.9	75.3	67.7	59.4		
	DBStd	11.12	6.85	8.26	7.49	6.94	5.24	3.50	3.12	3.07	4.02	4.87	5.56	5.59		
	HDD50	17	11	4	0	0	0	0	0	0	0	0	0	2		
	HDD65	706	260	156	60	6	0	0	0	0	0	1	33	190		
	CDD50	8483	233	327	546	787	951	995	1059	1047	928	783	532	295		
	CDD65	3697	17	59	141	343	486	545	594	582	478	319	115	18		
	CDH74	36746	86	418	980	3103	5174	6200	6943	6436	4591	2135	592	88		
	CDH80	15309	11	125	336	1313	2338	2667	3075	2787	1851	680	114	12		
(14) Wind	WSAvg	3.4	3.2	3.6	4.1	4.4	4.0	3.6	3.6	3.1	2.9	2.7	2.7	2.7		
(15) Precipitation	PrecAvg	42.9	0.6	0.7	1.3	2.7	5.9	7.2	7.8	7.6	3.9	2.8	1.8	0.6		
	PrecMax	64.1	1.9	2.5	6.0	7.8	14.6	16.9	15.3	17.0	11.9	9.2	5.9	2.9		
	PrecMin	28.7	0.0	0.1	0.1	0.1	0.5	0.8	1.3	0.4	1.1	0.2	0.0	0.0		
	PrecStd	8.4	0.5	0.5	1.4	1.7	3.3	3.7	3.6	3.4	2.3	1.8	1.5	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.9	89.3	92.7	98.5	99.2	97.8	98.1	97.5	96.6	91.6	87.2	81.4		
		MCWB	66.6	68.8	72.1	74.4	78.1	80.5	79.7	78.7	77.0	75.7	73.1	69.3		
	2%	DB	76.2	84.2	87.7	94.4	96.0	95.1	95.8	95.4	93.7	89.0	83.1	76.0		
		MCWB	65.3	68.6	71.5	75.0	77.9	79.5	79.4	78.6	77.2	74.3	70.7	65.7		
	5%	DB	71.8	79.3	83.6	91.1	93.3	93.0	93.9	93.7	91.6	86.6	80.4	71.8		
		MCWB	62.8	66.7	70.4	74.9	76.7	78.9	79.3	78.7	76.6	73.1	68.7	61.8		
	10%	DB	67.6	74.7	79.5	87.6	90.6	90.9	91.8	91.6	89.2	84.1	77.4	68.3		
		MCWB	60.3	64.7	68.7	73.9	75.8	78.5	79.1	78.7	76.2	72.0	67.2	59.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.4	70.8	74.5	78.8	81.1	82.7	83.1	82.5	80.9	78.2	75.2	70.8		
		MCDB	78.1	84.4	87.2	89.7	93.5	91.9	90.6	91.1	89.8	87.4	83.0	78.7		
	2%	WB	66.0	69.1	72.7	77.2	79.8	81.6	81.8	81.2	79.8	76.9	73.1	67.5		
		MCDB	74.0	81.1	84.2	88.7	90.9	90.6	90.2	89.9	88.3	85.1	79.6	73.6		
	5%	WB	63.9	67.4	71.2	76.0	78.8	80.7	80.9	80.4	78.8	75.7	71.6	64.7		
		MCDB	70.7	77.4	81.0	87.1	89.0	89.2	89.3	89.0	87.0	82.8	77.6	70.3		
	10%	WB	61.8	65.6	69.7	74.7	77.7	79.8	80.1	79.7	77.9	74.5	69.6	61.8		
		MCDB	67.1	73.4	78.0	85.2	87.1	87.7	88.2	87.7	85.3	80.6	75.0	66.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.9	13.3	13.7	14.8	14.5	12.8	13.2	14.1	14.3	13.6	14.3	13.5		
		MCDBR	20.7	23.3	21.2	20.7	18.7	16.4	16.8	17.8	17.9	17.6	18.9	20.4		
		MCWBR	10.0	8.8	7.5	5.7	4.9	4.3	4.3	4.5	4.3	5.2	7.2	9.5		
	5% WB	MCDBR	18.9	21.7	19.6	18.3	15.5	13.7	14.4	15.2	14.4	14.6	15.3	17.2		
		MCWBR	9.5	8.9	8.0	6.4	5.2	4.7	4.8	5.0	4.5	5.0	6.8	9.2		
(40) Clear-Sky Solar Irradiance	taub		0.619	0.623	0.772	0.731	0.577	0.567	0.537	0.599	0.628	0.714	0.622	0.652		
	taud		1.647	1.675	1.440	1.560	1.941	1.983	2.064	1.877	1.778	1.562	1.690	1.597		
	Ebn at Noon		201	214	191	204	238	238	245	231	220	190	199	185		
	Edh at Noon		72	75	99	89	61	58	53	64	69	82	69	74		
(44) All-Sky Solar Radiation	RadAvg		645	883	1027	1305	1402	1340	1485	1444	1317	1026	923	716		
	RadStd		154	166	113	140	150	154	100	87	106	108	133	109		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+144
(47) Regional (6 neighbors)		N/A	N/A	N/A	+0.86	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page