

BAISE, China

WMO: 592110

Lat: 23.9029N

Lon: 106.6065E

Elev: 177

StdP: 99.22

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.2	7.5	-0.7	3.6	12.2	1.2	4.2	11.9	5.4	19.8	4.7	19.0	1.0	0	0.297

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.3	36.1	25.7	35.1	25.7	34.3	25.6	27.7	32.6	27.2	32.1	26.8	31.5	2.9	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.6	22.6	29.4	26.1	21.9	29.3	25.6	21.3	29.0	89.9	33.0	87.7	32.1	85.9	31.7	29.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.2	4.4	3.8	DB	3.9	38.3	1.2	1.1	3.0	39.1	2.3	39.8	1.7	40.4	0.9	41.2	
			WB	3.2	28.4	1.1	0.6	2.4	28.8	1.7	29.2	1.1	29.5	0.3	30.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	22.9	14.0	16.4	19.8	24.6	27.0	28.4	29.0	28.8	27.2	24.0	19.8	15.2
	DBStd	6.18	3.80	4.59	4.16	3.86	2.91	1.94	1.73	1.70	2.23	2.71	3.09	3.10
	HDD10.0	9	6	2	0	0	0	0	0	0	0	0	0	1
	HDD18.3	392	144	87	33	3	0	0	0	0	1	18	106	
	CDD10.0	4713	129	182	303	437	528	553	588	582	516	435	296	164
	CDD18.3	2054	9	33	78	191	270	303	330	323	266	177	64	10
	CDH23.3	20414	48	232	544	1724	2874	3444	3857	3576	2551	1186	329	49
CDH26.7	8505	6	69	187	729	1299	1482	1708	1548	1028	378	63	7	
Wind	WSAvg	1.5	1.4	1.6	1.9	1.9	1.8	1.6	1.6	1.4	1.3	1.2	1.2	1.2
Precipitation	PrecAvg	1090	16	18	34	69	150	182	197	194	99	71	46	14
	PrecMax	1628	49	63	152	197	372	428	388	431	302	233	149	74
	PrecMin	729	1	3	3	3	12	21	34	9	27	4	0	0
	PrecStd	213	12	13	36	44	85	94	92	87	58	45	39	18
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.2	31.8	33.7	36.9	37.4	36.5	36.7	36.4	35.9	33.1	30.7	27.4
		MCWB	19.2	20.4	22.3	23.6	25.6	26.9	26.5	25.9	25.0	24.3	22.8	20.7
	2%	DB	24.6	29.0	31.0	34.7	35.5	35.1	35.4	35.2	34.3	31.7	28.4	24.4
		MCWB	18.5	20.3	21.9	23.9	25.5	26.4	26.4	25.9	25.1	23.5	21.5	18.7
	5%	DB	22.1	26.3	28.7	32.8	34.0	33.9	34.4	34.3	33.1	30.3	26.9	22.1
		MCWB	17.1	19.3	21.3	23.8	24.8	26.1	26.3	25.9	24.8	22.8	20.4	16.6
	10%	DB	19.8	23.7	26.4	30.9	32.5	32.7	33.2	33.1	31.8	29.0	25.2	20.2
		MCWB	15.7	18.2	20.4	23.3	24.3	25.8	26.2	26.0	24.5	22.2	19.6	15.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.2	21.6	23.6	26.0	27.3	28.2	28.4	28.0	27.2	25.6	24.0	21.6
		MCDB	25.6	29.1	30.7	32.1	34.2	33.3	32.6	32.8	32.1	30.8	28.4	26.0
	2%	WB	18.9	20.6	22.6	25.1	26.6	27.5	27.7	27.4	26.5	24.9	22.8	19.7
		MCDB	23.3	27.3	29.0	31.5	32.7	32.6	32.3	32.2	31.3	29.5	26.5	23.1
	5%	WB	17.7	19.7	21.8	24.4	26.0	27.0	27.2	26.9	26.0	24.3	22.0	18.1
		MCDB	21.5	25.2	27.2	30.6	31.7	31.8	31.9	31.7	30.5	28.2	25.3	21.3
	10%	WB	16.6	18.7	20.9	23.7	25.4	26.6	26.7	26.5	25.5	23.6	20.9	16.5
		MCDB	19.5	23.0	25.6	29.6	30.6	31.0	31.2	30.9	29.6	27.0	23.9	19.2
Mean Daily Temperature Range	5% DB	MDBR	6.6	7.4	7.6	8.2	8.0	7.1	7.3	7.8	8.0	7.6	8.0	7.5
		MCDBR	11.5	13.0	11.8	11.5	10.4	9.1	9.4	9.9	9.8	10.5	11.4	
		MCWBR	5.5	4.9	4.2	3.2	2.7	2.4	2.4	2.5	2.4	2.9	4.0	5.3
	5% WB	MCDBR	10.5	12.1	10.9	10.2	8.6	7.6	8.0	8.5	8.0	8.1	8.5	9.6
		MCWBR	5.3	4.9	4.5	3.5	2.9	2.6	2.7	2.8	2.5	2.8	3.8	5.1
Clear-Sky Solar Irradiance	taub	0.619	0.623	0.772	0.731	0.577	0.567	0.537	0.599	0.628	0.714	0.622	0.652	
	taud	1.647	1.675	1.440	1.560	1.941	1.983	2.064	1.877	1.778	1.562	1.690	1.597	
	Ebn at Noon	633	675	601	644	749	750	773	727	693	598	626	583	
	Edh at Noon	228	236	312	281	191	182	168	202	219	260	216	232	
All-Sky Solar Radiation	RadAvg	2.03	2.79	3.24	4.11	4.42	4.22	4.68	4.55	4.15	3.23	2.91	2.26	
	RadStd	0.48	0.52	0.36	0.44	0.47	0.49	0.31	0.28	0.34	0.34	0.42	0.34	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+80
Regional (6 neighbors)	N/A	N/A	N/A	+0.48	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page