

GUIPING, China

WMO: 592540

Lat: 23.3956N

Lon: 110.0841E

Elev: 44

StdP: 100.80

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.6	6.8	-1.6	3.3	12.0	0.7	4.0	11.1	5.4	15.3	4.2	15.1	1.3	40	0.283

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.6	35.2	26.7	34.4	26.6	33.6	26.4	27.8	32.4	27.5	31.9	27.1	31.4	2.0	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.7	22.5	29.6	26.4	22.0	29.4	26.1	21.6	29.2	89.6	32.6	87.9	32.1	86.3	31.6	30.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.9	3.8	3.2	4.1	37.1	1.3	1.0	3.2	37.9	2.4	38.5	1.7	39.1	0.8	39.8		
			2.7	28.6	1.3	0.6	1.8	29.0	1.1	29.4	0.3	29.7	-0.6	30.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	22.6	13.3	15.0	17.9	22.8	26.4	28.3	29.4	29.4	28.0	25.0	20.4	15.4	(6)
(7)		DBStd	6.53	4.03	4.81	3.94	3.56	2.45	1.92	1.88	1.72	2.12	2.64	3.31	3.31	(7)
(8)		HDD10.0	24	13	8	1	0	0	0	0	0	0	0	0	2	(8)
(9)		HDD18.3	462	162	114	58	8	0	0	0	0	0	1	17	102	(9)
(10)		CDD10.0	4638	117	149	244	383	509	550	601	602	539	465	311	169	(10)
(11)		CDD18.3	2035	7	22	44	141	251	300	342	343	290	207	78	11	(11)
(12)		CDH23.3	19872	11	86	154	878	2252	3243	4073	4096	3097	1592	365	26	(12)
(13)	CDH26.7	7634	0	16	18	219	751	1239	1809	1806	1224	488	63	1	(13)	
(14)	Wind	WSAvg	1.4	1.3	1.3	1.3	1.4	1.5	1.5	1.6	1.5	1.4	1.3	1.3	1.3	(14)
(15)	Precipitation	PrecAvg	1670	57	81	99	205	280	246	199	205	107	84	66	40	(15)
(16)		PrecMax	2485	163	293	218	528	529	596	460	571	335	276	214	175	(16)
(17)		PrecMin	1035	6	8	10	85	60	64	77	34	14	3	0	1	(17)
(18)		PrecStd	324	43	63	51	111	106	124	110	123	65	63	58	39	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.8	29.1	28.7	32.3	34.5	35.3	36.4	36.1	35.1	33.2	30.2	25.7	(19)
(20)			MCWB	19.2	22.3	22.8	25.4	26.7	27.0	26.8	26.6	26.2	24.3	23.0	19.7	(20)
(21)		2%	DB	22.6	25.7	26.6	30.7	33.1	34.1	35.2	35.0	34.0	31.8	28.5	23.8	(21)
(22)			MCWB	17.9	20.3	21.8	24.5	26.0	26.8	26.8	26.6	26.0	23.8	21.2	18.8	(22)
(23)		5%	DB	20.9	23.7	24.9	29.3	31.8	33.1	34.2	34.2	33.0	30.7	27.0	22.2	(23)
(24)			MCWB	16.9	19.4	21.2	23.9	25.4	26.7	26.7	26.5	25.8	23.2	20.5	17.0	(24)
(25)		10%	DB	19.4	21.8	23.5	27.7	30.5	31.9	33.1	33.2	32.0	29.5	25.5	20.6	(25)
(26)			MCWB	16.3	18.6	20.4	23.4	25.1	26.5	26.6	26.5	25.4	22.7	19.8	16.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.4	22.5	23.9	26.3	27.7	28.2	28.3	27.7	26.4	24.2	22.4	(27)	
(28)			MCDWB	23.1	27.4	26.7	30.8	32.3	32.9	33.4	32.5	31.5	30.5	27.6	24.4	(28)
(29)		2%	WB	19.1	21.2	23.0	25.4	27.0	27.7	27.7	27.2	25.6	23.4	20.2	(29)	
(30)			MCDWB	21.3	24.8	25.5	29.4	31.3	32.0	32.6	32.1	31.4	29.3	26.5	22.0	(30)
(31)		5%	WB	18.0	20.1	22.0	24.7	26.5	27.2	27.3	26.7	24.8	22.6	18.6	(31)	
(32)			MCDWB	20.4	22.9	24.0	28.1	30.3	31.3	31.9	31.6	30.9	28.6	25.5	20.9	(32)
(33)		10%	WB	16.7	18.9	20.9	24.1	25.9	26.8	26.9	27.0	26.3	24.1	21.5	17.0	(33)
(34)			MCDWB	19.0	21.3	23.0	26.9	29.3	30.6	31.3	31.2	30.2	27.7	24.3	19.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.4	5.3	5.0	5.3	6.0	5.9	6.4	6.6	6.7	7.1	7.0	6.5	(35)
(36)			MCDBR	8.2	8.8	7.8	8.0	8.2	7.6	8.1	8.2	8.1	8.2	8.9	8.7	(36)
(37)			MCWBR	3.9	3.8	3.6	3.1	2.7	2.3	2.1	2.1	2.2	2.3	3.2	4.0	(37)
(38)		5% WB	MCDBR	6.5	7.3	6.2	6.7	6.7	6.5	7.1	7.2	7.1	6.8	6.5	6.3	(38)
(39)			MCWBR	3.6	3.8	3.8	3.3	2.8	2.5	2.4	2.4	2.4	2.5	3.1	3.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.648	0.693	0.842	0.804	0.622	0.579	0.553	0.630	0.676	0.742	0.625	0.640	(40)	
(41)		taud	1.620	1.580	1.364	1.466	1.839	1.963	2.027	1.808	1.684	1.524	1.711	1.661	(41)	
(42)		Ebn at Noon	614	625	560	598	716	742	761	705	659	581	628	599	(42)	
(43)		Edh at Noon	235	260	337	309	212	186	174	217	241	271	213	219	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.16	2.33	2.54	3.24	4.01	4.18	4.86	4.85	4.49	4.00	3.12	2.56	(44)	
(45)		RadStd	0.54	0.43	0.39	0.42	0.38	0.58	0.49	0.33	0.32	0.33	0.49	0.53	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only		N/A	N/A	N/A	+0.46	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)		N/A	N/A	N/A	+0.31	N/A	N/A	N/A	N/A	+54

Nomenclature: See separate page