

GUANGZHOU, China

WMO: 592870

Lat: 23.2099N

Lon: 113.4822E

Elev: 235

StdP: 14.57

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	42.6	44.6	19.2	14.6	53.0	24.8	19.0	53.7	18.5	52.8	16.5	53.1	7.5	0	0.332

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.7	96.7	79.2	95.0	79.1	93.3	79.0	82.1	89.3	81.5	88.6	80.8	87.9	6.4	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.6	160.1	85.6	79.3	153.4	84.7	79.0	152.0	84.5	46.3	90.4	45.6	89.2	45.0	88.5	85.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.4	14.1	12.2	38.6	99.8	2.8	2.0	36.6	101.3	34.9	102.5	33.4	103.6	31.3	105.1
			33.5	83.7	3.1	0.7	31.3	84.2	29.5	84.6	27.7	85.0	25.5	85.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	73.7	58.1	60.9	65.8	73.7	79.8	83.6	85.4	85.1	82.7	77.6	69.7	61.0
	DBStd	11.18	7.07	8.47	7.02	5.93	4.23	3.30	3.04	2.94	3.66	4.28	5.95	6.13
	HDD50	29	14	11	1	0	0	0	0	0	0	0	0	3
	HDD65	667	232	164	79	10	0	0	0	0	0	0	26	156
	CDD50	8672	265	316	491	711	925	1008	1097	1087	982	856	591	343
	CDD65	3834	19	49	104	271	460	558	632	622	532	391	166	30
	CDH74	39612	52	180	423	1793	4397	6461	7957	7762	6104	3425	944	114
	CDH80	15970	1	13	39	411	1510	2687	3772	3636	2599	1114	182	6
Wind	WSAvg	5.3	5.6	5.4	5.1	5.0	4.9	5.2	5.3	4.7	5.1	5.5	5.5	6.0
Precipitation	PrecAvg	74.0	2.2	2.2	3.7	7.6	11.7	13.7	9.3	10.1	7.5	2.7	1.7	1.5
	PrecMax	111.0	16.9	8.7	10.3	15.7	30.1	34.7	15.8	18.7	20.7	10.1	6.6	5.7
	PrecMin	50.3	0.0	0.0	0.9	1.1	5.1	5.7	2.0	1.7	2.4	0.0	0.0	0.0
	PrecStd	15.0	3.1	2.1	2.4	4.0	5.8	6.0	3.6	4.5	4.1	2.8	1.7	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.7	82.2	83.8	89.6	94.8	96.8	98.9	98.7	96.7	93.1	87.6	80.7
		MCWB	66.0	69.8	71.5	74.9	78.4	79.7	79.5	79.4	78.5	75.1	72.0	68.0
	2%	DB	75.2	78.8	80.7	86.9	91.5	94.0	96.7	96.6	94.6	89.8	84.3	77.1
		MCWB	64.2	67.5	70.0	74.7	77.7	79.4	79.6	79.0	78.2	73.4	70.2	65.2
	5%	DB	72.0	76.0	78.7	84.3	89.5	92.3	94.8	94.7	92.6	87.8	82.2	74.2
		MCWB	62.2	66.3	69.3	74.0	76.9	79.3	79.6	79.1	77.7	72.7	68.8	63.5
	10%	DB	69.6	73.3	76.1	82.3	87.6	90.1	92.8	92.9	90.4	85.9	79.2	71.5
		MCWB	61.3	65.6	68.5	73.4	76.6	79.1	79.7	79.1	76.9	72.0	67.4	60.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.0	72.9	74.9	79.0	81.9	82.8	82.9	82.7	81.8	79.0	75.7	72.5
		MCDB	74.2	77.7	79.5	85.2	88.2	89.7	91.0	90.3	89.6	86.4	82.3	76.6
	2%	WB	66.9	70.4	73.3	77.4	80.5	81.8	81.9	81.8	80.7	77.6	74.0	69.1
		MCDB	72.5	75.4	77.6	82.9	86.7	88.3	89.5	89.1	88.1	84.6	80.3	74.4
	5%	WB	64.9	68.6	71.9	76.3	79.5	81.0	81.3	81.0	79.9	76.5	72.5	65.9
		MCDB	70.6	73.6	76.3	81.4	85.4	87.3	88.8	88.4	87.1	83.1	78.5	71.6
	10%	WB	62.5	66.6	70.2	75.2	78.7	80.3	80.6	80.3	79.1	75.4	70.7	63.0
		MCDB	67.9	72.2	74.8	80.1	84.4	86.4	88.0	87.6	86.2	82.0	76.8	69.3
Mean Daily Temperature Range	5% DB	MDBR	14.1	13.0	12.2	11.9	12.6	12.4	13.7	14.1	14.3	15.3	15.4	15.5
		MCDBR	18.1	17.3	15.8	14.9	15.7	15.4	16.8	17.6	17.0	17.2	18.0	18.8
		MCWBR	8.9	8.1	7.4	6.0	5.9	5.0	5.1	5.4	5.3	5.9	7.3	8.7
	5% WB	MCDBR	14.8	13.9	12.3	12.2	13.3	13.3	14.5	14.9	14.9	13.8	13.9	14.4
		MCWBR	8.7	8.3	7.5	6.2	6.3	5.3	5.4	5.6	5.4	5.4	7.2	8.3
Clear-Sky Solar Irradiance	taub	0.606	0.667	0.801	0.783	0.629	0.592	0.576	0.640	0.672	0.699	0.592	0.576	
	taud	1.720	1.646	1.446	1.510	1.831	1.931	1.968	1.792	1.708	1.609	1.807	1.803	
	Ebn at Noon	206	205	186	194	226	232	236	221	210	194	209	208	
	Edh at Noon	68	77	99	94	68	61	59	70	75	79	62	60	
All-Sky Solar Radiation	RadAvg	906	908	944	1026	1275	1340	1597	1535	1450	1338	1086	990	
	RadStd	151	150	136	183	171	183	146	118	101	136	139	157	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	Station Only	N/A	N/A	N/A	+1.21	N/A	N/A	N/A	N/A	N/A	N/A
	Regional (15 neighbors)	N/A	N/A	N/A	+0.49	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page