

XINYI, China

WMO: 594560

Lat: 22.3469N

Lon: 110.9250E

Elev: 467

StdP: 14.45

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	43.8	46.3	25.7	20.0	56.6	30.5	25.1	55.7	16.4	50.6	14.8	52.2	6.7	20	0.292

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.4	94.5	78.6	93.2	78.5	91.8	78.3	81.7	88.2	81.0	87.4	80.5	86.9	5.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.4	160.5	83.8	79.6	156.4	83.5	78.9	152.8	83.2	46.1	88.4	45.3	87.5	44.6	87.0	84.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.5	11.5	9.8	DB	41.1	97.2	3.0	1.4	38.9	98.2	37.1	99.0	35.4	99.7	33.2	100.7	
			WB	35.9	82.9	2.7	1.2	34.0	83.7	32.4	84.4	30.9	85.1	28.9	86.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	74.6	60.2	63.0	68.6	75.4	80.7	83.0	84.1	83.9	82.3	78.4	71.2	63.5
	DBStd	10.04	7.46	8.74	6.89	5.68	3.60	2.66	2.91	2.63	3.12	3.92	5.67	6.25
	HDD50	20	10	8	0	0	0	0	0	0	0	0	0	2
	HDD65	490	185	132	47	6	0	0	0	0	0	0	16	104
	CDD50	8990	326	373	576	763	950	991	1056	1051	968	879	637	420
	CDD65	3986	36	77	158	320	485	541	591	586	518	414	204	56
	CDH74	37046	120	316	757	2278	4548	5793	6729	6429	5292	3394	1161	229
	CDH80	13280	4	39	122	617	1579	2147	2806	2573	2000	1126	252	15
Wind	WSAvg	4.2	4.6	4.7	4.3	4.1	3.8	3.6	3.7	3.5	4.0	4.4	4.5	4.7
Precipitation	PrecAvg	70.1	1.6	2.5	2.7	8.5	12.0	12.5	8.5	10.8	5.8	2.9	1.5	0.9
	PrecMax	107.0	7.6	12.7	8.8	20.2	26.1	36.8	25.9	23.1	13.2	15.2	5.6	3.1
	PrecMin	41.7	0.0	0.1	0.2	1.9	2.7	3.1	1.5	1.7	0.8	0.0	0.0	0.0
	PrecStd	14.6	1.8	3.0	2.0	5.0	5.6	7.6	4.9	5.4	3.5	3.0	1.7	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.3	84.9	86.6	90.9	93.2	95.0	96.4	96.0	94.5	91.8	87.7	81.9
		MCWB	66.9	70.3	73.8	77.4	78.1	78.5	79.0	78.8	77.5	74.8	71.9	67.9
	2%	DB	77.6	80.4	83.3	88.6	91.4	93.1	94.6	94.2	92.7	89.8	85.2	79.4
		MCWB	66.0	68.0	72.2	75.8	77.6	79.1	79.0	78.6	77.3	74.2	70.3	66.9
	5%	DB	74.8	78.0	80.5	86.3	89.8	91.4	92.9	92.5	91.1	88.0	83.2	76.5
		MCWB	64.5	67.6	70.7	75.4	77.3	79.1	79.0	78.6	77.2	73.3	69.2	65.0
	10%	DB	71.9	75.4	78.1	83.9	87.8	89.4	90.9	90.6	89.3	86.1	80.7	73.7
		MCWB	63.0	67.0	70.0	74.6	76.9	79.0	79.1	78.7	76.5	72.2	68.3	63.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.8	72.5	75.4	79.8	81.6	82.4	82.6	82.5	81.2	78.4	75.8	73.9
		MCDB	76.6	79.9	82.7	87.2	88.0	88.0	89.9	89.6	87.4	86.5	82.0	78.3
	2%	WB	68.1	70.9	74.0	78.3	80.5	81.5	81.6	81.3	80.1	77.2	74.5	70.6
		MCDB	73.9	77.5	80.4	84.6	86.5	87.3	88.4	88.2	86.6	84.6	80.4	75.6
	5%	WB	66.5	69.7	72.9	77.1	79.6	80.8	80.8	80.6	79.4	76.3	73.4	68.1
		MCDB	72.9	75.3	78.6	83.2	85.7	86.8	87.4	87.3	85.6	83.1	79.3	72.9
	10%	WB	64.7	68.2	71.7	76.0	78.8	80.1	80.1	79.9	78.7	75.3	71.9	65.4
		MCDB	70.8	73.5	76.6	81.7	84.8	86.0	86.6	86.3	84.6	81.6	77.6	72.0
Mean Daily Temperature Range	5% DB	MDBR	13.4	12.5	12.0	11.5	12.3	11.5	12.4	12.6	12.9	14.0	14.6	14.4
		MCDBR	17.8	16.9	15.1	14.4	15.1	14.6	15.5	15.6	15.6	16.1	17.5	18.0
		MCWBR	7.7	6.6	5.9	4.7	4.5	3.8	3.5	3.8	4.0	4.5	6.0	7.7
	5% WB	MCDBR	14.7	13.2	12.1	12.5	12.8	11.8	13.1	13.3	13.4	13.7	13.3	14.2
		MCWBR	7.4	6.3	5.9	5.8	5.0	4.5	4.2	4.4	4.3	4.4	5.9	8.3
Clear-Sky Solar Irradiance	taub		0.624	0.675	0.838	0.803	0.607	0.566	0.546	0.626	0.679	0.750	0.610	0.609
	taud		1.668	1.607	1.371	1.464	1.876	1.999	2.041	1.814	1.677	1.505	1.745	1.719
	Ebn at Noon		203	204	179	190	231	238	243	225	209	184	205	200
	Edh at Noon		72	81	107	99	65	57	55	69	77	89	66	66
All-Sky Solar Radiation	RadAvg		830	869	915	1096	1344	1396	1547	1528	1435	1321	1093	934
	RadStd		166	137	127	153	119	194	164	105	92	94	145	160

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page