

SHANWEI, China

WMO: 595010

Lat: 22.7917N

Lon: 115.3606E

Elev: 18

StdP: 101.11

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.0	9.3	-5.6	2.4	12.5	-1.4	3.4	13.0	7.6	12.4	6.4	14.0	3.0	20	0.314

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.0	32.5	26.2	31.8	26.2	31.2	26.3	28.1	30.2	27.7	29.9	27.5	29.7	3.3	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.6	23.6	29.5	27.2	23.0	29.2	26.8	22.5	29.1	90.8	30.4	89.1	30.0	87.5	29.8	29.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.9	6.0	5.3	DB	6.2	34.6	1.8	1.0	4.9	35.3	3.9	35.9	2.8	36.5	1.5	37.2	(4)
			WB	2.0	28.5	2.2	0.6	0.4	29.0	-0.8	29.3	-2.1	29.7	-3.6	30.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.1	15.7	16.4	18.8	22.5	25.6	27.8	28.6	28.5	27.8	25.4	21.8	17.5
	DBStd	5.27	2.99	3.49	3.01	2.72	2.07	1.67	1.27	1.35	1.49	1.83	2.63	2.93
	HDD10.0	4	2	2	0	0	0	0	0	0	0	0	0	1
	HDD18.3	248	89	69	32	4	0	0	0	0	0	0	5	49
	CDD10.0	4777	179	182	273	374	483	533	576	573	535	479	354	234
	CDD18.3	1978	8	17	46	128	225	283	318	315	285	221	109	24
	CDH23.3	18413	8	19	80	563	1835	3157	3850	3744	3104	1631	390	31
CDH26.7	5779	0	0	3	47	384	1054	1485	1404	1031	332	38	1	
Wind	WSAvg	2.6	2.4	2.4	2.4	2.4	2.6	2.9	2.8	2.6	2.5	2.6	2.5	2.5
Precipitation	PrecAvg	1806	25	46	76	169	290	342	303	282	186	63	34	29
	PrecMax	2954	92	266	420	572	752	1026	607	598	555	404	152	124
	PrecMin	895	0	0	1	2	15	43	45	36	13	1	0	0
	PrecStd	468	24	60	91	128	173	187	163	137	152	99	41	39
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.6	25.2	26.6	29.1	31.0	32.2	33.5	33.6	33.1	31.6	29.2	26.0
		MCWB	19.6	20.4	22.7	24.5	26.1	26.7	27.0	26.5	25.2	24.3	22.4	20.7
	2%	DB	22.5	23.8	25.2	28.0	30.1	31.4	32.2	32.5	32.1	30.3	27.8	24.1
		MCWB	17.9	19.9	21.5	24.1	25.8	26.7	26.6	26.5	25.3	23.9	22.1	19.1
	5%	DB	21.0	22.5	24.1	27.1	29.4	30.9	31.5	31.7	31.3	29.4	26.6	22.7
		MCWB	16.8	19.0	20.7	23.8	25.7	26.7	26.7	26.5	25.3	23.4	21.3	18.3
	10%	DB	19.8	21.1	23.0	26.2	28.7	30.3	31.0	31.1	30.6	28.5	25.5	21.6
		MCWB	16.1	17.8	19.6	23.3	25.5	26.7	26.7	26.5	25.2	22.9	20.8	17.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.3	22.1	23.8	26.1	27.9	28.5	28.7	28.7	27.7	26.1	24.2	22.5
		MCDB	23.1	23.4	25.8	27.8	29.3	30.2	31.0	30.7	30.3	29.2	26.8	24.8
	2%	WB	19.1	20.9	22.7	25.2	27.3	28.0	28.1	28.0	27.1	25.4	23.4	20.9
		MCDB	21.6	23.1	24.4	26.8	28.9	29.8	30.3	30.4	29.7	28.6	26.2	22.9
	5%	WB	17.8	19.7	21.6	24.6	26.8	27.6	27.7	27.6	26.7	24.9	22.7	19.4
		MCDB	20.3	21.7	23.4	26.2	28.5	29.6	30.0	30.0	29.3	28.1	25.6	21.9
	10%	WB	16.8	18.5	20.6	23.9	26.2	27.3	27.3	27.2	26.4	24.3	21.8	18.2
		MCDB	19.2	20.7	22.3	25.7	28.1	29.3	29.7	29.6	29.0	27.4	24.7	20.8
Mean Daily Temperature Range	5% DB	MDBR	5.9	5.4	5.1	4.6	4.3	3.6	4.0	4.3	5.0	5.6	6.1	6.2
		MCDBR	6.9	6.9	6.3	5.2	4.9	4.2	4.9	5.4	5.8	6.2	6.6	6.8
		MCWBR	3.8	3.9	3.7	2.7	2.2	1.6	1.8	2.0	2.2	2.5	3.1	3.6
	5% WB	MCDBR	5.9	5.8	5.2	4.3	3.8	3.4	4.1	4.4	4.7	5.3	5.5	5.8
		MCWBR	3.8	4.1	3.6	2.6	2.2	1.7	1.9	2.2	2.0	2.3	3.0	3.8
Clear-Sky Solar Irradiance	taub	0.555	0.617	0.740	0.723	0.567	0.540	0.526	0.585	0.622	0.645	0.552	0.544	
	taud	1.835	1.746	1.545	1.621	2.004	2.089	2.126	1.940	1.828	1.724	1.914	1.888	
	Ebn at Noon	698	686	626	650	756	771	782	739	701	654	697	689	
	Edh at Noon	190	221	282	265	180	164	158	190	209	223	175	175	
All-Sky Solar Radiation	RadAvg	3.08	3.23	3.46	3.88	4.48	4.64	5.48	5.14	4.85	4.46	3.56	3.17	
	RadStd	0.47	0.48	0.46	0.60	0.64	0.71	0.53	0.48	0.34	0.47	0.40	0.45	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Regional (13 neighbors)	N/A	N/A	N/A	+0.33	N/A	N/A	N/A	N/A	N/A	+48

Nomenclature: See separate page