

BEIHAI, China

WMO: 596440

Lat: 21.4566N

Lon: 109.1363E

Elev: 16

StdP: 101.13

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.4	7.7	-1.2	3.4	13.0	0.9	4.0	11.5	10.1	9.6	9.3	9.9	5.3	0	0.371

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.2	33.1	26.9	32.5	26.9	32.0	26.9	28.6	30.8	28.2	30.8	27.8	30.6	3.3	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.0	24.2	29.9	27.5	23.4	29.8	27.1	22.8	29.8	93.0	30.7	91.0	30.9	89.4	30.7	30.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.9	7.7	6.8	DB	5.3	34.7	1.6	0.9	4.1	35.3	3.2	35.8	2.3	36.3	1.1	37.0	(4)
			WB	3.3	28.9	1.4	0.6	2.3	29.3	1.5	29.6	0.7	30.0	-0.3	30.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	23.5	15.0	16.7	19.7	24.2	27.3	29.0	29.1	28.8	27.8	25.6	21.6	17.0	(6)
(7)		DBStd	5.90	4.35	4.86	4.15	3.32	2.15	1.51	1.46	1.43	1.76	2.29	3.31	3.59	(7)
(8)		HDD10.0	14	8	4	0	0	0	0	0	0	0	0	0	2	(8)
(9)		HDD18.3	321	119	82	36	4	0	0	0	0	0	0	11	68	(9)
(10)		CDD10.0	4956	164	193	302	427	537	569	593	582	535	484	349	219	(10)
(11)		CDD18.3	2221	17	37	79	181	279	319	335	323	285	226	110	28	(11)
(12)		CDH23.3	22461	17	83	292	1312	2966	4009	4239	3930	3100	1878	570	64	(12)
(13)	CDH26.7	8231	0	4	28	286	1041	1730	1849	1588	1107	517	78	1	(13)	
(14)	Wind	WSAvg	3.3	3.8	3.6	3.5	3.2	3.0	3.1	3.3	2.8	3.0	3.1	3.3	3.5	(14)
(15)	Precipitation	PrecAvg	1717	37	41	59	99	143	261	364	372	191	84	34	18	(15)
(16)		PrecMax	2213	214	208	189	197	720	584	922	802	357	207	218	97	(16)
(17)		PrecMin	850	0	1	8	9	23	65	62	116	24	10	0	0	(17)
(18)		PrecStd	296	47	41	47	59	127	145	214	168	84	53	45	22	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.1	27.4	28.8	31.4	33.0	33.6	33.7	34.1	33.3	32.2	29.7	26.5	(19)
(20)		0.4%	MCWB	20.5	22.7	23.5	25.5	26.5	27.3	27.2	26.6	26.1	24.8	23.6	22.0	(20)
(21)		2%	DB	23.6	25.5	27.5	30.3	32.1	32.6	32.9	32.9	32.4	31.1	28.6	25.0	(21)
(22)		2%	MCWB	19.8	21.6	23.1	25.2	26.5	27.3	27.3	27.0	26.1	24.5	23.0	20.8	(22)
(23)		5%	DB	22.4	24.2	26.2	29.4	31.4	32.0	32.3	32.2	31.7	30.2	27.6	23.8	(23)
(24)		5%	MCWB	18.9	20.8	22.6	24.9	26.3	27.1	27.2	27.1	26.0	24.1	22.3	20.0	(24)
(25)		10%	DB	21.2	23.0	25.0	28.4	30.7	31.5	31.7	31.5	31.0	29.4	26.5	22.5	(25)
(26)		10%	MCWB	18.3	20.2	21.9	24.5	26.0	27.1	27.2	27.1	25.9	23.8	21.8	18.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.6	23.1	24.4	26.6	28.1	29.0	29.0	29.2	28.6	27.2	25.6	23.6	(27)
(28)		0.4%	MCDWB	23.6	26.2	27.0	29.8	30.9	30.7	30.9	31.1	30.2	29.4	27.4	25.4	(28)
(29)		2%	WB	20.6	22.2	23.7	26.0	27.5	28.4	28.4	28.5	27.8	26.2	24.8	22.4	(29)
(30)		2%	MCDWB	22.6	24.6	26.2	28.9	30.4	30.7	30.9	30.9	30.2	28.8	26.7	24.2	(30)
(31)		5%	WB	19.8	21.5	23.1	25.5	27.1	28.0	28.0	28.0	27.3	25.6	24.1	21.1	(31)
(32)		5%	MCDWB	21.8	23.6	25.5	28.3	30.0	30.7	30.9	30.6	29.9	28.4	26.4	22.9	(32)
(33)		10%	WB	19.0	20.7	22.5	25.0	26.7	27.7	27.6	27.6	26.8	25.1	23.3	19.7	(33)
(34)		10%	MCDWB	20.7	22.6	24.7	27.6	29.6	30.4	30.6	30.3	29.6	27.9	25.6	21.7	(34)
(35)	Mean Daily Temperature Range		MDBR	5.9	5.5	5.4	5.1	5.1	4.2	4.2	4.8	5.5	6.3	6.7	6.5	(35)
(36)		5% DB	MCDBR	7.1	6.4	6.3	5.9	5.4	4.5	4.8	5.7	6.2	6.9	7.3	7.5	(36)
(37)		5% DB	MCWBR	3.8	3.1	3.0	2.4	2.1	1.8	1.8	2.1	2.2	2.4	3.0	3.7	(37)
(38)		5% WB	MCDBR	6.2	6.0	6.0	5.5	4.9	4.1	4.2	4.8	5.3	5.9	6.0	6.0	(38)
(39)		5% WB	MCWBR	3.9	3.3	3.3	2.6	2.2	2.0	1.9	2.3	2.3	2.4	3.1	3.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.610	0.649	0.804	0.758	0.554	0.525	0.508	0.572	0.620	0.715	0.599	0.616	(40)	
(41)		taud	1.732	1.685	1.448	1.566	2.061	2.164	2.203	2.000	1.846	1.613	1.812	1.745	(41)	
(42)		Ebn at Noon	658	666	589	629	767	783	797	750	706	609	664	634	(42)	
(43)		Edh at Noon	214	237	312	281	170	152	146	180	207	252	196	205	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.53	2.82	3.15	4.02	4.87	4.76	4.96	4.86	4.71	4.35	3.55	2.85	(44)	
(45)		RadStd	0.55	0.49	0.45	0.46	0.42	0.63	0.58	0.28	0.28	0.26	0.46	0.45	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	+0.43	N/A	N/A	N/A	N/A	N/A	+74	
(47)	Regional (5 neighbors)	N/A	N/A	N/A	+0.31	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page