

ZHANJIANG, China

WMO: 596580

Lat: 21.1548N

Lon: 110.3034E

Elev: 164

StdP: 14.61

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 45.8	(c) 48.3	(d) 32.0	(e) 26.6	(f) 56.8	(g) 36.6	(h) 32.0	(i) 54.5	(j) 19.0	(k) 58.3	(l) 17.8	(m) 58.5	(n) 9.6	(o) 0	(p) 0.360

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 8.8	(c) 93.2	(d) 80.2	(e) 91.7	(f) 80.2	(g) 90.4	(h) 80.1	(i) 82.8	(j) 87.7	(k) 82.3	(l) 87.3	(m) 81.7	(n) 86.7	(o) 7.2	(p) 220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.8	166.5	85.0	81.0	162.2	84.7	80.5	159.2	84.5	47.1	87.8	46.5	87.6	45.8	87.0	85.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 18.2	(b) 15.7	(c) 13.8	(e) 43.5	(f) 95.9	(g) 2.8	(h) 1.4	(i) 41.5	(j) 96.9	(k) 39.9	(l) 97.8	(m) 38.3	(n) 98.6	(o) 36.2	(p) 99.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	75.0	61.2	63.4	68.7	75.7	81.4	84.3	84.5	83.8	81.9	78.4	72.1	64.6
	DBStd	9.62	6.36	7.51	6.08	5.62	3.96	2.79	2.65	2.56	2.76	3.49	5.18	5.83
	HDD50	10	5	4	0	0	0	0	0	0	0	0	0	1
	HDD65	383	148	108	34	5	0	0	0	0	0	0	10	78
	CDD50	9153	352	381	580	771	973	1028	1068	1047	957	880	663	453
	CDD65	4051	30	64	149	326	508	578	603	582	507	415	223	66
	CDH74	38743	11	96	383	2101	5217	7000	7398	6819	5349	3301	974	94
	CDH80	13330	0	13	53	445	1703	2903	3087	2611	1696	719	98	2
Wind	WSAvg	7.2	7.7	7.7	7.9	7.7	6.7	6.4	7.0	6.3	6.7	7.2	7.6	7.5
Precipitation	PrecAvg	65.6	1.4	1.3	2.0	4.3	8.6	10.0	9.4	11.9	9.1	4.4	1.8	1.5
	PrecMax	90.9	11.2	6.9	5.0	12.6	20.3	30.4	29.4	22.6	22.8	15.1	6.7	7.6
	PrecMin	42.6	0.0	0.0	0.1	0.4	3.1	2.2	1.8	3.9	3.7	0.1	0.0	0.0
	PrecStd	14.4	2.0	1.5	1.3	3.0	4.4	5.6	6.0	4.4	4.1	4.4	1.8	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.5	81.4	85.2	91.3	94.5	94.6	95.1	93.9	92.0	88.8	85.0	79.5
		MCWB	68.0	72.4	75.0	79.0	79.7	80.4	80.2	80.1	79.5	76.3	74.1	71.8
	2%	DB	72.9	76.6	80.8	87.3	91.3	92.5	92.8	92.0	90.2	87.0	82.9	76.5
		MCWB	66.4	71.2	74.6	78.7	80.0	80.4	80.5	80.3	79.1	75.8	73.6	69.9
	5%	DB	70.8	74.0	77.8	84.8	88.9	90.8	91.2	90.5	88.6	85.4	80.8	74.4
		MCWB	65.4	69.5	73.3	77.8	80.0	80.3	80.5	80.2	78.7	75.5	72.4	68.3
	10%	DB	69.0	72.0	75.5	82.4	87.0	89.3	89.5	88.9	87.0	83.9	79.0	72.3
		MCWB	64.6	68.7	72.2	77.0	79.6	80.4	80.3	80.1	78.2	74.8	71.8	66.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.1	74.2	76.8	81.1	82.9	83.8	83.5	83.3	82.8	80.8	77.6	75.1
		MCDB	73.2	78.1	81.8	85.8	87.4	88.7	88.3	88.0	86.3	83.6	81.0	77.6
	2%	WB	68.4	72.4	75.4	79.8	81.9	82.9	82.6	82.4	81.7	79.0	76.6	73.0
		MCDB	70.9	75.4	79.0	84.3	87.0	87.8	87.8	87.6	85.8	83.2	79.8	75.0
	5%	WB	67.2	71.0	74.2	78.7	81.1	82.2	81.9	81.7	80.8	78.0	75.5	70.4
		MCDB	69.5	73.3	77.1	83.0	86.0	87.1	87.2	86.7	85.3	82.4	78.8	72.8
	10%	WB	66.0	69.5	72.9	77.7	80.5	81.6	81.3	81.0	80.0	77.2	74.3	68.1
		MCDB	68.3	71.4	75.1	81.6	85.2	86.4	86.5	85.9	84.5	81.6	77.8	71.0
Mean Daily Temperature Range	5% DB	MDBR	9.5	8.3	8.1	8.0	8.8	9.0	8.8	9.1	9.4	9.9	10.4	10.6
		MCDBR	10.6	10.7	10.7	11.2	11.3	11.0	11.4	11.3	11.4	11.0	11.0	11.3
		MCWBR	5.4	5.0	5.1	4.2	4.0	3.4	3.5	3.5	3.8	3.8	4.4	5.4
	5% WB	MCDBR	8.7	9.4	10.2	10.0	10.0	9.4	9.9	9.7	9.8	8.7	8.5	8.6
		MCWBR	5.3	5.0	5.7	4.5	4.3	3.9	3.9	4.0	4.1	3.5	4.1	5.6
Clear-Sky Solar Irradiance	taub	0.589	0.627	0.773	0.738	0.547	0.512	0.499	0.566	0.614	0.700	0.586	0.594	
	taud	1.771	1.722	1.490	1.593	2.071	2.190	2.216	2.003	1.850	1.626	1.832	1.781	
	Ebn at Noon	215	217	193	204	245	251	255	239	226	197	214	208	
	Edh at Noon	65	73	95	87	53	47	46	57	65	79	61	63	
All-Sky Solar Radiation	RadAvg	883	977	1095	1326	1577	1587	1650	1577	1486	1363	1138	948	
	RadStd	173	160	130	160	128	196	169	108	102	85	128	136	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	+0.43	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page