

YANGJIANG, China

WMO: 596630

Lat: 21.8457N

Lon: 111.9779E

Elev: 299

StdP: 14.54

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 45.0	(c) 47.2	(d) 25.0	(e) 19.3	(f) 55.5	(g) 29.9	(h) 24.2	(i) 55.7	(j) 20.8	(k) 53.1	(l) 18.9	(m) 53.1	(n) 11.0	(o) 40	(p) 0.361

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 7.9	(c) 91.5	(d) 80.0	(e) 90.0	(f) 79.7	(g) 88.8	(h) 79.4	(i) 82.4	(j) 86.8	(k) 81.8	(l) 86.2	(m) 81.2	(n) 85.6	(o) 7.7	(p) 180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.3	164.5	84.7	80.7	161.2	84.4	80.1	157.8	84.0	46.7	87.2	46.0	86.2	45.4	85.6	85.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 19.4	(b) 16.6	(c) 14.6	(e) 42.7	(f) 95.6	(g) 2.9	(h) 1.5	(i) 40.6	(j) 96.7	(k) 38.8	(l) 97.5	(m) 37.2	(n) 98.4	(o) 35.1	(p) 99.5		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			37.2	83.6	3.0	1.1	35.0	84.4	33.3	85.0	31.6	85.6	29.5	86.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	73.9	60.5	62.4	67.0	73.9	79.4	82.5	83.2	83.2	81.6	77.8	70.9	63.3
	DBStd	9.68	6.75	7.82	6.30	5.37	3.63	2.78	2.64	2.66	3.01	3.60	5.24	5.91
	HDD50	14	6	7	0	0	0	0	0	0	0	0	0	1
	HDD65	477	170	128	55	8	0	0	0	0	0	0	14	102
	CDD50	8727	331	354	526	717	913	975	1030	1030	949	861	628	413
	CDD65	3717	31	55	117	275	448	525	565	565	499	396	192	49
	CDH74	33780	29	59	218	1516	4060	5908	6558	6453	5152	2949	781	97
CDH80	10366	0	1	5	170	995	2039	2420	2368	1639	643	84	2	
Wind	WSAvg	7.5	8.0	7.6	7.7	7.4	7.2	7.4	7.5	6.8	7.1	7.5	7.7	8.1
Precipitation	PrecAvg	89.6	1.5	2.4	3.4	8.7	15.8	15.0	11.1	15.0	9.6	3.4	2.0	1.1
	PrecMax	131.6	7.8	14.1	15.6	23.3	46.8	32.7	33.3	32.5	20.7	9.5	12.2	6.9
	PrecMin	47.2	0.0	0.1	0.1	0.7	2.2	2.5	3.1	3.0	0.8	0.0	0.0	0.0
	PrecStd	21.7	1.9	3.1	3.2	5.5	11.3	7.2	6.4	7.2	5.9	2.7	2.8	1.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	76.9	78.6	80.2	85.6	89.3	91.6	93.7	94.1	92.2	89.0	84.7	79.7
		MCWB	68.1	69.6	72.7	77.3	79.5	79.9	80.8	80.2	78.7	76.1	72.7	69.9
	2%	DB	74.3	75.8	77.9	83.6	87.3	89.3	90.9	91.5	90.1	87.0	82.4	76.8
		MCWB	66.5	69.0	72.3	76.7	79.1	80.1	80.5	80.3	78.4	75.3	72.0	68.1
	5%	DB	72.0	73.8	76.4	81.9	86.0	88.1	89.3	89.8	88.6	85.2	80.4	74.3
		MCWB	65.1	68.4	71.7	76.3	78.8	80.2	80.0	80.1	78.1	74.5	70.6	66.1
	10%	DB	69.7	72.0	74.9	80.4	84.6	86.9	87.9	88.2	87.0	83.6	78.4	71.8
		MCWB	63.7	67.5	71.1	76.1	78.5	80.1	79.7	79.8	77.6	73.5	69.6	63.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.6	72.8	75.5	79.8	82.3	83.2	83.2	83.1	81.9	79.4	76.7	73.9
		MCDB	74.2	75.3	77.6	82.2	85.2	86.9	89.4	88.8	87.0	84.4	80.2	76.8
	2%	WB	68.5	71.1	74.5	78.8	81.4	82.3	82.0	82.0	80.9	78.2	75.5	71.1
		MCDB	72.5	73.5	76.4	81.2	84.5	85.8	86.9	87.3	86.2	83.2	78.9	74.6
	5%	WB	66.7	70.0	73.4	77.9	80.5	81.7	81.5	81.4	80.1	77.2	74.3	68.4
		MCDB	70.9	72.5	75.2	80.4	83.9	85.3	86.3	86.5	85.3	82.3	78.0	72.4
	10%	WB	64.7	68.4	72.1	76.9	79.7	81.0	80.9	80.7	79.4	76.2	72.6	65.8
		MCDB	68.7	71.4	74.0	79.6	83.2	84.9	85.5	85.7	84.4	81.2	76.9	70.5
Mean Daily Temperature Range	5% DB	MDBR	11.1	9.6	8.7	7.5	7.8	7.3	7.9	8.9	9.4	10.3	11.4	11.5
		MCDBR	13.4	11.6	9.7	8.5	9.0	8.6	10.1	11.5	11.6	11.7	12.8	13.6
		MCWBR	6.9	5.8	5.2	3.7	3.6	3.1	3.5	3.9	4.1	4.5	5.7	7.0
	5% WB	MCDBR	11.6	8.3	7.3	6.8	7.3	7.5	8.8	9.9	9.7	9.8	9.9	11.1
MCWBR		6.7	5.4	5.4	4.0	3.8	3.6	3.8	4.3	4.0	4.1	5.4	7.0	
Clear-Sky Solar Irradiance	taub		0.579	0.619	0.757	0.728	0.555	0.521	0.506	0.579	0.624	0.694	0.579	0.575
	taud		1.779	1.733	1.507	1.603	2.033	2.152	2.183	1.954	1.816	1.620	1.835	1.809
	Ebn at Noon		216	219	196	206	243	249	253	236	222	197	215	211
	Edh at Noon		64	71	93	86	56	49	47	60	68	79	61	61
All-Sky Solar Radiation	RadAvg		923	951	1011	1163	1430	1485	1640	1540	1450	1351	1133	988
	RadStd		157	144	128	180	134	217	186	120	111	108	128	141

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page