

HAIKOU, China

WMO: 597580

Lat: 19.9938N

Lon: 110.2469E

Elev: 64

StdP: 100.56

Time Zone: 8.00 (E08)

Period: 94-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.7	12.3	5.9	5.8	13.8	7.6	6.5	14.2	8.3	17.6	7.5	17.8	2.7	20	0.326

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	6.5	35.1	26.8	34.2	26.7	33.4	26.6	27.9	32.4	27.6	31.9	27.2	31.3	2.9	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.9	22.7	30.0	26.5	22.2	29.6	26.2	21.8	29.3	90.1	32.7	88.4	32.1	87.0	31.6	30.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.0	6.9	6.0		9.4	36.9	1.5	1.1	8.3	37.7	7.4	38.4	6.6	39.0	5.5	39.8
				7.8	28.5	1.5	0.6	6.8	28.9	5.9	29.2	5.1	29.6	4.0	30.0
				DB											
				WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.0	18.4	19.6	22.6	26.2	28.3	29.4	29.3	28.8	27.8	26.2	23.5	19.8
	DBStd	4.65	3.29	4.10	3.75	3.09	2.09	1.46	1.38	1.26	1.31	1.51	2.41	2.81
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	102	41	32	9	1	0	0	0	0	0	0	2	17
	CDD10.0	5482	260	270	392	487	567	583	598	583	533	502	404	304
	CDD18.3	2542	43	68	143	238	308	333	340	324	283	243	156	63
	CDH23.3	24611	79	247	832	2101	3361	4041	4145	3803	3038	2095	749	121
CDH26.7	8841	10	52	232	733	1298	1770	1789	1494	939	414	98	11	
Wind	WSAvg	2.7	2.8	2.8	2.9	2.9	2.5	2.4	2.5	2.3	2.4	2.9	2.9	2.9
Precipitation	PrecAvg	1972	28	41	53	95	205	204	216	281	330	351	101	67
	PrecMax	2702	147	177	236	317	437	444	431	537	801	1429	215	195
	PrecMin	1204	0	4	6	14	101	84	101	68	102	19	4	5
	PrecStd	365	27	37	46	67	74	87	82	101	166	291	60	48
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.1	31.4	33.7	35.5	36.1	35.9	35.8	34.6	33.3	31.3	30.6	28.2
		MCWB	22.4	23.2	24.9	26.0	26.8	27.4	26.9	26.9	25.9	25.4	24.8	23.8
	2%	DB	25.3	28.0	31.1	33.8	34.6	34.8	34.7	33.5	32.2	30.3	28.9	25.9
		MCWB	21.3	22.5	24.2	25.8	26.9	27.2	26.8	26.7	26.0	24.9	24.4	22.4
	5%	DB	23.7	26.2	29.2	32.3	33.4	33.9	33.7	32.6	31.4	29.6	27.8	24.6
		MCWB	20.7	21.9	23.8	25.6	26.7	27.0	26.8	26.5	26.0	24.7	23.7	21.7
	10%	DB	22.4	24.5	27.4	30.7	32.1	32.9	32.8	31.8	30.6	28.8	26.7	23.4
		MCWB	20.2	21.4	23.1	25.2	26.5	26.7	26.6	26.5	25.8	24.4	23.3	21.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.9	23.8	25.7	27.5	28.2	28.6	28.3	27.9	27.4	26.6	25.6	24.4
		MCDB	26.1	28.7	31.6	32.9	33.1	33.6	33.0	31.8	30.6	29.4	28.6	26.8
	2%	WB	21.8	22.9	24.7	26.6	27.6	28.0	27.7	27.5	27.0	26.1	25.0	23.3
		MCDB	24.1	26.8	29.7	31.5	32.2	32.6	32.1	31.3	30.2	28.7	27.5	25.1
	5%	WB	21.2	22.3	24.0	26.0	27.2	27.6	27.4	27.2	26.7	25.7	24.5	22.4
		MCDB	23.1	25.2	28.3	30.5	31.4	31.9	31.6	30.9	29.7	28.1	26.9	24.1
	10%	WB	20.5	21.7	23.5	25.5	26.7	27.2	27.0	26.9	26.3	25.3	24.0	21.5
		MCDB	22.2	24.2	26.8	29.5	30.7	31.2	31.1	30.6	29.2	27.6	26.3	23.1
Mean Daily Temperature Range	5% DB	MDBR	4.4	4.8	5.6	6.0	6.2	6.5	6.3	5.6	4.8	4.3	4.1	3.9
		MCDBR	6.4	7.3	8.4	8.9	8.4	8.0	7.9	6.9	6.3	5.4	5.6	5.6
		MCWBR	2.8	2.5	2.9	2.7	2.6	2.5	2.5	2.3	2.1	1.8	1.9	2.7
	5% WB	MCDBR	5.8	6.8	7.7	7.8	7.3	7.3	6.7	6.0	5.2	4.6	4.9	5.0
		MCWBR	2.9	2.8	3.1	2.9	2.7	2.7	2.6	2.3	2.1	1.8	1.9	2.9
Clear-Sky Solar Irradiance	taub	0.568	0.587	0.705	0.670	0.512	0.483	0.465	0.515	0.568	0.640	0.573	0.587	
	taud	1.832	1.830	1.622	1.743	2.195	2.298	2.337	2.172	1.987	1.762	1.883	1.811	
	Ebn at Noon	703	723	657	689	800	816	831	796	749	671	695	669	
	Edh at Noon	196	207	263	236	149	133	128	152	180	218	185	195	
All-Sky Solar Radiation	RadAvg	2.76	3.36	3.91	4.69	5.38	5.39	5.42	5.04	4.55	4.01	3.32	2.72	
	RadStd	0.55	0.61	0.43	0.53	0.46	0.51	0.49	0.38	0.41	0.34	0.38	0.41	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	-0.83	-1.20	N/A	-0.37	-0.40	N/A	N/A	N/A	N/A	
(47)	Regional (6 neighbors)	N/A	N/A	-0.91	+0.26	N/A	N/A	N/A	N/A	N/A	+64	

Nomenclature: See separate page