

DONGSHA DAO, Taiwan

WMO: 597920

Lat: 20.701N

Lon: 116.730E

Elev: 20

StdP: 14.69

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 63.1	(c) 64.5	(d) 53.1	(e) 60.0	(f) 65.1	(g) 55.9	(h) 66.6	(i) 66.1	(j) 43.1	(k) 70.5	(l) 33.3	(m) 70.7	(n) 20.0	(o) 50	(p) 0.508

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 8.1	(c) 92.6	(d) 84.0	(e) 91.5	(f) 83.7	(g) 90.6	(h) 83.3	(i) 86.1	(j) 89.6	(k) 84.8	(l) 89.4	(m) 84.1	(n) 89.1	(o) 6.8	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
85.4	186.5	88.2	83.7	176.2	87.9	82.7	170.7	87.5	50.8	89.5	49.2	89.7	48.3	89.3	92.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 29.8	(b) 26.4	(c) 23.6	(e) 60.6	(f) 95.1	(g) 2.5	(h) 2.3	(i) 58.8	(j) 96.8	(k) 57.3	(l) 98.2	(m) 56.0	(n) 99.4	(o) 54.2	(p) 101.1		
(a) 29.8	(b) 26.4	(c) 23.6	(e) 55.1	(f) 86.4	(g) 3.9	(h) 2.0	(i) 52.3	(j) 87.9	(k) 50.0	(l) 89.0	(m) 47.9	(n) 90.2	(o) 45.1	(p) 91.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	79.4	71.1	72.4	75.4	79.6	82.9	84.9	85.4	85.2	83.8	80.9	77.5	72.6
	DBStd	5.92	3.42	3.77	3.68	3.21	2.79	2.53	2.31	2.23	2.36	2.48	2.79	3.18
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	4	2	2	0	0	0	0	0	0	0	0	0	0
	CDD50	10714	655	627	787	889	1021	1046	1099	1091	1014	959	825	701
	CDD65	5244	192	209	323	439	556	596	634	626	564	494	375	236
	CDH74	50447	286	538	1566	3713	6274	7525	8263	7974	6743	4784	2325	456
	CDH80	17961	14	36	221	945	2218	3313	3845	3566	2558	997	226	22
(14) Wind	WSAvg	12.1	16.4	13.9	11.7	9.5	8.3	8.3	8.8	8.9	10.0	14.4	16.8	18.1
(15) Precipitation	PrecAvg	41.9	1.1	0.7	0.7	1.1	4.7	6.4	4.3	7.2	7.5	4.7	1.8	1.9
	PrecMax	96.5	8.7	2.6	4.2	7.8	13.7	16.4	10.9	24.3	38.5	23.7	7.3	12.8
	PrecMin	9.1	0.0	0.0	0.0	0.0	0.3	0.0	0.3	0.0	0.6	0.0	0.0	0.0
	PrecStd	20.6	1.9	0.7	0.9	1.7	3.5	4.6	2.6	6.0	7.5	6.3	1.9	2.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	81.7	83.2	86.2	90.2	92.4	93.3	94.0	94.5	92.5	89.6	86.5	82.7
		MCWB	75.0	77.3	79.3	81.7	83.6	85.2	84.3	82.9	83.2	81.8	80.7	75.8
	2%	DB	79.1	81.0	84.2	88.4	90.8	91.7	92.5	91.9	90.7	87.4	84.3	79.7
		MCWB	73.4	75.8	78.4	81.2	82.9	84.5	84.1	83.5	82.9	80.4	79.2	74.3
	5%	DB	76.9	79.1	82.5	86.9	89.5	90.7	91.3	90.8	89.3	85.9	82.5	77.8
		MCWB	71.9	74.4	77.0	80.2	82.4	84.0	83.6	83.5	82.3	79.8	77.8	73.2
	10%	DB	75.2	77.3	80.7	85.2	88.2	89.6	90.1	89.6	87.9	84.3	80.9	76.4
		MCWB	71.0	73.1	75.9	79.1	81.9	83.4	83.1	83.3	81.5	78.9	76.8	72.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.4	78.4	81.9	85.9	88.2	89.1	88.3	86.9	83.2	82.6	77.2	
		MCDB	79.6	81.9	84.0	87.5	88.9	89.8	91.0	89.9	88.9	87.3	85.1	80.6
	2%	WB	74.4	76.5	79.0	82.7	84.3	85.5	85.2	83.7	81.8	80.1	75.5	
		MCDB	77.5	79.8	82.9	86.6	89.0	90.2	89.9	89.2	88.8	85.8	82.8	78.5
	5%	WB	72.9	75.2	77.6	80.9	83.3	84.5	84.2	84.1	82.8	80.8	78.9	74.2
		MCDB	76.0	78.1	81.4	85.6	87.9	89.5	89.7	89.3	87.8	84.6	81.4	77.1
	10%	WB	71.7	73.8	76.4	79.6	82.4	83.7	83.4	83.3	82.0	79.8	77.7	72.9
		MCDB	74.6	76.5	79.8	84.1	86.8	88.5	88.8	88.3	86.8	83.5	80.3	75.8
(35) Mean Daily Temperature Range	5% DB	MDBR	5.7	6.6	7.7	8.6	8.4	8.0	8.1	8.1	7.5	5.8	4.8	4.9
		MCDBR	8.9	9.6	10.4	11.1	10.3	9.2	9.9	9.9	9.6	8.0	7.2	7.6
	5% WB	MCWBR	6.4	6.2	6.1	6.2	5.1	4.7	5.0	4.9	5.0	4.9	4.8	5.5
		MCWBR	8.9	9.3	9.9	10.6	9.5	8.6	9.0	9.0	8.6	7.3	6.6	7.0
(40) Clear-Sky Solar Irradiance	taub		0.539	0.548	0.643	0.602	0.483	0.472	0.471	0.506	0.533	0.578	0.570	0.587
		taud	1.944	1.943	1.764	1.900	2.302	2.351	2.349	2.223	2.108	1.927	1.927	1.844
	Ebn at Noon		231	239	222	234	261	262	262	255	246	228	220	211
		Edh at Noon	55	58	72	64	42	40	40	46	50	58	56	59
(44) All-Sky Solar Radiation	RadAvg		904	1172	1429	1741	1833	1844	1886	1700	1587	1386	1019	810
	RadStd		163	226	137	178	146	181	140	174	187	140	136	147

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page