

DANXIAN, China

WMO: 598450

Lat: 19.5108N

Lon: 109.5773E

Elev: 554

StdP: 14.40

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 49.6	(c) 51.8	(d) 43.0	(e) 41.6	(f) 56.7	(g) 46.0	(h) 46.8	(i) 55.6	(j) 12.0	(k) 72.5	(l) 10.9	(m) 71.4	(n) 3.5	(o) 40	(p) 0.283

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 6	(b) 13.1	(c) 96.1	(d) 78.5	(e) 94.4	(f) 78.4	(g) 92.8	(h) 78.3	(i) 80.9	(j) 90.2	(k) 80.3	(l) 89.4	(m) 79.8	(n) 88.5	(o) 6.0	(p) 270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.9	153.2	83.7	78.2	149.6	83.3	77.7	146.9	82.9	45.1	90.3	44.5	89.8	44.0	89.1	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.8	10.0	9.0	47.0	99.5	2.6	1.9	45.1	100.8	43.5	101.9	42.1	103.0	40.2	104.3
			45.0	82.1	2.6	1.0	43.1	82.8	41.5	83.4	40.1	83.9	38.1	84.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	76.8	65.3	68.4	74.3	80.0	83.0	84.6	84.0	82.9	80.9	77.9	73.1	67.0		
	DBStd	8.43	6.92	8.36	7.08	5.84	4.04	2.96	2.78	2.49	2.78	3.22	5.04	5.84		
	HDD50	2	1	1	0	0	0	0	0	0	0	0	0	0		
	HDD65	219	87	60	16	2	0	0	0	0	0	0	6	48		
	CDD50	9793	475	516	753	901	1023	1038	1054	1020	928	866	692	527		
	CDD65	4535	96	156	304	452	558	588	589	555	478	401	248	110		
	CDH74	40688	343	898	2154	4134	5687	6749	6511	5661	4239	2760	1186	366		
	CDH80	15232	42	264	783	1746	2403	2953	2692	2080	1292	684	242	51		
(14) Wind	WSAvg	4.4	4.4	4.4	4.4	4.3	4.1	4.3	4.5	4.2	4.3	4.6	4.7	4.4		
(15) Precipitation	PrecAvg	71.0	0.7	0.9	1.3	3.3	9.2	8.1	10.0	11.7	12.5	9.1	3.2	1.1		
	PrecMax	99.8	3.1	2.7	5.9	12.5	17.6	15.4	20.0	21.0	31.1	28.2	12.7	3.9		
	PrecMin	43.4	0.0	0.1	0.0	0.3	2.6	3.4	2.6	2.4	3.1	0.4	0.0	0.0		
	PrecStd	14.0	0.7	0.7	1.3	2.5	3.8	3.0	4.6	5.0	6.1	6.7	3.0	1.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	85.3	92.4	95.3	98.8	98.7	97.0	97.0	94.7	92.6	89.2	88.3	84.3		
		MCWB	70.1	72.3	74.3	77.2	78.4	79.6	78.9	79.6	79.1	76.3	74.9	73.0		
	2%	DB	80.8	87.0	91.2	95.0	95.5	95.0	94.4	92.5	90.4	87.4	85.5	81.2		
		MCWB	68.9	72.0	74.9	77.0	78.8	79.3	78.8	79.2	78.5	75.8	74.5	71.2		
	5%	DB	78.1	82.8	87.6	92.1	93.2	93.4	92.6	90.8	88.8	85.8	83.0	78.2		
		MCWB	68.0	70.7	73.8	76.8	78.6	79.1	78.7	78.9	78.1	75.1	73.3	69.7		
	10%	DB	75.4	79.6	84.2	89.2	90.7	91.5	90.8	89.2	86.9	84.1	80.4	75.2		
		MCWB	67.0	69.3	72.8	76.3	78.1	78.8	78.6	78.7	77.5	74.3	72.2	68.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.4	74.6	77.3	80.3	81.5	81.6	81.2	81.5	80.8	79.0	77.2	74.6		
		MCDB	79.3	87.1	89.8	91.7	91.7	91.7	90.6	89.5	88.1	85.4	83.3	80.7		
	2%	WB	70.8	72.9	75.8	79.0	80.4	80.8	80.4	80.5	79.9	77.9	76.0	73.0		
		MCDB	77.4	83.7	87.3	90.2	90.8	90.7	89.5	88.5	86.9	83.6	81.5	78.2		
	5%	WB	69.6	71.5	74.6	77.9	79.6	80.1	79.8	79.9	79.1	77.0	74.9	71.6		
		MCDB	75.6	80.5	84.8	88.5	89.4	89.5	88.5	87.5	85.7	82.1	80.0	75.9		
	10%	WB	68.3	70.2	73.4	76.9	78.8	79.4	79.1	79.2	78.4	76.2	73.9	70.1		
		MCDB	73.6	77.7	82.4	86.7	88.1	88.3	87.5	86.5	84.3	80.8	78.5	73.8		
(35) Mean Daily Temperature Range	MDBR		11.8	13.1	14.8	14.5	13.9	13.1	12.8	12.2	11.1	10.8	10.6	10.4		
	5% DB	MCDBR	16.4	19.0	20.0	18.4	16.8	15.3	15.5	14.7	14.2	13.3	14.0	14.4		
		MCWBR	5.9	6.8	7.1	6.4	5.3	4.8	4.8	4.6	4.5	4.1	4.5	5.4		
	5% WB	MCDBR	14.3	17.5	18.4	16.5	15.0	13.7	14.0	13.1	12.4	10.9	11.7	12.4		
		MCWBR	6.0	6.9	7.2	6.3	5.4	5.0	5.0	4.8	4.6	4.2	4.4	5.8		
(40) Clear-Sky Solar Irradiance	taub		0.549	0.565	0.683	0.647	0.499	0.470	0.452	0.497	0.552	0.610	0.551	0.569		
	taud		1.853	1.860	1.637	1.765	2.202	2.301	2.339	2.194	2.000	1.802	1.913	1.825		
	Ebn at Noon		229	235	213	224	257	262	267	257	242	221	227	218		
	Edh at Noon		61	64	82	73	47	42	41	47	56	67	57	61		
(44) All-Sky Solar Radiation	RadAvg		927	1128	1283	1506	1670	1665	1655	1542	1402	1249	1037	858		
	RadStd		174	206	132	156	154	134	149	129	146	152	125	133		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.54	N/A	N/A	+0.79	N/A	+0.36	N/A	N/A	N/A	+248
Regional (8 neighbors)	N/A	N/A	-1.80	+0.40	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page