

QIONGHAI, China

WMO: 598550

Lat: 19.2089N

Lon: 110.4819E

Elev: 80

StdP: 14.65

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 52.8	(c) 55.2	(d) 44.8	(e) 43.9	(f) 57.9	(g) 48.0	(h) 49.7	(i) 58.1	(j) 13.4	(k) 74.0	(l) 12.0	(m) 72.3	(n) 5.6	(o) 320	(p) 0.292

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 6	(b) 11.7	(c) 94.9	(d) 81.1	(e) 93.5	(f) 80.9	(g) 92.3	(h) 80.6	(i) 83.0	(j) 91.1	(k) 82.3	(l) 90.3	(m) 81.6	(n) 89.2	(o) 6.7	(p) 180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.9	161.2	87.1	80.2	157.3	86.1	79.7	154.8	85.6	47.2	91.9	46.3	90.6	45.6	89.5	86.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 13.9	(b) 12.0	(c) 10.6	(e) 49.3	(f) 98.6	(g) 3.6	(h) 1.6	(i) 46.7	(j) 99.7	(k) 44.6	(l) 100.6	(m) 42.5	(n) 101.5	(o) 39.9	(p) 102.6		
(a) 13.9	(b) 12.0	(c) 10.6	(e) 46.9	(f) 84.1	(g) 2.7	(h) 1.4	(i) 45.0	(j) 85.1	(k) 43.5	(l) 85.9	(m) 42.0	(n) 86.7	(o) 40.0	(p) 87.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	78.0	67.1	69.6	74.6	80.1	83.6	85.3	85.0	84.3	82.5	79.4	74.8	69.2
	DBStd	7.66	5.65	6.84	5.71	4.50	3.25	2.55	2.61	2.40	2.73	2.69	4.23	4.95
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	111	47	35	7	0	0	0	0	0	0	0	2	20
	CDD50	10219	529	550	764	902	1041	1059	1085	1065	974	911	745	594
	CDD65	4855	111	165	306	452	576	609	620	600	524	446	297	149
	CDH74	45827	222	630	1820	4096	6331	7399	7420	6806	5419	3707	1584	393
	CDH80	16508	8	104	403	1294	2521	3309	3201	2719	1821	878	226	24
	WSAvg	5.0	4.7	5.0	5.4	5.7	5.1	5.0	4.9	4.4	4.6	5.2	5.1	4.9
	PrecAvg	78.7	1.5	1.6	2.3	4.8	7.3	8.8	6.8	10.6	13.9	12.2	6.5	2.4
(15) Precipitation	PrecMax	124.5	3.8	4.9	8.0	18.4	17.8	22.0	17.3	21.0	31.1	26.5	31.7	7.6
	PrecMin	42.3	0.2	0.1	0.2	0.1	0.4	3.2	1.0	3.7	2.4	0.4	0.4	0.1
	PrecStd	18.4	1.0	1.1	1.9	4.3	4.7	4.6	4.1	4.8	7.6	7.1	7.4	1.9
	PrecStd	18.4	1.0	1.1	1.9	4.3	4.7	4.6	4.1	4.8	7.6	7.1	7.4	1.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	81.3	87.4	89.6	93.0	96.0	96.8	96.9	95.7	94.0	89.7	87.0	82.7
		MCWB	72.6	75.9	76.8	79.4	81.4	81.9	80.8	80.9	80.0	77.4	76.3	74.9
	2%	DB	78.7	83.1	86.9	90.8	93.6	94.4	94.4	93.6	91.7	87.6	84.8	80.2
		MCWB	71.0	74.1	76.2	78.9	80.8	81.5	80.9	80.9	79.5	77.3	75.5	72.8
	5%	DB	76.6	80.0	84.4	89.0	91.9	92.9	92.7	91.9	89.9	86.1	82.8	78.0
		MCWB	70.1	72.4	75.6	78.4	80.6	81.2	80.8	80.5	79.2	76.4	74.7	71.5
	10%	DB	74.7	77.6	81.8	87.0	90.0	91.4	91.1	90.3	88.1	84.7	80.8	76.1
		MCWB	69.4	71.5	74.6	77.8	80.1	81.0	80.5	80.2	78.7	75.9	73.8	70.8
	0.4%	WB	74.4	76.5	78.3	81.4	83.7	84.4	83.6	83.1	82.1	80.1	78.2	76.2
		MCDB	79.3	84.8	86.1	89.4	92.0	92.6	91.9	91.2	89.5	85.8	83.0	80.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	72.6	74.7	77.1	80.1	82.4	83.1	82.5	82.1	81.0	79.2	77.2	74.8
		MCDB	76.3	80.8	84.3	87.7	90.6	91.1	90.7	90.2	87.7	84.4	81.7	78.1
	5%	WB	71.4	73.5	76.1	79.2	81.5	82.3	81.7	81.4	80.3	78.4	76.4	73.5
		MCDB	75.0	78.2	82.3	85.9	89.1	90.1	89.4	88.9	86.5	83.2	80.6	76.6
	10%	WB	70.3	72.5	75.3	78.4	80.7	81.6	81.0	80.8	79.7	77.7	75.6	72.0
		MCDB	73.9	76.6	80.4	84.5	87.7	88.7	88.1	87.7	85.4	82.0	79.6	75.2
(35) Mean Daily Temperature Range	5% DB	MDBR	9.7	9.8	10.4	10.7	11.8	11.7	11.7	11.9	10.7	9.8	9.2	9.2
		MCDBR	12.1	12.7	13.0	13.6	14.3	13.9	14.3	14.5	13.7	12.0	11.3	11.4
		MCWBR	5.2	5.1	4.7	4.5	4.8	4.7	4.7	4.7	4.2	3.8	3.8	4.8
	5% WB	MCDBR	10.1	11.4	12.0	12.4	13.4	12.8	12.8	13.1	12.0	9.5	8.9	9.1
		MCWBR	4.9	5.1	4.8	4.8	5.3	5.1	4.9	5.0	4.4	3.7	3.4	4.6
(40) Clear-Sky Solar Irradiance	taub		0.567	0.569	0.675	0.642	0.504	0.481	0.462	0.502	0.560	0.619	0.577	0.595
	taud		1.834	1.873	1.676	1.798	2.211	2.292	2.338	2.205	2.003	1.806	1.873	1.792
	Ebn at Noon		225	235	216	225	256	259	265	256	240	219	221	211
	Edh at Noon		62	63	79	71	46	43	41	47	56	67	60	63
(44) All-Sky Solar Radiation	RadAvg		901	1130	1323	1581	1775	1745	1733	1639	1450	1256	1021	848
	RadStd		169	196	133	159	147	154	150	115	139	134	121	142

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	-2.02	+0.68	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	-1.80	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page