

QIONGHAI, China

WMO: 598550

Lat: 19.2089N

Lon: 110.4819E

Elev: 24

StdP: 101.03

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.5	12.9	7.1	6.3	14.4	8.9	7.1	14.5	6.0	23.3	5.4	22.4	2.5	320	0.292

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	6.5	35.0	27.3	34.2	27.1	33.5	27.0	28.3	32.8	27.9	32.4	27.6	31.8	3.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.2	23.0	30.6	26.8	22.5	30.0	26.5	22.1	29.8	91.8	33.3	89.8	32.6	88.1	32.0	30.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.2	5.4	4.8	9.6	37.0	2.0	0.9	8.2	37.6	7.0	38.1	5.9	38.6	4.4	39.2		
			8.3	29.0	1.5	0.8	7.2	29.5	6.4	30.0	5.5	30.4	4.5	30.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.6	19.5	20.9	23.7	26.7	28.6	29.6	29.4	29.1	28.0	26.3	23.8	20.6
	DBStd	4.26	3.14	3.80	3.17	2.50	1.81	1.42	1.45	1.34	1.51	1.49	2.35	2.75
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	62	26	19	4	0	0	0	0	0	0	0	1	11
	CDD10.0	5677	294	306	424	501	578	588	603	592	541	506	414	330
	CDD18.3	2697	62	92	170	251	320	338	344	333	291	248	165	83
	CDH23.3	25459	123	350	1011	2276	3517	4111	4122	3781	3011	2059	880	218
CDH26.7	9171	4	58	224	719	1401	1838	1778	1511	1012	488	126	13	
Wind	WSAvg	2.2	2.1	2.2	2.4	2.5	2.3	2.2	2.2	2.0	2.0	2.3	2.3	2.2
Precipitation	PrecAvg	1999	37	40	58	123	185	224	172	270	352	310	166	62
	PrecMax	3162	96	124	202	467	452	560	440	533	789	672	806	192
	PrecMin	1074	6	2	5	2	10	81	26	95	61	11	9	2
	PrecStd	468	26	29	48	109	119	118	105	122	192	181	188	48
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.4	30.8	32.0	33.9	35.5	36.0	36.0	35.4	34.5	32.0	30.6	28.2
		MCWB	22.5	24.4	24.9	26.3	27.5	27.7	27.1	27.2	26.7	25.2	24.6	23.8
	2%	DB	25.9	28.4	30.5	32.7	34.2	34.7	34.7	34.2	33.2	30.9	29.3	26.8
		MCWB	21.7	23.4	24.6	26.0	27.1	27.5	27.2	27.1	26.4	25.2	24.2	22.7
	5%	DB	24.8	26.6	29.1	31.7	33.3	33.8	33.7	33.3	32.2	30.1	28.2	25.6
		MCWB	21.2	22.5	24.2	25.8	27.0	27.3	27.1	27.0	26.2	24.7	23.7	21.9
	10%	DB	23.7	25.3	27.7	30.6	32.2	33.0	32.8	32.4	31.2	29.3	27.1	24.5
		MCWB	20.8	21.9	23.7	25.4	26.7	27.2	26.9	26.8	25.9	24.4	23.2	21.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.5	24.7	25.7	27.5	28.7	29.1	28.7	28.4	27.8	26.7	25.6	24.6
		MCDB	26.3	29.4	30.1	31.9	33.3	33.7	33.3	32.9	31.9	29.9	28.3	26.8
	2%	WB	22.5	23.7	25.1	26.7	28.0	28.4	28.1	27.8	27.2	26.2	25.1	23.8
		MCDB	24.6	27.1	29.1	30.9	32.6	32.8	32.6	32.3	30.9	29.1	27.6	25.6
	5%	WB	21.9	23.1	24.5	26.2	27.5	27.9	27.6	27.5	26.8	25.8	24.7	23.1
		MCDB	23.9	25.7	27.9	30.0	31.7	32.3	31.9	31.6	30.3	28.4	27.0	24.8
	10%	WB	21.3	22.5	24.0	25.8	27.0	27.5	27.2	27.1	26.5	25.4	24.2	22.2
		MCDB	23.3	24.8	26.9	29.2	30.9	31.5	31.2	31.0	29.7	27.8	26.4	24.0
Mean Daily Temperature Range	5% DB	MDBR	5.4	5.5	5.8	5.9	6.5	6.5	6.5	6.6	5.9	5.5	5.1	5.1
		MCDBR	6.7	7.1	7.2	7.5	7.9	7.7	7.9	8.0	7.6	6.7	6.3	6.3
		MCWBR	2.9	2.8	2.6	2.5	2.7	2.6	2.6	2.6	2.3	2.1	2.1	2.7
	5% WB	MCDBR	5.6	6.4	6.7	6.9	7.4	7.1	7.1	7.3	6.7	5.3	4.9	5.1
		MCWBR	2.7	2.8	2.7	2.7	2.9	2.8	2.7	2.8	2.5	2.1	1.9	2.6
Clear-Sky Solar Irradiance	taub	0.567	0.569	0.675	0.642	0.504	0.481	0.462	0.502	0.560	0.619	0.577	0.595	
	taud	1.834	1.873	1.676	1.798	2.211	2.292	2.338	2.205	2.003	1.806	1.873	1.792	
	Ebn at Noon	709	740	680	710	807	817	834	807	757	690	696	666	
	Edh at Noon	197	199	250	223	146	134	128	147	178	210	188	200	
All-Sky Solar Radiation	RadAvg	2.84	3.56	4.17	4.98	5.60	5.50	5.46	5.17	4.57	3.96	3.22	2.67	
	RadStd	0.53	0.62	0.42	0.50	0.46	0.48	0.47	0.36	0.44	0.42	0.38	0.45	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	-1.12	+0.38	N/A	N/A	N/A	N/A	N/A	N/A
Regional (7 neighbors)		N/A	N/A	-1.00	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page