

SANHU DAO, China

WMO: 599850

Lat: 16.5343N

Lon: 111.6056E

Elev: 16

StdP: 14.69

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	69.4	70.4	59.4	75.5	71.5	61.4	81.5	72.4	23.3	71.5	22.3	71.7	14.2	40	0.428

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	8.2	93.3	84.0	92.3	83.6	91.4	83.2	85.3	91.3	84.6	90.6	84.1	90.1	7.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
83.6	176.0	90.0	83.0	172.3	89.2	82.5	169.3	88.6	49.8	91.8	49.0	90.9	48.3	90.4	91.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.2	18.9	16.9	DB	67.0	95.5	1.9	1.3	65.6	96.4	64.5	97.2	63.5	97.9	62.1	98.9	(4)
(5)			WB	61.7	86.7	2.0	1.4	60.3	87.7	59.2	88.6	58.1	89.4	56.6	90.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.1	76.0	77.2	80.4	83.8	85.9	86.7	85.8	85.2	83.8	82.3	80.4	77.3
	DBStd	4.24	2.39	2.76	2.65	2.15	2.26	2.16	2.15	1.94	2.04	1.72	2.20	2.62
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11709	805	761	942	1015	1114	1100	1109	1090	1015	1000	911	847
	CDD65	6234	340	341	477	565	649	650	644	625	565	535	461	382
	CDH74	65694	1430	1897	4131	6504	8400	8630	8267	7814	6579	5635	4160	2247
	CDH80	24400	105	305	1055	2457	3996	4335	3854	3415	2429	1541	715	193
Wind	WSAvg	8.3	10.9	8.8	7.7	6.6	6.4	7.1	6.8	6.8	6.1	8.6	11.3	12.6
Precipitation	PrecAvg	52.7	0.8	0.5	0.7	2.2	3.5	3.2	6.5	7.8	8.8	9.5	6.1	3.2
	PrecMax	78.5	4.1	1.2	1.7	12.2	8.1	10.6	14.5	22.6	25.4	24.0	17.8	14.2
	PrecMin	22.7	0.0	0.1	0.3	0.0	0.0	0.0	1.2	0.3	1.9	0.6	1.1	0.0
	PrecStd	13.9	0.9	0.4	0.5	3.0	2.7	3.1	3.7	6.3	5.9	5.1	4.3	3.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	84.5	86.8	90.0	92.4	94.5	95.0	94.0	92.7	91.7	89.7	88.1	85.4
		MCWB	76.8	78.3	80.3	81.8	84.1	84.5	84.7	84.2	83.1	81.4	80.9	77.6
	2%	DB	82.7	85.2	88.4	91.0	93.0	93.4	92.3	91.5	90.5	88.3	86.6	83.5
		MCWB	75.6	77.2	79.6	81.5	83.6	84.1	83.9	83.9	82.8	80.8	79.8	76.6
	5%	DB	81.0	83.6	87.0	89.9	91.8	92.2	91.3	90.5	89.5	87.2	85.3	82.1
		MCWB	74.3	76.2	78.9	81.2	83.1	83.9	83.4	83.4	82.5	80.3	79.1	75.7
	10%	DB	79.7	81.9	85.4	88.8	90.7	91.0	90.3	89.5	88.5	86.0	83.8	80.8
		MCWB	73.4	75.1	77.8	80.7	82.7	83.5	83.0	83.0	82.0	79.5	78.1	75.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.1	79.5	81.4	83.6	85.4	86.1	85.9	86.0	85.0	83.2	82.1	79.1
		MCDB	82.8	85.4	88.2	90.1	92.2	92.3	91.9	91.2	89.8	88.1	86.5	83.8
	2%	WB	76.7	78.1	80.3	82.6	84.5	85.3	85.0	84.6	83.9	82.0	80.7	77.7
		MCDB	80.8	83.6	87.0	89.3	91.2	91.6	91.0	90.0	89.0	86.8	85.5	81.7
	5%	WB	75.5	76.9	79.4	81.8	83.8	84.5	84.2	84.0	83.1	81.2	79.6	76.9
		MCDB	79.7	81.6	85.4	88.3	90.2	90.9	90.2	89.4	88.2	85.7	84.0	80.5
	10%	WB	74.5	75.9	78.4	81.0	83.2	83.9	83.4	83.3	82.3	80.4	78.8	76.1
		MCDB	78.5	80.3	83.8	87.3	89.1	89.9	89.0	88.4	87.3	84.6	82.7	79.8
Mean Daily Temperature Range	5% DB	MDBR	6.5	7.9	9.0	9.4	8.9	8.2	8.3	8.0	8.4	7.4	5.7	5.4
		MCDBR	8.3	9.8	10.8	10.6	10.1	9.5	9.6	9.4	9.8	9.0	7.7	7.2
		MCWBR	4.1	4.4	4.5	4.2	4.0	4.0	4.3	4.6	4.9	4.7	4.0	3.5
	5% WB	MCDBR	7.7	9.6	10.5	9.9	9.1	8.8	9.0	8.7	9.2	8.5	7.3	6.4
		MCWBR	4.0	4.4	4.6	4.2	4.1	4.3	4.6	4.7	5.1	4.8	4.0	3.4
Clear-Sky Solar Irradiance	taub	0.484	0.481	0.545	0.507	0.451	0.446	0.436	0.450	0.487	0.536	0.541	0.556	
	taud	2.140	2.171	2.024	2.185	2.415	2.439	2.466	2.407	2.277	2.078	2.025	1.943	
	Ebn at Noon	254	262	249	258	270	268	271	270	261	244	235	228	
	Edh at Noon	47	48	56	48	38	36	36	38	43	51	52	56	
All-Sky Solar Radiation	RadAvg	1343	1635	1853	2053	2024	1931	1845	1789	1669	1553	1315	1156	
	RadStd	128	158	139	105	133	163	140	136	115	136	171	181	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	-0.43	-0.54	N/A	N/A	N/A	N/A
Regional (1 neighbor)	+0.49	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+202	+202

Nomenclature: See separate page