

TENERIFE SUR, Spain

WMO: 600250

Lat: 28.044N

Lon: 16.572W

Elev: 209

StdP: 14.59

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	56.9	58.1	26.9	21.0	71.7	32.2	26.9	71.4	37.4	66.8	33.3	67.1	7.7	10	0.456

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.5	90.1	66.8	86.3	67.7	84.0	69.0	73.7	81.6	72.7	80.5	71.9	79.7	18.9	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
71.3	116.4	78.3	70.0	111.1	77.6	69.1	107.7	77.2	37.3	82.0	36.4	80.9	35.7	80.3	80.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
30.1	27.5	25.2	53.2	98.3	1.5	5.6	52.1	102.4	51.3	105.7	50.4	108.9	49.4	113.0		
			45.2	75.7	2.1	1.8	43.6	77.0	42.4	78.0	41.2	79.0	39.7	80.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	70.8	65.5	65.4	66.7	67.6	69.5	72.3	75.6	77.1	76.1	74.6	71.1	67.9
	DBStd	5.02	2.58	3.02	3.39	3.19	2.81	2.47	3.33	3.17	2.38	2.92	3.01	2.39
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	70	23	26	14	4	0	0	0	0	0	0	0	3
	CDD50	7596	481	431	516	529	605	670	792	840	782	761	634	555
	CDD65	2193	39	37	66	83	141	220	327	375	332	296	184	93
	CDH74	10195	40	86	239	249	341	750	2003	2555	1886	1427	504	115
	CDH80	1999	1	6	51	86	63	85	477	630	290	246	60	4
(14) Wind	WSAvg	12.3	12.1	13.0	12.3	12.0	11.8	11.8	14.1	13.9	11.9	10.5	11.8	12.3
(15) Precipitation	PrecAvg	11.3	1.5	1.7	1.5	0.6	0.1	0.0	0.0	0.2	0.2	1.2	1.6	2.7
	PrecMax	21.5	6.5	8.7	6.1	1.9	0.6	0.1	0.0	2.2	1.4	3.6	6.9	9.2
	PrecMin	5.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	4.6	1.6	2.1	1.5	0.6	0.2	0.0	0.0	0.5	0.4	1.0	1.5	2.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.3	80.6	85.9	89.9	87.4	86.7	97.2	95.4	90.7	91.6	86.1	80.3
		MCWB	59.9	58.5	61.3	62.3	62.5	67.9	64.7	67.8	67.7	66.5	65.4	59.9
	2%	DB	74.8	76.8	80.3	80.2	80.3	82.1	88.2	89.5	84.5	85.7	81.0	77.0
		MCWB	60.1	59.2	59.0	62.9	65.6	68.8	67.2	69.0	71.3	67.9	65.2	61.5
	5%	DB	72.3	73.5	75.7	75.3	77.0	79.2	84.4	85.2	82.6	82.1	78.8	74.9
		MCWB	60.3	59.7	60.4	64.2	65.5	67.9	68.1	70.1	70.9	69.4	65.8	62.7
	10%	DB	71.0	71.4	73.1	73.3	75.2	77.5	81.5	82.7	81.0	80.2	76.9	73.2
		MCWB	60.0	60.2	61.7	62.8	64.7	67.3	68.9	70.4	70.4	69.1	65.9	62.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.0	66.9	67.4	68.1	70.4	72.5	74.3	75.4	74.6	74.1	71.9	69.3
		MCDB	72.6	71.2	73.8	76.4	77.4	80.4	84.1	84.6	81.7	81.1	77.7	72.8
	2%	WB	64.7	64.7	65.5	66.3	68.4	70.7	72.1	73.7	73.4	72.5	69.8	67.4
		MCDB	70.7	70.5	71.9	74.3	75.8	78.5	81.0	82.6	80.6	79.1	76.5	71.9
	5%	WB	63.3	63.1	64.3	65.0	67.0	69.4	71.0	72.6	72.5	71.5	68.5	65.6
		MCDB	69.3	69.6	71.1	72.6	74.5	77.1	79.9	81.2	79.9	78.3	75.4	70.9
	10%	WB	61.9	61.8	63.1	63.8	65.7	68.3	70.0	71.7	71.6	70.3	67.3	64.1
		MCDB	68.2	68.7	70.0	71.1	73.2	75.9	78.9	80.1	79.2	77.3	74.4	70.5
(35) Mean Daily Temperature Range	5% DB	MDBR	11.3	11.8	12.6	12.0	11.9	11.7	12.9	12.5	11.4	11.8	11.2	11.0
		MCDBR	12.8	14.5	16.7	15.0	14.4	13.9	17.1	15.9	12.9	14.7	13.0	13.2
		MCWBR	10.2	10.1	9.6	8.4	7.7	7.2	8.3	7.8	6.9	8.6	8.6	10.6
	5% WB	MCDBR	12.0	12.6	13.9	13.5	13.3	13.2	14.0	13.6	12.2	12.3	11.9	10.9
		MCWBR	9.9	9.3	8.9	8.4	7.8	7.4	7.5	7.3	7.2	8.1	8.4	9.0
(40) Clear-Sky Solar Irradiance	taub		0.372	0.395	0.428	0.415	0.403	0.436	0.533	0.529	0.473	0.412	0.393	0.384
	taud		2.413	2.324	2.217	2.298	2.358	2.264	1.964	2.005	2.186	2.380	2.399	2.382
	Ebn at Noon		274	277	274	280	282	271	246	246	257	268	265	264
	Edh at Noon		32	38	44	42	40	43	59	56	45	35	32	32
(44) All-Sky Solar Radiation	RadAvg		1175	1443	1812	2089	2261	2344	2293	2141	1906	1542	1195	1057
	RadStd		50	86	57	77	67	72	68	71	68	50	62	73

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	-5.08	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page