

TENERIFE SUR, Spain

WMO: 600250

Lat: 28.044N

Lon: 16.572W

Elev: 64

StdP: 100.56

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	13.8	14.5	-2.8	3.0	22.1	0.1	3.8	21.9	16.7	19.3	14.9	19.5	3.5	10	0.456

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.0	32.3	19.4	30.2	19.9	28.9	20.5	23.2	27.5	22.6	26.9	22.2	26.5	8.4	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.8	16.6	25.7	21.1	15.9	25.4	20.6	15.4	25.1	68.9	27.8	66.8	27.2	65.1	26.8	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.5	12.3	11.3	DB	11.8	36.9	0.8	3.1	11.2	39.1	10.7	40.9	10.2	42.7	9.7	45.0	(4)
(5)			WB	7.3	24.3	1.2	1.0	6.5	25.0	5.8	25.6	5.1	26.1	4.3	26.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.6	18.6	18.6	19.3	19.8	20.8	22.4	24.2	25.1	24.5	23.6	21.7	19.9
	DBStd	2.79	1.43	1.68	1.88	1.77	1.56	1.37	1.85	1.76	1.32	1.62	1.67	1.33
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	39	13	14	8	2	0	0	0	0	0	0	0	2
	CDD10.0	4220	267	239	287	294	336	372	440	467	434	423	352	308
	CDD18.3	1218	22	21	37	46	78	122	182	208	184	164	102	52
	CDH23.3	5664	22	48	133	138	189	417	1113	1419	1048	793	280	64
	CDH26.7	1111	1	3	28	48	35	47	265	350	161	137	33	2
Wind	WSAvg	5.5	5.4	5.8	5.5	5.4	5.3	5.3	6.3	6.2	5.3	4.7	5.3	5.5
Precipitation	PrecAvg	288	37	44	38	16	3	1	0	5	6	30	40	68
	PrecMax	546	164	220	156	49	14	3	1	56	36	91	175	234
	PrecMin	127	0	0	0	0	0	0	0	0	0	0	1	0
	PrecStd	116	40	54	39	16	4	1	0	13	9	25	39	61
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.7	27.0	30.0	32.2	30.8	30.4	36.2	35.2	32.6	33.1	30.1	26.8
		MCWB	15.5	14.7	16.3	16.8	17.0	19.9	18.2	19.9	19.9	19.2	18.6	15.5
	2%	DB	23.8	24.9	26.8	26.8	26.8	27.8	31.2	31.9	29.1	29.8	27.2	25.0
		MCWB	15.6	15.1	15.0	17.1	18.7	20.4	19.6	20.6	21.9	19.9	18.5	16.4
	5%	DB	22.4	23.0	24.3	24.1	25.0	26.2	29.1	29.5	28.1	27.8	26.0	23.8
		MCWB	15.7	15.4	15.8	17.9	18.6	19.9	20.0	21.2	21.6	20.8	18.8	17.0
	10%	DB	21.7	21.9	22.8	22.9	24.0	25.3	27.5	28.2	27.2	26.8	24.9	22.9
		MCWB	15.6	15.7	16.5	17.1	18.2	19.6	20.5	21.4	21.3	20.6	18.8	16.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.4	19.4	19.6	20.0	21.3	22.5	23.5	24.1	23.7	23.4	22.2	20.7
		MCDB	22.6	21.8	23.2	24.7	25.2	26.9	29.0	29.2	27.6	27.3	25.4	22.7
	2%	WB	18.2	18.2	18.6	19.1	20.2	21.5	22.3	23.2	23.0	22.5	21.0	19.6
		MCDB	21.5	21.4	22.2	23.5	24.3	25.8	27.2	28.1	27.0	26.2	24.7	22.1
	5%	WB	17.4	17.3	17.9	18.3	19.5	20.8	21.7	22.5	22.5	22.0	20.3	18.7
		MCDB	20.7	20.9	21.7	22.6	23.6	25.0	26.6	27.3	26.6	25.7	24.1	21.6
	10%	WB	16.6	16.6	17.3	17.6	18.7	20.2	21.1	22.0	22.0	21.3	19.6	17.8
		MCDB	20.1	20.4	21.1	21.7	22.9	24.4	26.1	26.7	26.2	25.1	23.6	21.4
Mean Daily Temperature Range	5% DB	MDBR	6.3	6.6	7.0	6.7	6.6	6.5	7.1	7.0	6.3	6.6	6.2	6.1
		MCDBR	7.1	8.1	9.3	8.3	8.0	7.7	9.5	8.8	7.2	8.2	7.2	7.4
		MCWBR	5.7	5.6	5.3	4.6	4.3	4.0	4.6	4.3	3.8	4.8	4.8	5.9
	5% WB	MCDBR	6.7	7.0	7.7	7.5	7.4	7.3	7.8	7.6	6.8	6.8	6.6	6.1
		MCWBR	5.5	5.2	4.9	4.6	4.3	4.1	4.1	4.0	4.0	4.5	4.6	5.0
Clear-Sky Solar Irradiance	taub	0.372	0.395	0.428	0.415	0.403	0.436	0.533	0.529	0.473	0.412	0.393	0.384	
	taud	2.413	2.324	2.217	2.298	2.358	2.264	1.964	2.005	2.186	2.380	2.399	2.382	
	Ebn at Noon	865	872	863	884	889	855	774	775	809	844	835	831	
	Edh at Noon	101	119	140	133	126	137	185	176	143	111	102	100	
All-Sky Solar Radiation	RadAvg	3.71	4.55	5.71	6.59	7.13	7.39	7.23	6.75	6.01	4.86	3.77	3.33	
	RadStd	0.16	0.27	0.18	0.24	0.21	0.23	0.21	0.22	0.21	0.16	0.19	0.23	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	-2.82	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page