

GRAN CANARIA, Spain

WMO: 600300

Lat: 27.932N

Lon: 15.387W

Elev: 78

StdP: 14.65

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	56.9	58.0	33.3	27.9	68.0	38.6	34.5	69.4	31.1	65.1	28.5	64.8	8.5	340	0.566

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.5	86.8	67.6	83.8	68.2	81.8	69.1	74.5	79.5	73.3	78.9	72.3	78.1	19.8	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.0	122.6	78.0	71.5	116.7	77.1	70.1	110.9	76.4	38.0	79.7	36.9	78.9	36.0	78.5	84.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 32.8	30.9	29.2	DB	53.8	94.7	1.9	4.3	52.4	97.7	51.3	100.3	50.2	102.7	48.8	105.8	(4)
(5)			WB	46.2	75.7	2.6	3.0	44.4	77.9	42.8	79.6	41.4	81.3	39.4	83.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	70.4	64.8	64.8	66.0	67.4	69.5	72.4	75.2	76.6	75.7	74.1	70.6	67.0
	DBStd	4.94	2.40	2.68	2.94	2.84	2.58	2.35	2.66	2.62	2.04	2.69	3.02	2.40
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	97	33	32	19	5	0	0	0	0	0	0	1	7
	CDD50	7433	457	414	497	522	604	672	780	826	770	746	617	528
	CDD65	2055	25	26	50	77	139	222	315	361	320	281	168	71
	CDH74	7425	11	24	98	138	210	602	1453	2033	1454	1036	322	44
	CDH80	974	0	3	11	32	27	52	246	348	113	112	29	1
Wind	WSAvg	15.9	11.4	13.5	14.3	16.0	17.7	20.3	24.5	22.5	16.4	12.1	11.8	10.5
Precipitation	PrecAvg	4.8	0.9	0.6	0.4	0.2	0.0	0.0	0.0	0.0	0.2	0.6	0.7	1.2
	PrecMax	8.4	4.9	4.1	2.5	1.1	0.4	0.1	0.2	0.2	1.5	4.5	3.7	4.6
	PrecMin	0.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	1.9	1.1	0.8	0.5	0.2	0.1	0.0	0.0	0.0	0.3	0.8	0.8	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.3	76.9	81.2	84.6	83.7	84.8	91.6	92.0	86.8	87.9	83.8	78.0
		MCWB	62.3	59.5	60.1	61.5	65.1	66.9	66.5	69.0	68.5	66.2	66.3	64.3
	2%	DB	72.2	73.4	76.6	77.3	78.2	80.8	85.5	86.3	82.5	82.6	79.2	75.0
		MCWB	62.6	61.1	60.9	62.6	64.8	67.1	67.6	69.8	71.4	68.9	66.9	63.7
	5%	DB	70.8	71.3	73.4	73.9	75.8	78.8	82.2	83.1	80.8	80.2	77.2	73.2
		MCWB	61.7	61.4	61.4	63.3	64.8	67.2	68.5	70.0	70.8	69.5	66.4	64.0
	10%	DB	69.4	69.7	71.3	72.0	74.3	77.1	79.9	81.1	79.7	78.7	75.5	71.7
		MCWB	60.9	60.9	61.5	62.6	64.4	66.8	68.2	70.0	70.2	69.2	66.2	63.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.7	68.2	68.3	68.5	70.0	72.5	74.3	78.2	75.6	74.9	73.6	70.9
		MCDB	71.3	70.8	72.8	73.8	76.4	78.1	80.9	82.5	79.9	78.5	77.4	73.2
	2%	WB	65.6	65.7	65.8	66.5	68.4	70.8	72.5	74.5	74.3	73.1	71.0	68.3
		MCDB	69.7	69.7	71.4	73.0	74.5	77.0	79.2	80.2	79.1	77.7	75.9	72.2
	5%	WB	63.9	63.9	64.1	65.2	67.1	69.4	71.2	73.1	73.1	71.8	69.2	66.3
		MCDB	68.6	68.5	70.3	71.5	73.2	75.7	77.9	79.6	78.3	77.1	74.6	70.9
	10%	WB	62.4	62.4	62.9	63.8	65.8	68.2	69.9	71.9	71.9	70.6	67.7	64.8
		MCDB	67.5	67.5	69.1	70.1	72.2	74.9	76.8	78.6	77.6	76.4	73.5	69.8
Mean Daily Temperature Range	5% DB	MDBR	9.2	9.4	10.2	10.1	9.8	9.8	9.9	9.5	8.7	9.6	9.2	9.3
		MCDBR	10.7	11.5	13.1	12.2	11.5	11.4	12.9	11.9	9.7	11.4	11.0	11.1
		MCWBR	8.5	8.8	8.8	7.2	6.9	6.3	7.3	7.3	5.8	7.8	8.1	9.2
	5% WB	MCDBR	10.2	9.7	11.3	10.9	10.3	10.2	10.6	9.9	8.8	9.9	9.6	10.4
		MCWBR	8.7	8.5	8.3	7.3	7.1	6.5	6.6	6.6	6.4	7.9	7.9	8.9
Clear-Sky Solar Irradiance	taub	0.362	0.382	0.413	0.401	0.390	0.428	0.522	0.516	0.456	0.404	0.380	0.374	
	taud	2.459	2.384	2.281	2.359	2.415	2.306	2.009	2.053	2.259	2.426	2.465	2.437	
	Ebn at Noon	279	281	279	285	286	273	248	249	262	271	270	268	
	Edh at Noon	31	36	42	40	38	42	56	53	42	34	30	30	
All-Sky Solar Radiation	RadAvg	1164	1437	1816	2079	2255	2289	2216	2095	1886	1540	1200	1052	
	RadStd	51	88	66	72	74	91	75	82	81	51	59	68	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page