

GRAN CANARIA, Spain

WMO: 600300

Lat: 27.932N

Lon: 15.387W

Elev: 24

StdP: 101.04

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.8	14.5	0.7	4.0	20.0	3.6	4.9	20.8	13.9	18.4	12.7	18.2	3.8	340	0.566

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.3	30.5	19.8	28.8	20.1	27.7	20.6	23.6	26.4	23.0	26.0	22.4	25.6	8.8	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.8	17.5	25.6	22.0	16.7	25.1	21.1	15.8	24.7	70.4	26.5	68.1	26.1	65.9	25.8	29.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
14.7	13.8	13.0	12.1	34.8	1.1	2.4	11.4	36.5	10.7	37.9	10.1	39.3	9.3	41.0		
			7.9	24.3	1.5	1.7	6.9	25.5	6.0	26.5	5.2	27.4	4.1	28.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	21.3	18.2	18.2	18.9	19.7	20.8	22.5	24.0	24.8	24.3	23.4	21.4	19.5	(6)
(7)		DBStd	2.74	1.33	1.49	1.63	1.58	1.44	1.30	1.48	1.45	1.14	1.50	1.68	1.33	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	54	18	18	11	3	0	0	0	0	0	0	1	4	(9)
(10)		CDD10.0	4129	254	230	276	290	336	373	433	459	428	414	343	293	(10)
(11)		CDD18.3	1142	14	14	28	43	77	123	175	201	178	156	93	39	(11)
(12)		CDH23.3	4125	6	13	54	77	117	334	807	1129	808	576	179	24	(12)
(13)	CDH26.7	541	0	2	6	18	15	29	137	193	63	62	16	1	(13)	
(14)	Wind	WSAvg	7.1	5.1	6.1	6.4	7.2	7.9	9.1	10.9	10.1	7.3	5.4	5.3	4.7	(14)
(15)	Precipitation	PrecAvg	122	22	15	10	4	1	0	0	5	16	19	30	(15)	
(16)		PrecMax	214	124	103	63	28	11	3	5	37	114	94	118	(16)	
(17)		PrecMin	24	0	0	0	0	0	0	0	0	0	0	0	(17)	
(18)		PrecStd	49	27	20	12	6	3	1	1	8	20	21	29	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.0	24.9	27.3	29.2	28.7	29.4	33.1	33.3	30.5	31.0	28.8	25.6	(19)
(20)			MCWB	16.9	15.3	15.6	16.4	18.4	19.4	19.2	20.5	20.3	19.0	19.1	17.9	(20)
(21)		2%	DB	22.3	23.0	24.8	25.2	25.7	27.1	29.7	30.1	28.0	28.1	26.2	23.9	(21)
(22)			MCWB	17.0	16.2	16.1	17.0	18.2	19.5	19.8	21.0	21.9	20.5	19.4	17.6	(22)
(23)		5%	DB	21.5	21.9	23.0	23.3	24.3	26.0	27.9	28.4	27.1	26.8	25.1	22.9	(23)
(24)			MCWB	16.5	16.3	16.3	17.4	18.2	19.5	20.3	21.1	21.5	20.8	19.1	17.8	(24)
(25)		10%	DB	20.8	20.9	21.8	22.2	23.5	25.1	26.6	27.3	26.5	25.9	24.2	22.1	(25)
(26)			MCWB	16.1	16.1	16.4	17.0	18.0	19.3	20.1	21.1	21.2	20.6	19.0	17.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.8	20.1	20.2	20.3	21.1	22.5	23.5	25.7	24.2	23.8	23.1	21.6	(27)
(28)			MADB	21.9	21.6	22.7	23.2	24.7	25.6	27.2	28.0	26.6	25.8	25.2	22.9	(28)
(29)		2%	WB	18.6	18.7	18.8	19.2	20.2	21.5	22.5	23.6	23.5	22.8	21.7	20.2	(29)
(30)			MADB	21.0	20.9	21.9	22.8	23.6	25.0	26.2	26.8	26.2	25.4	24.4	22.3	(30)
(31)		5%	WB	17.7	17.7	17.9	18.4	19.5	20.8	21.8	22.8	22.8	22.1	20.7	19.1	(31)
(32)			MADB	20.4	20.3	21.3	22.0	22.9	24.3	25.5	26.4	25.7	25.1	23.6	21.6	(32)
(33)		10%	WB	16.9	16.9	17.2	17.7	18.8	20.1	21.1	22.2	22.2	21.4	19.8	18.2	(33)
(34)			MADB	19.7	19.7	20.6	21.1	22.3	23.9	24.9	25.9	25.3	24.7	23.1	21.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.1	5.2	5.6	5.6	5.5	5.4	5.5	5.3	4.9	5.3	5.1	5.2	(35)
(36)			MCDBR	6.0	6.4	7.3	6.8	6.4	6.4	7.2	6.6	5.4	6.3	6.1	6.2	(36)
(37)			MCWBR	4.7	4.9	4.9	4.0	3.8	3.5	4.1	4.0	3.2	4.3	4.5	5.1	(37)
(38)		5% WB	MCDDBR	5.6	5.4	6.3	6.0	5.7	5.6	5.9	5.5	4.9	5.5	5.3	5.8	(38)
(39)			MCWBR	4.8	4.7	4.6	4.1	3.9	3.6	3.7	3.7	3.5	4.4	4.4	5.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.362	0.382	0.413	0.401	0.390	0.428	0.522	0.516	0.456	0.404	0.380	0.374	(40)	
(41)		taud	2.459	2.384	2.281	2.359	2.415	2.306	2.009	2.053	2.259	2.426	2.465	2.437	(41)	
(42)		Ebn at Noon	878	887	878	897	902	862	783	785	826	854	852	846	(42)	
(43)		Edh at Noon	97	112	132	125	119	132	177	168	133	106	96	95	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.67	4.53	5.72	6.55	7.11	7.22	6.99	6.60	5.95	4.85	3.78	3.32	(44)	
(45)		RadStd	0.16	0.28	0.21	0.23	0.23	0.29	0.24	0.26	0.25	0.16	0.18	0.21	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page