

LANZAROTE, Spain

WMO: 600400

Lat: 28.945N

Lon: 13.605W

Elev: 47

StdP: 14.67

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	55.1	56.5	37.4	32.9	68.2	41.7	38.9	66.6	29.7	66.2	27.0	64.8	7.5	0	0.493

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.5	91.0	69.6	86.7	70.0	84.3	69.9	73.6	82.6	72.6	81.5	71.7	80.6	17.1	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.2	115.3	77.0	69.9	110.0	76.7	68.7	105.8	76.2	37.1	82.5	36.2	81.5	35.4	80.6	78.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.6	27.2	25.1	DB	51.9	99.0	1.5	5.1	50.8	102.6	49.9	105.6	49.1	108.5	48.0	112.1	(4)
(5)			WB	45.6	75.3	1.9	1.4	44.2	76.4	43.1	77.2	42.1	78.0	40.7	79.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	70.7	63.9	64.4	66.4	68.1	70.6	73.5	76.4	78.2	76.8	74.3	69.9	66.0
	DBStd	5.65	2.45	2.90	3.26	3.19	3.04	2.99	3.35	2.82	2.42	2.91	3.13	2.28
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	130	51	41	19	3	0	0	0	0	0	0	1	15
	CDD50	7571	430	404	508	542	639	706	818	874	805	752	597	496
	CDD65	2226	16	25	62	95	174	256	353	409	355	287	148	46
	CDH74	10367	8	20	132	246	519	1063	2037	2693	2051	1266	318	14
	CDH80	2343	0	0	13	51	90	190	547	815	425	186	26	0
Wind	WSAvg	13.2	10.6	12.2	12.5	13.5	14.7	15.5	19.1	17.2	12.0	10.0	10.7	10.2
Precipitation	PrecAvg	5.1	0.8	0.7	0.6	0.2	0.1	0.0	0.0	0.0	0.1	0.6	0.8	1.2
	PrecMax	10.1	3.0	3.7	1.9	0.7	0.4	0.2	0.0	0.2	0.5	2.5	4.9	5.2
	PrecMin	2.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1
	PrecStd	1.7	0.8	0.9	0.6	0.2	0.1	0.0	0.0	0.1	0.1	0.7	0.9	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.0	76.8	81.9	86.3	88.5	91.3	97.9	97.2	91.6	88.2	83.1	75.6
		MCWB	62.3	62.1	61.6	62.5	63.5	68.9	69.0	70.8	71.1	68.0	67.5	63.7
	2%	DB	72.0	73.5	77.2	79.3	81.5	84.5	89.5	90.5	85.9	84.2	79.1	73.8
		MCWB	61.8	61.1	62.5	63.9	65.9	69.0	70.3	71.3	71.0	69.2	67.0	63.3
	5%	DB	70.4	71.6	74.5	76.1	78.5	81.0	84.5	86.1	83.9	81.7	77.2	72.5
		MCWB	60.9	61.1	62.0	63.2	65.0	67.7	70.3	71.2	70.2	68.9	66.1	63.2
	10%	DB	69.2	69.9	72.3	73.7	76.4	79.1	82.1	84.0	82.3	79.7	75.5	71.3
		MCWB	60.2	60.5	61.5	62.1	64.3	66.7	69.2	70.4	69.6	68.6	65.5	62.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.1	66.9	68.7	68.4	70.1	72.5	74.5	74.7	74.5	74.3	72.8	69.3
		MCDB	70.3	71.3	72.2	77.3	79.3	81.7	82.3	87.3	83.4	79.0	77.6	72.7
	2%	WB	64.6	65.0	66.2	66.2	68.2	70.8	72.5	73.5	73.0	72.6	70.7	67.6
		MCDB	69.3	69.7	71.3	74.3	76.9	80.4	82.9	84.4	81.5	78.2	75.6	71.3
	5%	WB	63.1	63.5	64.8	64.6	66.9	69.3	71.1	72.3	72.0	71.6	69.1	65.7
		MCDB	68.4	68.7	70.8	72.9	75.6	78.5	81.6	83.0	80.6	77.8	74.4	70.1
	10%	WB	61.8	62.1	63.4	63.5	65.5	68.2	70.0	71.4	71.1	70.6	67.5	64.2
		MCDB	67.5	67.8	70.1	71.7	74.2	76.9	80.1	81.7	79.7	77.2	73.3	69.3
Mean Daily Temperature Range	5% DB	MDBR	10.9	11.3	12.6	12.7	12.7	12.6	13.1	13.5	12.6	11.9	11.1	10.6
		MCDBR	12.1	13.0	15.1	15.5	15.5	15.1	16.3	16.8	14.2	14.3	12.5	11.8
		MCWBR	8.0	8.1	8.3	6.7	6.6	5.6	5.5	5.5	5.3	7.1	7.5	8.2
	5% WB	MCDBR	11.7	11.4	13.3	14.5	14.8	14.7	15.2	15.1	13.1	12.2	11.6	10.7
	MCWBR	8.8	8.6	9.0	7.3	7.2	6.2	5.7	5.6	6.1	7.7	8.7	9.0	
Clear-Sky Solar Irradiance	taub	0.361	0.388	0.429	0.412	0.404	0.444	0.535	0.527	0.447	0.410	0.386	0.375	
	taud	2.451	2.353	2.213	2.303	2.357	2.247	1.967	2.014	2.275	2.382	2.421	2.419	
	Ebn at Noon	277	278	272	281	282	269	245	246	264	267	266	266	
	Edh at Noon	30	36	44	42	40	44	58	55	41	35	31	30	
All-Sky Solar Radiation	RadAvg	1107	1376	1744	2015	2156	2191	2105	1997	1833	1474	1144	1007	
	RadStd	62	86	67	85	96	113	105	96	76	55	63	59	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	+0.85	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page