

LANZAROTE, Spain

WMO: 600400

Lat: 28.945N

Lon: 13.605W

Elev: 14

StdP: 101.15

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.8	13.6	3.0	4.7	20.1	5.4	5.6	19.2	13.3	19.0	12.1	18.2	3.3	0	0.493

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.5	32.8	20.9	30.4	21.1	29.1	21.0	23.1	28.1	22.6	27.5	22.1	27.0	7.7	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.8	16.5	25.0	21.0	15.7	24.8	20.4	15.1	24.6	68.5	28.0	66.3	27.5	64.5	27.0	25.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.2	12.2	11.2	11.0	37.2	0.8	2.8	10.4	39.2	10.0	40.9	9.5	42.5	8.9	44.5
			7.5	24.1	1.0	0.8	6.8	24.6	6.2	25.1	5.6	25.5	4.9	26.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.5	17.7	18.0	19.1	20.0	21.5	23.1	24.7	25.7	24.9	23.5	21.1	18.9
	DBStd	3.14	1.36	1.61	1.81	1.77	1.69	1.66	1.86	1.57	1.35	1.61	1.74	1.27
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	72	28	23	11	2	0	0	0	0	0	0	1	8
	CDD10.0	4206	239	224	282	301	355	392	454	486	447	418	332	276
	CDD18.3	1237	9	14	34	53	97	142	196	227	197	159	82	26
	CDH23.3	5759	4	11	73	137	288	591	1132	1496	1139	703	177	8
CDH26.7	1302	0	0	7	28	50	106	304	453	236	103	14	0	
Wind	WSAvg	5.9	4.7	5.5	5.6	6.0	6.6	6.9	8.5	7.7	5.4	4.5	4.8	4.6
Precipitation	PrecAvg	130	21	17	15	5	2	0	0	1	3	16	20	31
	PrecMax	257	76	94	47	18	9	5	1	6	12	64	125	131
	PrecMin	68	0	0	0	0	0	0	0	0	0	0	0	3
	PrecStd	43	20	22	14	5	3	1	0	2	3	19	23	28
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.9	24.9	27.7	30.2	31.4	32.9	36.6	36.2	33.1	31.2	28.4	24.2
		MCWB	16.8	16.7	16.5	17.0	17.5	20.5	20.5	21.5	21.7	20.0	19.7	17.6
	2%	DB	22.2	23.0	25.1	26.3	27.5	29.1	32.0	32.5	29.9	29.0	26.2	23.2
		MCWB	16.6	16.2	16.9	17.7	18.9	20.5	21.3	21.8	21.7	20.7	19.4	17.4
	5%	DB	21.3	22.0	23.6	24.5	25.9	27.2	29.2	30.1	28.8	27.6	25.1	22.5
		MCWB	16.1	16.2	16.6	17.3	18.3	19.8	21.3	21.8	21.2	20.5	19.0	17.3
	10%	DB	20.6	21.1	22.4	23.2	24.7	26.2	27.8	28.9	28.0	26.5	24.1	21.8
		MCWB	15.7	15.8	16.4	16.7	17.9	19.3	20.7	21.3	20.9	20.3	18.6	17.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.5	19.4	20.4	20.2	21.2	22.5	23.6	23.7	23.6	23.5	22.7	20.7
		MCDB	21.3	21.8	22.3	25.2	26.3	27.6	28.0	30.7	28.6	26.1	25.3	22.6
	2%	WB	18.1	18.3	19.0	19.0	20.1	21.6	22.5	23.0	22.8	22.5	21.5	19.8
		MCDB	20.7	21.0	21.9	23.5	25.0	26.9	28.3	29.1	27.5	25.7	24.2	21.8
	5%	WB	17.3	17.5	18.2	18.1	19.4	20.7	21.7	22.4	22.2	22.0	20.6	18.7
		MCDB	20.2	20.4	21.6	22.7	24.2	25.8	27.6	28.3	27.0	25.4	23.5	21.2
	10%	WB	16.6	16.7	17.5	17.5	18.6	20.1	21.1	21.9	21.7	21.4	19.7	17.9
		MCDB	19.7	19.9	21.2	22.0	23.5	25.0	26.7	27.6	26.5	25.1	22.9	20.7
Mean Daily Temperature Range	5% DB	MDBR	6.1	6.3	7.0	7.1	7.1	7.0	7.3	7.5	7.0	6.6	6.2	5.9
		MCDBR	6.7	7.2	8.4	8.6	8.6	8.4	9.1	9.3	7.9	7.9	6.9	6.6
		MCWBR	4.5	4.5	4.6	3.7	3.7	3.1	3.0	3.1	2.9	3.9	4.1	4.5
	5% WB	MCDBR	6.5	6.3	7.4	8.1	8.2	8.2	8.4	8.4	7.3	6.8	6.5	5.9
		MCWBR	4.9	4.8	5.0	4.1	4.0	3.4	3.2	3.1	3.4	4.3	4.8	5.0
Clear-Sky Solar Irradiance	taub	0.361	0.388	0.429	0.412	0.404	0.444	0.535	0.527	0.447	0.410	0.386	0.375	
	taud	2.451	2.353	2.213	2.303	2.357	2.247	1.967	2.014	2.275	2.382	2.421	2.419	
	Ebn at Noon	873	876	859	885	888	848	772	775	831	842	838	837	
	Edh at Noon	96	115	140	132	126	140	184	174	130	110	99	96	
All-Sky Solar Radiation	RadAvg	3.49	4.34	5.50	6.35	6.80	6.91	6.63	6.30	5.78	4.65	3.61	3.17	
	RadStd	0.20	0.27	0.21	0.27	0.30	0.36	0.33	0.30	0.24	0.17	0.20	0.19	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	+0.47	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page