

AGADIR INEZGANE, Morocco

WMO: 602500

Lat: 30.381N

Lon: 9.546W

Elev: 89

StdP: 14.65

Time Zone: 1.00 (E01)

Period: 82-91

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	41.0	43.6	28.2	22.2	66.7	31.9	26.4	66.1	39.5	69.3	30.7	72.1	2.0	80	0.356

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	14.9	95.3	66.9	89.3	65.9	84.1	65.2	72.4	83.7	71.3	79.9	70.3	77.7	10.6	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.7	109.7	75.3	68.4	104.8	73.8	68.1	103.4	73.4	36.1	83.8	35.1	80.3	34.4	77.3	85.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.6	19.5	16.1	DB	35.7	109.3	1.8	5.6	34.4	113.4	33.3	116.6	32.3	119.8	31.0	123.8	(4)
(5)			WB	34.3	77.4	1.5	3.3	33.2	79.7	32.3	81.6	31.4	83.5	30.3	85.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	65.6	56.9	59.6	62.8	63.6	65.9	69.0	71.7	72.7	72.7	68.9	64.2	59.5	(6)
(7)		DBStd	7.15	4.72	5.29	5.66	5.17	4.37	2.83	3.37	4.86	5.50	5.58	5.09	5.53	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	936	260	169	113	82	29	1	0	0	0	16	74	192	(9)
(10)		CDD50	5711	214	268	397	408	493	569	674	703	682	585	425	293	(10)
(11)		CDD65	1171	8	17	45	40	57	120	209	238	232	136	49	20	(11)
(12)		CDH74	5831	77	134	468	394	311	231	602	1045	1277	891	264	137	(12)
(13)		CDH80	2193	18	32	171	200	152	47	144	434	542	359	62	32	(13)
(14)	Wind	WSAvg	6.2	5.6	7.0	6.7	7.4	7.8	6.9	5.3	5.3	5.6	5.9	5.3	5.5	(14)
(15)	Precipitation	PrecAvg	10.0	1.9	1.3	1.2	0.6	0.2	0.0	0.0	0.0	0.1	0.8	1.8	2.2	(15)
(16)		PrecMax	26.4	7.0	4.4	5.2	4.0	1.4	0.5	0.0	0.1	1.7	3.3	7.6	12.4	(16)
(17)		PrecMin	1.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	5.7	2.1	1.4	1.3	0.7	0.3	0.1	0.0	0.0	0.3	0.9	2.1	2.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.1	84.3	91.2	95.3	98.3	86.2	91.3	107.3	104.2	96.6	87.6	84.1	(19)
(20)			MCWB	59.2	59.7	61.1	62.4	72.1	68.8	71.8	72.0	69.8	66.3	62.5	61.4	(20)
(21)		2%	DB	74.9	77.4	84.6	85.8	80.5	78.6	82.5	91.1	93.1	89.4	80.8	77.4	(21)
(22)			MCWB	56.2	58.5	61.1	61.5	65.6	67.3	69.7	70.8	68.6	65.5	62.1	59.9	(22)
(23)		5%	DB	70.1	73.4	78.8	75.5	75.0	75.8	79.1	82.2	85.4	82.6	76.7	73.0	(23)
(24)			MCWB	55.2	57.9	59.7	61.4	64.9	66.9	69.3	70.5	68.9	64.5	62.7	58.6	(24)
(25)		10%	DB	66.5	69.8	73.3	71.2	72.0	74.0	76.8	78.3	80.3	77.4	73.3	69.5	(25)
(26)			MCWB	55.9	57.0	60.3	61.6	63.9	66.2	69.1	69.8	69.6	65.3	62.8	58.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	62.4	64.1	65.7	66.6	71.5	71.0	73.3	74.3	73.7	70.3	69.2	65.7	(27)
(28)			MCDWB	76.0	71.2	75.9	76.9	91.7	80.7	85.1	92.2	86.6	79.1	74.4	74.1	(28)
(29)		2%	WB	60.3	62.2	63.9	64.9	67.9	69.1	71.6	72.4	72.0	69.1	67.1	63.8	(29)
(30)			MCDWB	66.5	69.5	73.8	73.8	76.9	75.8	78.8	84.4	81.8	77.2	72.1	70.6	(30)
(31)		5%	WB	59.2	61.0	62.8	63.7	66.3	67.9	70.6	71.1	70.9	68.1	65.6	62.3	(31)
(32)			MCDWB	65.0	67.9	71.9	71.4	73.1	73.9	76.7	80.0	79.7	75.8	71.3	68.3	(32)
(33)		10%	WB	57.9	59.8	61.7	62.7	65.0	67.1	69.7	70.1	69.9	67.1	64.5	60.7	(33)
(34)			MCDWB	64.4	66.4	70.1	69.3	70.9	72.7	74.8	77.0	77.9	74.4	70.7	66.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	22.2	19.5	19.2	16.8	14.7	12.6	12.4	13.0	14.9	17.0	18.1	20.8	(35)
(36)			MCDBR	26.3	25.0	28.4	26.3	19.9	15.6	17.0	21.1	26.2	25.9	23.1	24.0	(36)
(37)			MCWBR	14.7	12.2	12.2	11.6	9.1	7.3	7.3	8.1	9.4	11.0	11.3	12.5	(37)
(38)		5% WB	MCDBR	21.9	20.2	21.7	18.5	16.2	13.5	13.1	16.8	17.6	17.0	16.6	18.9	(38)
(39)			MCWBR	15.0	12.3	12.2	10.3	8.7	7.0	6.3	7.1	8.3	9.0	10.1	12.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.323	0.369	0.426	0.425	0.449	0.491	0.582	0.563	0.472	0.430	0.376	0.349	(40)	
(41)		taud	2.509	2.348	2.153	2.193	2.140	2.030	1.801	1.868	2.110	2.220	2.369	2.442	(41)	
(42)		Ebn at Noon	289	282	272	276	269	256	233	236	255	258	266	272	(42)	
(43)		Edh at Noon	28	36	47	47	49	55	69	64	48	41	32	29	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1203	1473	1870	2167	2359	2410	2375	2169	1874	1498	1221	1069	(44)	
(45)		RadStd	66	114	75	85	115	51	60	54	87	66	71	79	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		+0.43	N/A	N/A	N/A	-0.58	N/A	N/A	N/A	+275	+308

Nomenclature: See separate page