

MELILLA, Spain

WMO: 603380

Lat: 35.280N

Lon: 2.956W

Elev: 156

StdP: 14.61

Time Zone: 1.00 (EUC)

Period: 82-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	45.9	47.7	32.7	27.4	54.5	35.7	30.9	55.8	28.9	53.3	25.1	56.0	4.6	250	0.381

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.8	90.1	68.3	87.4	69.2	84.6	70.5	76.7	82.3	75.7	81.1	74.9	80.2	9.5	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.0	131.8	80.3	73.9	126.9	79.4	73.1	123.8	79.0	40.2	82.4	39.2	81.2	38.4	80.3	81.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
23.6	20.5	18.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	66.6	56.6	57.5	60.0	62.3	66.9	72.3	77.8	79.1	74.7	69.2	63.0	58.7
	DBStd	8.42	3.45	3.58	3.42	3.01	3.48	3.34	3.38	3.31	3.40	3.59	3.50	3.61
	HDD50	4	1	2	1	0	0	0	0	0	0	0	0	0
	HDD65	1032	261	211	161	93	19	1	0	0	9	79	198	
	CDD50	6049	205	211	310	368	524	668	863	903	742	595	390	270
	CDD65	1603	1	0	5	11	78	219	398	438	292	139	18	4
	CDH74	10038	3	0	26	32	196	872	3184	3850	1542	303	19	11
	CDH80	2397	0	0	1	1	18	132	904	1091	222	25	0	3
Wind	WSAvg	7.9	7.4	8.6	8.9	8.8	8.6	8.4	7.7	7.8	7.2	6.6	7.3	7.4
Precipitation	PrecAvg	15.1	2.3	1.9	1.7	1.4	0.8	0.3	0.0	0.1	0.7	1.6	2.2	2.0
	PrecMax	30.0	6.6	4.6	6.5	7.3	2.4	4.2	0.3	1.0	5.2	10.3	7.4	6.3
	PrecMin	8.5	0.0	0.1	0.1	0.2	0.1	0.0	0.0	0.0	0.0	0.1	0.0	0.0
	PrecStd	4.7	1.8	1.3	1.6	1.5	0.7	0.9	0.1	0.2	1.0	2.0	1.8	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	71.4	71.7	77.8	78.2	82.5	88.0	98.6	94.6	88.1	82.6	76.2	74.3
		MCWB	57.4	59.2	59.3	62.6	63.6	70.4	66.2	67.8	69.4	66.4	61.5	59.8
	2%	DB	66.7	68.1	71.6	73.5	78.8	82.8	90.1	91.0	84.6	79.2	73.4	69.6
		MCWB	56.9	58.3	58.4	60.5	63.5	68.4	67.8	68.8	69.5	67.4	61.6	58.8
	5%	DB	64.4	65.6	68.5	70.7	75.9	80.5	87.1	87.9	82.6	77.2	71.2	66.4
		MCWB	55.5	57.1	58.5	59.9	63.3	68.2	68.5	69.9	70.3	68.0	62.1	58.4
	10%	DB	62.3	63.5	66.2	68.4	73.8	78.4	84.3	85.2	80.6	75.4	69.2	64.2
		MCWB	54.9	56.4	58.1	59.2	62.8	67.7	70.1	71.2	70.0	67.3	60.8	57.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	62.2	62.4	63.3	65.9	68.0	74.5	76.4	78.2	76.4	72.0	66.8	63.4
		MCDB	68.2	67.8	69.6	73.8	74.7	80.0	83.5	85.0	81.0	76.2	72.0	69.8
	2%	WB	59.1	59.9	61.4	63.6	66.4	72.4	75.3	77.2	75.4	70.7	65.0	61.1
		MCDB	64.1	65.3	67.5	69.8	73.6	78.2	81.7	83.2	79.6	75.5	70.0	65.9
	5%	WB	57.2	58.4	60.1	62.0	65.3	71.0	74.6	76.5	74.5	69.7	63.4	59.8
		MCDB	62.3	63.7	65.8	67.9	72.5	77.1	80.8	82.1	78.9	74.7	68.2	64.4
	10%	WB	56.0	57.2	59.0	60.6	64.3	69.7	73.8	75.6	73.4	68.7	62.1	58.6
		MCDB	60.7	62.3	64.2	65.7	71.3	76.0	79.8	80.9	78.2	73.5	66.8	63.4
Mean Daily Temperature Range	5% DB	MDBR	11.8	11.3	11.2	11.9	11.6	11.4	11.9	10.8	10.9	11.2	11.6	10.6
		MCDBR	14.3	14.4	16.2	16.2	15.6	14.3	16.0	15.1	13.7	13.5	14.2	13.5
		MCWBR	9.0	9.2	9.5	9.3	8.2	7.6	8.7	9.6	7.2	7.6	8.2	8.0
	5% WB	MCDBR	12.3	12.4	13.2	13.6	13.2	11.6	11.6	11.3	10.0	11.4	11.7	11.2
	MCWBR	8.4	8.7	8.7	9.1	7.7	7.6	6.4	6.9	6.0	7.2	7.5	7.2	
Clear-Sky Solar Irradiance	taub	0.327	0.355	0.409	0.417	0.446	0.480	0.516	0.504	0.462	0.415	0.365	0.334	
	taud	2.515	2.438	2.265	2.268	2.210	2.116	2.016	2.062	2.194	2.319	2.448	2.514	
	Ebn at Noon	278	281	272	276	268	258	247	248	252	255	260	267	
	Edh at Noon	26	31	41	43	46	50	55	52	43	35	28	25	
All-Sky Solar Radiation	RadAvg	882	1153	1518	1847	2123	2353	2301	2050	1667	1261	927	799	
	RadStd	70	100	132	136	172	75	62	81	73	78	69	58	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (6 neighbors)		+0.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page