

JIJEL FERHAT ABBAS, Algeria

WMO: 603510

Lat: 36.795N

Lon: 5.874E

Elev: 36

StdP: 14.68

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	40.7	42.6	34.0	28.7	49.3	36.1	31.2	48.8	27.6	55.6	24.5	54.9	2.8	160	0.373

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	17.1	94.9	73.1	91.2	73.5	88.2	73.8	78.9	86.6	77.7	85.4	76.5	84.2	9.0	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.8	140.0	83.8	75.4	133.1	82.5	74.0	126.8	81.7	42.3	86.9	41.1	85.5	40.0	84.4	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
22.4	19.1	16.6	DB	38.4	103.1	1.8	5.0	37.1	106.7	36.0	109.7	35.0	112.5	33.7	116.1
			WB	36.5	81.3	1.8	1.4	35.2	82.3	34.2	83.1	33.2	83.9	31.9	84.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	65.4	53.4	53.3	57.2	61.0	65.9	73.1	78.3	79.3	75.2	70.2	61.3	55.8	(6)
	DBStd	10.24	3.68	4.58	4.80	4.31	4.57	4.91	4.02	3.96	4.13	4.97	5.14	4.01	(7)
	HDD50	33	11	15	3	0	0	0	0	0	0	0	1	3	(8)
	HDD65	1538	359	329	247	135	39	1	0	0	0	8	132	288	(9)
	CDD50	5654	117	107	227	329	494	693	876	907	755	626	341	182	(10)
	CDD65	1685	0	2	6	14	68	244	411	442	305	169	22	2	(11)
	CDH74	15243	1	14	58	98	421	1942	4234	4690	2533	1140	106	6	(12)
	CDH80	5260	0	1	15	20	102	588	1587	1900	713	324	10	0	(13)
(14) Wind	WSAvg	5.3	5.9	6.5	5.9	5.4	5.1	5.1	5.3	5.2	4.7	4.3	5.3	5.6	(14)
(15) Precipitation	PrecAvg	38.4	5.2	4.4	3.6	3.0	2.0	0.5	0.1	0.6	2.4	3.8	5.9	7.0	(15)
	PrecMax	53.5	13.1	14.8	10.0	7.4	6.1	2.1	0.8	4.0	7.3	11.7	13.5	15.5	(16)
	PrecMin	23.5	0.5	0.0	0.3	0.0	0.2	0.0	0.0	0.0	0.1	0.1	0.3	0.1	(17)
	PrecStd	7.1	2.8	3.4	2.4	1.9	1.6	0.6	0.2	0.9	1.5	2.6	3.1	3.8	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.2	75.6	80.6	81.5	89.4	97.0	100.4	100.4	94.3	93.1	80.9	73.9	(19)
		MCWB	58.4	59.7	61.5	63.7	71.9	71.7	74.8	74.8	73.1	69.2	62.6	60.5	(20)
	2%	DB	66.4	68.3	73.6	75.8	82.1	90.7	93.1	94.7	89.2	87.5	77.0	69.6	(21)
		MCWB	56.9	57.6	60.0	63.3	68.0	72.3	73.5	74.4	73.4	68.8	62.2	58.3	(22)
	5%	DB	64.0	64.7	69.8	73.0	78.4	85.9	89.5	91.0	86.1	83.0	73.5	66.4	(23)
		MCWB	56.1	56.4	59.2	62.3	67.0	71.6	74.5	74.5	73.3	69.3	62.2	57.3	(24)
	10%	DB	61.3	62.4	66.8	70.0	75.3	82.6	86.9	88.0	84.0	79.8	70.7	64.2	(25)
		MCWB	54.6	55.4	58.3	61.4	65.9	71.2	74.2	75.6	73.3	68.9	61.6	56.6	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.5	61.9	64.8	67.6	72.9	77.2	80.5	80.6	79.1	75.2	68.4	62.3	(27)
		MCDB	67.0	69.2	76.1	76.7	85.3	86.3	88.6	88.0	86.1	82.7	74.4	70.2	(28)
	2%	WB	58.4	59.3	62.0	65.3	70.0	75.2	78.8	79.1	77.3	73.2	65.8	60.0	(29)
		MCDB	64.8	66.0	70.2	73.0	78.0	84.0	86.2	87.0	84.0	80.3	72.2	66.5	(30)
	5%	WB	56.9	57.4	60.3	63.6	68.4	73.7	77.4	78.0	75.9	71.7	64.0	58.6	(31)
		MCDB	62.5	63.6	67.4	70.4	75.6	82.2	84.9	85.9	82.7	78.6	70.4	64.5	(32)
	10%	WB	55.3	55.8	59.0	62.2	67.0	72.4	76.1	76.9	74.5	70.1	62.5	57.4	(33)
		MCDB	60.8	61.5	65.5	68.2	73.6	80.4	83.8	84.6	81.4	77.6	68.6	62.9	(34)
(35) Mean Daily Temperature Range	MDBR		15.1	15.4	16.1	16.2	16.0	17.0	16.8	17.1	16.1	16.8	15.0	14.9	(35)
	5% DB	MCDBR	19.8	20.2	21.9	21.5	21.5	22.7	21.7	21.9	18.9	21.9	19.3	19.0	(36)
		MCWBR	13.3	12.4	12.2	12.0	11.0	10.4	10.8	11.1	10.0	11.3	11.1	11.9	(37)
	5% WB	MCDBR	18.3	18.5	19.2	18.4	18.4	18.9	17.2	17.7	16.3	18.6	17.1	16.8	(38)
		MCWBR	12.9	12.4	11.9	11.4	10.6	9.9	10.0	10.6	9.6	11.3	11.2	11.3	(39)
(40) Clear-Sky Solar Irradiance	taub		0.346	0.365	0.421	0.458	0.488	0.480	0.526	0.502	0.479	0.431	0.386	0.352	(40)
	taud		2.457	2.396	2.215	2.134	2.083	2.134	2.009	2.078	2.151	2.258	2.352	2.445	(41)
	Ebn at Noon		266	274	266	263	256	257	244	247	246	247	247	255	(42)
	Edh at Noon		27	32	42	48	52	49	55	50	44	36	30	26	(43)
(44) All-Sky Solar Radiation	RadAvg		737	981	1387	1728	2023	2338	2352	2075	1586	1191	803	665	(44)
	RadStd		80	105	124	135	141	77	63	66	80	75	58	68	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page