

SKIKDA, Algeria

WMO: 603550

Lat: 36.885N

Lon: 6.902E

Elev: 23

StdP: 14.68

Time Zone: 1.00 (E01)

Period: 94-14

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	43.3	45.4	34.2	28.9	53.5	36.3	31.5	52.7	26.3	54.6	23.1	54.0	10.5	180	0.373

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.9	90.8	73.6	87.3	74.4	85.1	74.4	79.1	84.8	77.9	83.8	76.7	82.8	6.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.3	142.2	83.6	76.0	135.9	82.6	74.7	130.1	81.7	42.5	85.0	41.3	83.8	40.2	82.8	85.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.8	18.0	15.5	40.0	101.3	3.1	4.8	37.8	104.7	36.0	107.5	34.2	110.2	32.0	113.6
			37.8	80.3	2.6	1.7	35.9	81.5	34.4	82.5	32.9	83.4	31.0	84.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.1	55.4	55.1	58.1	61.5	67.0	73.1	77.7	79.6	74.9	70.2	62.6	57.0
	DBStd	9.58	4.30	4.36	4.90	4.42	4.32	4.37	3.56	3.68	4.19	4.69	4.96	4.34
	HDD50	19	7	8	2	0	0	0	0	0	0	0	0	2
	HDD65	1305	299	278	222	122	23	1	0	0	0	8	102	250
	CDD50	5891	174	151	253	346	528	692	858	917	747	626	379	220
	CDD65	1702	1	1	9	18	86	243	393	452	297	169	30	3
	CDH74	12120	4	4	46	82	230	1199	3236	4524	1980	713	91	11
	CDH80	2759	0	0	13	20	51	230	684	1287	340	124	9	1
(14) Wind	WSAvg	7.4	8.5	7.8	7.4	7.3	6.6	6.7	6.8	6.5	6.7	7.0	8.1	8.7
(15) Precipitation	PrecAvg	28.5	4.4	3.7	3.2	2.2	1.3	0.4	0.1	0.4	1.5	3.0	4.1	5.0
	PrecMax	45.2	10.9	9.7	8.7	7.2	5.2	1.7	0.5	2.5	3.9	7.5	9.6	13.7
	PrecMin	19.4	0.8	0.5	0.0	0.1	0.1	0.0	0.0	0.0	0.0	0.1	0.2	0.0
	PrecStd	6.6	2.4	2.0	1.9	1.6	1.1	0.4	0.2	0.6	0.9	2.0	2.5	3.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.1	72.2	79.7	82.8	85.6	91.0	93.3	96.0	91.0	91.2	81.4	73.8
		MCWB	58.7	58.4	59.8	64.0	67.9	73.2	72.7	73.2	71.1	69.5	60.3	58.6
	2%	DB	67.1	67.4	72.3	75.0	79.3	85.6	87.9	91.5	85.6	82.4	76.3	69.4
		MCWB	55.9	56.6	58.6	62.2	66.8	71.5	74.0	75.5	73.4	67.8	62.0	57.8
	5%	DB	64.3	64.6	68.7	71.0	75.7	82.2	85.2	87.9	83.1	79.6	72.9	66.4
		MCWB	55.1	55.4	58.2	61.3	66.7	71.1	75.1	75.9	73.8	68.9	62.3	57.1
	10%	DB	62.0	62.1	65.9	68.2	73.4	79.6	83.5	85.7	81.5	77.5	70.3	64.2
		MCWB	54.1	54.7	57.7	60.3	65.8	70.9	74.7	75.8	73.1	68.7	61.2	56.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.1	60.1	63.5	67.0	71.5	77.4	80.8	80.9	78.6	74.6	68.3	62.0
		MCDB	67.7	67.9	74.5	74.5	80.0	83.9	85.7	86.9	83.3	79.7	73.6	68.8
	2%	WB	58.3	58.2	61.1	64.3	69.6	75.1	78.5	79.6	76.9	72.7	66.1	60.2
		MCDB	64.3	64.6	68.2	71.7	75.6	81.7	84.1	85.5	81.9	78.2	71.7	66.1
	5%	WB	56.6	56.8	59.7	62.8	68.0	73.3	77.1	78.4	75.5	71.1	64.0	58.8
		MCDB	62.0	63.2	66.3	68.9	74.0	79.3	83.0	84.4	81.0	77.2	70.1	64.3
	10%	WB	55.3	55.4	58.4	61.4	66.7	72.0	75.8	77.4	74.1	69.7	62.4	57.4
		MCDB	60.5	61.3	64.7	67.0	72.2	77.9	81.7	83.6	80.1	76.3	68.7	62.9
(35) Mean Daily Temperature Range	5% DB	MDBR	11.3	11.6	11.5	11.4	10.3	9.6	9.3	9.9	10.5	11.8	11.2	11.6
		MCDBR	15.2	16.0	16.6	16.4	13.8	13.8	11.9	13.4	12.2	15.2	15.0	15.5
		MCWBR	9.2	9.2	9.2	9.1	8.2	9.6	9.6	11.0	8.7	9.5	8.7	8.8
	5% WB	MCDBR	12.9	14.1	14.3	13.5	11.2	11.0	9.7	10.6	10.4	12.2	12.8	13.0
		MCWBR	9.2	9.5	9.0	8.6	7.9	9.0	9.2	10.2	9.0	9.3	8.7	8.7
(40) Clear-Sky Solar Irradiance	taub		0.348	0.367	0.421	0.459	0.484	0.468	0.507	0.490	0.473	0.430	0.386	0.354
	taud		2.449	2.390	2.217	2.135	2.096	2.173	2.068	2.118	2.173	2.265	2.354	2.436
	Ebn at Noon		265	273	266	262	257	260	249	251	247	247	247	253
	Edh at Noon		27	32	42	48	51	47	52	49	43	36	30	26
(44) All-Sky Solar Radiation	RadAvg		726	982	1392	1736	2042	2359	2367	2082	1579	1190	801	657
	RadStd		79	98	116	130	133	70	66	79	78	74	57	62

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page