

SKIKDA, Algeria

WMO: 603550

Lat: 36.885N

Lon: 6.902E

Elev: 7

StdP: 101.24

Time Zone: 1.00 (E01)

Period: 94-14

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.3	7.4	1.2	4.1	12.0	2.4	4.5	11.5	11.8	12.6	10.3	12.2	4.7	180	0.373

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.5	32.7	23.1	30.7	23.6	29.5	23.5	26.2	29.3	25.5	28.8	24.9	28.2	2.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.2	20.3	28.7	24.4	19.4	28.1	23.7	18.6	27.6	81.1	29.4	78.2	28.8	75.6	28.2	29.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.7	8.0	6.9	4.5	38.5	1.7	2.6	3.2	40.4	2.2	41.9	1.2	43.4	0.0	45.3		
(5)			3.2	26.8	1.5	0.9	2.2	27.5	1.3	28.0	0.5	28.6	-0.5	29.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.9	13.0	12.8	14.5	16.4	19.5	22.8	25.4	26.4	23.8	21.2	17.0	13.9
	DBStd	5.32	2.39	2.42	2.72	2.46	2.40	2.43	1.98	2.04	2.33	2.61	2.75	2.41
	HDD10.0	11	4	4	1	0	0	0	0	0	0	0	0	1
	HDD18.3	725	166	154	123	68	13	1	0	0	0	4	57	139
	CDD10.0	3273	97	84	141	192	293	384	477	509	415	348	211	122
	CDD18.3	946	1	1	5	10	48	135	218	251	165	94	17	2
	CDH23.3	6733	2	2	26	46	128	666	1798	2513	1100	396	51	6
	CDH26.7	1533	0	0	7	11	28	128	380	715	189	69	5	1
Wind	WSAvg	3.3	3.8	3.5	3.3	3.3	3.0	3.0	3.0	2.9	3.0	3.1	3.6	3.9
Precipitation	PrecAvg	725	113	94	81	55	32	11	2	11	37	76	105	127
	PrecMax	1149	276	246	220	183	132	43	13	64	100	190	243	348
	PrecMin	492	21	13	0	3	2	0	0	0	0	2	6	0
	PrecStd	168	62	50	48	40	28	11	4	16	24	51	64	87
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.3	22.3	26.5	28.2	29.8	32.8	34.0	35.6	32.8	32.9	27.4	23.2
		MCWB	14.9	14.7	15.4	17.8	19.9	22.9	22.6	22.9	21.7	20.9	15.7	14.8
	2%	DB	19.5	19.7	22.4	23.9	26.3	29.8	31.1	33.1	29.8	28.0	24.6	20.8
		MCWB	13.3	13.7	14.8	16.8	19.3	21.9	23.3	24.1	23.0	19.9	16.6	14.3
	5%	DB	17.9	18.1	20.4	21.7	24.3	27.9	29.6	31.0	28.4	26.4	22.7	19.1
		MCWB	12.9	13.0	14.6	16.3	19.3	21.7	23.9	24.4	23.2	20.5	16.9	13.9
	10%	DB	16.7	16.7	18.8	20.1	23.0	26.5	28.6	29.8	27.5	25.3	21.3	17.9
		MCWB	12.3	12.6	14.3	15.7	18.8	21.6	23.7	24.3	22.8	20.4	16.2	13.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.1	15.6	17.5	19.4	22.0	25.2	27.1	27.1	25.9	23.6	20.2	16.7
		MCDB	19.8	19.9	23.6	23.6	26.7	28.8	29.8	30.5	28.5	26.5	23.1	20.4
	2%	WB	14.6	14.5	16.1	17.9	20.9	24.0	25.8	26.4	24.9	22.6	18.9	15.6
		MCDB	17.9	18.1	20.1	22.0	24.2	27.6	28.9	29.7	27.7	25.7	22.0	18.9
	5%	WB	13.7	13.8	15.4	17.1	20.0	22.9	25.1	25.8	24.2	21.7	17.8	14.9
		MCDB	16.7	17.3	19.1	20.5	23.3	26.3	28.4	29.1	27.2	25.1	21.2	18.0
	10%	WB	12.9	13.0	14.7	16.3	19.3	22.2	24.3	25.2	23.4	20.9	16.9	14.1
		MCDB	15.8	16.3	18.2	19.4	22.4	25.5	27.6	28.7	26.7	24.6	20.4	17.2
Mean Daily Temperature Range	5% DB	MDBR	6.3	6.4	6.4	6.3	5.7	5.3	5.2	5.5	5.8	6.5	6.2	6.4
		MCDBR	8.5	8.9	9.2	9.1	7.7	7.7	6.6	7.5	6.8	8.5	8.3	8.6
		MCWBR	5.1	5.1	5.1	5.1	4.6	5.3	5.3	6.1	4.9	5.3	4.8	4.9
	5% WB	MCDBR	7.2	7.8	7.9	7.5	6.2	6.1	5.4	5.9	5.8	6.8	7.1	7.2
		MCWBR	5.1	5.3	5.0	4.8	4.4	5.0	5.1	5.7	5.0	5.2	4.8	4.8
Clear-Sky Solar Irradiance	taub	0.348	0.367	0.421	0.459	0.484	0.468	0.507	0.490	0.473	0.430	0.386	0.354	
	taud	2.449	2.390	2.217	2.135	2.096	2.173	2.068	2.118	2.173	2.265	2.354	2.436	
	Ebn at Noon	835	862	840	827	810	821	785	790	780	779	778	799	
	Edh at Noon	86	102	133	152	160	148	164	153	137	115	94	82	
All-Sky Solar Radiation	RadAvg	2.29	3.10	4.39	5.47	6.44	7.44	7.46	6.56	4.98	3.75	2.52	2.07	
	RadStd	0.25	0.31	0.37	0.41	0.42	0.22	0.21	0.25	0.24	0.23	0.18	0.20	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page