

ANNABA, Algeria

WMO: 603600

Lat: 36.8220N

Lon: 7.8036E

Elev: 5

StdP: 101.27

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.1	5.1	0.9	4.0	9.7	2.2	4.4	9.5	13.4	12.6	11.5	11.9	3.4	220	0.449

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.2	35.1	22.8	32.9	22.9	31.1	23.2	26.2	29.8	25.4	29.2	24.7	28.7	5.2	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.1	20.2	28.4	24.1	19.1	27.7	23.4	18.2	27.3	81.2	30.1	77.6	29.3	74.8	28.7	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 10.3	9.2	8.2	DB	1.6	41.6	1.3	1.9	0.7	43.0	0.0	44.1	-0.7	45.2	-1.6	46.6	(4)
(5)			WB	1.1	27.4	1.2	1.1	0.3	28.1	-0.4	28.8	-1.1	29.3	-2.0	30.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	18.2	11.8	11.7	13.5	15.6	18.7	22.4	25.1	25.9	23.6	20.7	16.1	13.0	(6)
(7)		DBStd	5.61	2.22	2.48	2.53	2.41	2.52	2.56	2.13	2.29	2.49	2.68	2.72	2.36	(7)
(8)		HDD10.0	24	8	10	2	0	0	0	0	0	0	0	1	4	(8)
(9)		HDD18.3	904	203	187	151	88	24	1	0	0	0	7	76	168	(9)
(10)		CDD10.0	3025	63	57	112	168	271	371	469	494	409	332	184	95	(10)
(11)		CDD18.3	863	0	1	2	6	36	122	211	236	159	81	10	1	(11)
(12)		CDH23.3	7597	1	4	29	61	237	955	2106	2434	1215	484	66	6	(12)
(13)	CDH26.7	2593	0	0	7	17	65	279	779	955	346	133	12	1	(13)	
(14)	Wind	WSAvg	3.7	3.8	3.9	3.7	3.7	3.6	3.8	3.9	3.8	3.6	3.3	3.6	3.6	(14)
(15)	Precipitation	PrecAvg	635	93	78	68	51	34	13	3	9	35	67	83	98	(15)
(16)		PrecMax	1127	227	187	224	176	90	52	18	66	90	271	237	231	(16)
(17)		PrecMin	410	14	12	5	1	0	0	0	0	2	4	4	8	(17)
(18)		PrecStd	145	53	43	44	36	21	13	4	13	24	52	58	58	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.1	23.1	26.8	29.1	33.0	36.1	38.2	38.6	35.8	34.2	28.1	23.9	(19)
(20)			MCWB	14.3	14.7	17.3	17.5	20.8	22.0	23.4	22.2	21.7	19.2	16.7	15.2	(20)
(21)		2%	DB	19.3	20.1	22.9	24.7	27.8	31.9	34.1	34.9	32.0	30.0	25.1	20.9	(21)
(22)			MCWB	13.6	13.9	15.9	17.5	19.6	22.3	23.0	23.6	22.4	20.1	16.5	14.4	(22)
(23)		5%	DB	17.6	18.1	20.4	22.1	25.4	29.6	31.9	32.6	29.9	27.3	22.9	19.0	(23)
(24)			MCWB	12.9	13.2	15.0	16.4	19.1	21.7	23.3	24.0	22.8	20.4	16.5	13.8	(24)
(25)		10%	DB	16.1	16.2	18.7	20.8	24.0	27.9	30.1	30.9	28.2	25.9	21.1	17.5	(25)
(26)			MCWB	12.3	12.5	14.2	16.0	18.5	21.4	23.5	24.3	22.5	20.4	16.3	13.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.7	16.2	18.2	20.0	22.4	25.3	26.9	27.7	26.2	24.3	20.6	16.6	(27)
(28)			MCDWB	19.3	20.4	24.0	26.2	28.8	30.0	30.2	30.5	29.2	26.8	23.2	20.8	(28)
(29)		2%	WB	14.4	14.7	16.6	18.3	20.9	23.9	25.9	26.4	25.1	22.8	18.9	15.4	(29)
(30)			MCDWB	17.8	18.7	20.9	22.6	25.3	28.5	29.7	29.9	28.4	25.7	22.0	19.0	(30)
(31)		5%	WB	13.5	13.7	15.6	17.4	19.9	23.0	25.1	25.6	24.3	21.8	17.7	14.6	(31)
(32)			MCDWB	16.7	17.1	19.3	21.1	24.0	27.3	29.1	29.4	27.7	25.1	21.1	17.9	(32)
(33)		10%	WB	12.7	12.8	14.7	16.5	19.2	22.2	24.4	25.0	23.5	20.8	16.7	13.8	(33)
(34)			MCDWB	15.7	16.0	18.1	19.8	23.2	26.5	28.6	29.0	27.0	24.5	19.9	17.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.7	9.2	9.8	10.1	10.4	10.4	10.5	10.2	9.7	10.3	9.4	8.9	(35)
(36)			MCDBR	11.4	12.3	13.5	13.3	13.4	13.5	13.7	13.1	11.9	13.4	12.6	11.7	(36)
(37)			MCWBR	7.0	7.3	7.8	7.6	6.7	6.1	6.1	6.2	5.7	6.5	6.8	6.9	(37)
(38)		5% WB	MCDWR	10.2	11.0	11.9	11.6	11.6	11.3	11.0	10.8	10.2	11.3	10.7	10.0	(38)
(39)			MCWBR	6.9	7.2	7.6	7.4	6.7	6.1	6.0	6.1	5.9	6.6	6.8	6.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.347	0.366	0.418	0.457	0.480	0.459	0.491	0.479	0.465	0.426	0.383	0.354	(40)	
(41)		taud	2.452	2.393	2.230	2.141	2.107	2.205	2.116	2.150	2.201	2.274	2.365	2.435	(41)	
(42)		Ebn at Noon	837	864	844	829	813	829	798	800	788	783	782	800	(42)	
(43)		Edh at Noon	86	102	131	151	159	144	156	148	134	113	93	82	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.28	3.08	4.36	5.45	6.44	7.47	7.51	6.59	4.96	3.75	2.55	2.06	(44)	
(45)		RadStd	0.24	0.28	0.36	0.41	0.41	0.23	0.21	0.28	0.24	0.24	0.18	0.19	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	+0.75	N/A	+0.41	+0.47	N/A	N/A	N/A	N/A
(47)	Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page