

DAR EL BEIDA, Algeria

WMO: 603900

Lat: 36.6897N

Lon: 3.2166E

Elev: 25

StdP: 101.03

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 1.9	(c) 3.0	(d) 0.1	(e) 3.8	(f) 5.7	(g) 1.2	(h) 4.1	(i) 6.5	(j) 12.2	(k) 13.8	(l) 10.5	(m) 14.2	(n) 0.8	(o) 240	(p) 0.415

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 11.5	(c) 35.5	(d) 22.4	(e) 33.8	(f) 22.5	(g) 32.1	(h) 22.6	(i) 25.7	(j) 30.7	(k) 25.0	(l) 30.0	(m) 24.4	(n) 29.2	(o) 4.4	(p) 0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.2	19.2	28.1	23.6	18.5	27.8	22.9	17.7	27.3	79.1	30.8	76.1	30.1	73.5	29.1	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 10.4	(b) 8.9	(c) 7.7	(e) -0.1	(f) 40.4	(g) 0.8	(h) 2.5	(i) -0.7	(j) 42.2	(k) -1.2	(l) 43.6	(m) -1.7	(n) 45.0	(o) -2.3	(p) 46.8		
(a) 10.4	(b) 8.9	(c) 7.7	(e) -0.5	(f) 26.9	(g) 0.8	(h) 1.1	(i) -1.1	(j) 27.7	(k) -1.6	(l) 28.4	(m) -2.0	(n) 29.0	(o) -2.7	(p) 29.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.2	11.4	11.5	13.6	15.6	18.8	22.7	25.8	26.6	23.7	20.5	15.5	12.4
	DBStd	5.95	2.37	2.72	2.77	2.35	2.74	2.60	2.17	2.24	2.50	2.96	2.92	2.40
	HDD10.0	32	12	12	3	0	0	0	0	0	0	0	1	4
	HDD18.3	964	217	192	151	88	26	1	0	0	0	11	95	184
	CDD10.0	3029	54	54	113	167	273	382	489	513	412	326	165	80
	CDD18.3	919	1	1	3	5	41	133	231	255	162	78	9	1
	CDH23.3	9228	2	7	42	74	381	1257	2510	2814	1432	636	69	5
	CDH26.7	3665	0	1	10	9	99	435	1130	1301	481	189	10	0
Wind	WSAvg	2.7	2.6	2.7	2.7	2.9	2.9	3.1	3.0	2.9	2.7	2.3	2.5	2.4
Precipitation	PrecAvg	688	84	77	68	61	42	13	3	5	30	63	99	105
	PrecMax	1169	255	346	220	195	151	71	23	33	158	253	250	250
	PrecMin	333	4	0	0	0	0	0	0	0	0	0	10	0
	PrecStd	155	53	60	45	44	40	16	5	8	33	51	58	64
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.2	24.0	27.8	28.0	33.1	36.0	38.0	38.8	35.4	34.8	28.0	23.8
		MCWB	14.3	15.2	16.8	18.2	20.2	21.1	22.4	22.9	21.8	20.2	17.9	16.0
	2%	DB	20.0	21.0	23.8	25.2	29.1	32.9	34.9	35.5	32.2	30.9	25.2	21.1
		MCWB	13.4	14.1	15.6	16.8	19.3	21.4	22.7	22.9	22.2	20.1	16.5	14.6
	5%	DB	18.2	19.2	21.8	23.6	26.9	30.8	33.0	33.8	30.8	28.5	23.1	19.3
		MCWB	13.0	13.5	15.0	16.4	18.8	21.3	22.6	23.2	22.1	19.7	16.3	13.9
	10%	DB	16.9	17.8	20.0	22.0	25.1	29.0	31.8	32.1	29.2	26.8	21.5	18.0
		MCWB	12.7	12.9	14.3	15.8	18.4	20.9	22.8	23.3	21.8	19.6	15.8	13.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.7	16.4	18.2	19.5	22.0	24.6	26.4	26.9	25.4	23.4	19.5	16.7
		MCDB	20.0	21.6	24.9	25.1	28.8	30.3	31.6	32.2	30.4	27.9	24.1	21.7
	2%	WB	14.7	15.1	16.6	18.1	20.7	23.4	25.4	26.0	24.3	22.1	18.3	15.5
		MCDB	18.6	19.4	22.1	23.2	26.4	29.1	30.8	30.8	29.0	26.9	22.6	19.5
	5%	WB	13.8	14.1	15.6	17.2	19.8	22.6	24.7	25.3	23.6	21.2	17.4	14.7
		MCDB	17.3	18.0	20.2	21.9	25.1	28.0	30.0	30.1	28.1	25.7	21.4	18.3
	10%	WB	12.9	13.4	14.8	16.4	19.1	21.9	24.1	24.7	22.9	20.4	16.4	13.9
		MCDB	16.1	16.9	19.0	20.6	23.9	26.9	29.2	29.4	27.1	25.1	20.3	17.2
Mean Daily Temperature Range	5% DB	MDBR	10.8	11.3	11.9	11.9	11.8	12.0	11.9	11.5	11.1	11.8	10.6	10.7
		MCDBR	13.5	14.3	15.5	15.5	15.1	14.9	14.5	13.9	12.7	14.7	13.4	13.6
		MCWBR	8.6	8.8	8.7	8.4	7.0	6.2	5.9	5.6	5.6	6.5	7.2	8.3
	5% WB	MCDBR	12.2	12.8	13.6	13.0	12.6	12.0	11.1	11.0	10.3	11.8	11.7	11.9
		MCWBR	8.2	8.4	8.2	7.6	6.4	5.7	5.4	5.3	5.2	6.0	7.0	7.9
Clear-Sky Solar Irradiance	taub	0.337	0.357	0.414	0.440	0.473	0.481	0.528	0.502	0.471	0.423	0.379	0.343	
	taud	2.484	2.422	2.238	2.184	2.123	2.117	1.990	2.067	2.164	2.287	2.379	2.479	
	Ebn at Noon	852	875	848	844	820	810	769	780	782	788	789	817	
	Edh at Noon	83	99	130	145	156	157	177	161	139	112	92	79	
All-Sky Solar Radiation	RadAvg	2.43	3.21	4.46	5.52	6.38	7.50	7.45	6.62	5.13	3.87	2.61	2.19	
	RadStd	0.26	0.35	0.37	0.45	0.55	0.29	0.18	0.24	0.27	0.26	0.22	0.18	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page