

BEJAIA SOUMMAM ABANE RAMDANE, AlgeriaWMO: **604020**Lat: **36.712N**Lon: **5.070E**Elev: **6**StdP: **101.25**Time Zone: **1.00 (E01)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.8	5.8	1.1	4.1	10.2	2.1	4.4	9.5	10.6	14.4	9.8	13.6	4.0	240	0.392

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.4	32.8	23.2	31.0	24.1	29.9	24.2	26.5	29.8	25.7	29.2	25.1	28.6	4.1	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.2	20.4	28.9	24.7	19.8	28.5	24.0	18.9	27.9	82.3	29.9	79.1	29.3	76.3	28.6	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.8	7.5	6.6	2.2	39.0	2.1	2.8	0.7	41.0	-0.5	42.7	-1.7	44.2	-3.2	46.3		
(5)			1.7	27.5	1.9	0.9	0.3	28.1	-0.8	28.6	-1.8	29.1	-3.2	29.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.4	12.1	12.1	13.9	15.8	18.6	22.2	25.1	26.0	23.6	20.9	16.3	13.3
	DBStd	5.49	2.53	2.78	2.69	2.35	2.42	2.35	2.06	2.10	2.32	2.78	2.94	2.55
	HDD10.0	23	8	9	2	0	0	0	0	0	0	0	1	3
	HDD18.3	848	193	175	139	82	23	1	0	0	0	6	73	157
	CDD10.0	3084	73	68	124	175	268	367	469	496	409	338	191	107
	CDD18.3	870	1	1	3	7	32	118	211	237	159	86	13	2
	CDH23.3	6753	2	7	22	32	117	703	1919	2312	1146	432	55	6
	CDH26.7	1878	0	1	6	8	27	128	557	793	259	92	8	1
Wind	WSAvg	3.1	3.5	3.4	3.1	3.0	2.7	2.8	2.8	2.8	2.8	3.0	3.3	3.7
Precipitation	PrecAvg	737	106	87	62	64	47	17	5	12	52	80	99	115
	PrecMax	1022	278	279	163	185	142	58	66	70	179	191	196	266
	PrecMin	386	12	9	10	9	3	3	0	0	8	14	27	11
	PrecStd	149	60	59	39	39	32	15	12	16	36	51	51	68
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.2	24.0	26.2	26.9	30.0	32.9	35.4	36.5	33.1	33.1	27.8	23.5
		MCWB	14.4	15.2	16.3	16.7	20.7	22.7	22.9	23.2	22.7	20.6	17.3	15.4
	2%	DB	19.9	20.3	22.4	23.3	25.8	29.5	31.8	32.6	30.2	28.8	24.9	21.0
		MCWB	13.6	14.0	15.2	16.4	19.6	22.7	23.7	24.0	23.4	20.3	16.9	14.4
	5%	DB	18.1	18.3	20.2	21.7	24.1	27.9	30.1	31.1	29.0	27.0	22.9	19.2
		MCWB	12.8	13.3	15.1	16.5	19.4	22.7	24.5	24.9	23.4	21.1	16.8	13.8
	10%	DB	16.8	16.8	18.9	20.3	23.1	26.7	29.1	30.1	28.0	25.6	21.2	17.9
		MCWB	12.3	12.8	14.7	16.2	19.0	22.3	24.2	24.8	23.1	20.6	16.1	13.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.0	16.1	17.5	19.2	22.2	25.2	27.1	27.4	26.3	24.0	20.4	17.0
		MCDB	20.1	20.7	22.8	22.8	26.4	28.8	30.2	30.6	29.3	27.2	23.9	20.7
	2%	WB	14.5	14.9	16.5	18.1	21.0	24.3	26.2	26.6	25.1	22.9	18.7	15.4
		MCDB	18.3	19.0	20.3	21.3	24.3	27.7	29.4	30.1	28.4	26.2	22.3	19.4
	5%	WB	13.6	14.0	15.7	17.3	20.2	23.5	25.5	26.1	24.3	22.0	17.6	14.4
		MCDB	17.2	17.5	19.2	20.5	23.3	26.9	28.9	29.6	27.8	25.5	21.3	18.2
	10%	WB	12.6	13.1	15.0	16.6	19.5	22.7	24.9	25.4	23.6	20.9	16.7	13.6
		MCDB	16.0	16.4	18.3	19.7	22.5	26.0	28.3	29.0	27.1	24.6	20.4	17.1
Mean Daily Temperature Range	5% DB	MDBR	8.4	8.7	9.1	8.9	8.4	8.2	8.2	8.4	8.5	9.0	8.8	8.5
		MCDBR	10.5	11.2	11.4	10.9	9.9	10.3	9.4	9.6	9.2	10.7	10.7	10.3
		MCWBR	6.3	6.5	6.3	6.2	5.8	6.3	6.5	6.8	5.6	6.3	6.0	6.0
	5% WB	MCDBR	9.9	10.2	10.1	9.4	8.7	8.9	8.4	8.8	8.4	9.5	9.7	9.6
		MCWBR	6.4	6.5	6.2	6.1	5.7	6.3	6.4	6.7	5.6	6.2	6.1	6.0
Clear-Sky Solar Irradiance	taub		0.344	0.364	0.422	0.458	0.490	0.491	0.539	0.511	0.483	0.433	0.385	0.350
	taud		2.467	2.402	2.213	2.132	2.075	2.098	1.973	2.051	2.137	2.257	2.356	2.458
	Ebn at Noon		843	866	840	829	805	802	760	772	771	777	780	808
	Edh at Noon		84	101	133	152	164	160	180	163	142	116	94	81
All-Sky Solar Radiation	RadAvg		2.35	3.10	4.37	5.44	6.37	7.41	7.47	6.60	5.03	3.79	2.56	2.12
	RadStd		0.26	0.35	0.41	0.45	0.49	0.26	0.20	0.21	0.27	0.25	0.20	0.22