

BORDJ BOU ARRERIDJ, Algeria

WMO: 604440

Lat: 36.067N

Lon: 4.667E

Elev: 957

StdP: 90.34

Time Zone: 1.00 (E01)

Period: 94-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.7	0.3	-6.3	2.5	14.3	-4.6	2.9	11.0	10.5	9.8	9.4	8.9	1.0	20	0.449

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.3	37.3	18.6	36.0	18.5	34.7	18.4	21.1	31.7	20.4	31.3	19.7	30.7	4.4	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.2	14.7	24.7	17.2	13.8	24.0	16.3	13.0	23.6	65.9	31.7	63.2	31.5	60.8	30.8	26.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.1	7.9	6.9	-2.7	39.6	1.7	1.1	-3.9	40.4	-4.8	41.0	-5.8	41.6	-7.0	42.4		
			-2.8	23.5	1.3	1.1	-3.7	24.2	-4.4	24.9	-5.1	25.5	-6.0	26.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.2	6.7	7.3	10.7	13.4	18.5	24.1	28.0	27.0	21.7	17.5	11.0	7.3
	DBStd	8.23	2.78	3.28	3.70	3.71	4.39	4.17	2.88	2.84	3.51	3.67	3.28	2.61
	HDD10.0	356	107	86	36	10	1	0	0	0	0	1	26	89
	HDD18.3	1751	361	309	238	154	53	6	0	0	8	61	219	341
	CDD10.0	2606	4	11	58	112	265	423	559	528	351	233	57	6
	CDD18.3	958	0	0	1	5	59	179	301	270	109	34	0	0
	CDH23.3	10966	0	1	7	56	592	2061	3799	3225	974	249	2	0
	CDH26.7	5508	0	0	1	5	183	1002	2142	1756	358	62	0	0
Wind	WSAvg	2.4	2.2	2.4	2.5	2.7	2.6	2.7	2.7	2.5	2.4	2.0	2.2	2.2
Precipitation	PrecAvg	509	64	51	45	52	45	18	8	11	46	46	56	67
	PrecMax	724	180	111	126	129	115	44	29	40	122	108	115	138
	PrecMin	305	14	8	8	10	7	1	0	0	17	13	13	11
	PrecStd	89	39	27	27	30	29	13	8	10	25	26	24	35
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.5	19.2	24.1	27.4	33.3	37.5	39.4	38.7	34.4	30.7	22.4	17.2
		MCWB	9.1	9.7	11.8	14.2	16.7	17.9	19.6	18.7	18.7	16.4	13.3	9.7
	2%	DB	14.9	16.8	21.5	25.0	30.8	35.7	37.8	36.9	32.2	28.3	19.9	14.8
		MCWB	8.9	8.8	11.2	13.4	16.1	17.8	19.1	18.6	17.5	15.4	11.9	9.4
	5%	DB	13.0	14.9	19.3	22.8	28.9	34.1	36.4	35.6	30.6	26.1	18.1	13.2
		MCWB	8.1	8.1	10.5	12.8	15.6	17.5	18.7	18.6	17.4	15.0	11.1	8.8
	10%	DB	11.2	13.0	17.3	20.5	26.9	32.2	35.0	34.3	28.7	23.9	16.5	11.7
		MCWB	7.2	7.6	9.8	11.9	15.0	17.2	18.5	18.5	17.0	14.6	10.7	8.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.9	11.5	13.4	16.0	19.5	20.9	22.5	22.4	20.9	18.3	15.1	11.4
		MCDB	15.1	16.9	20.8	24.0	29.2	31.3	32.6	32.5	28.1	26.0	19.5	14.8
	2%	WB	9.5	10.0	12.2	14.6	17.8	19.9	21.1	21.1	19.5	16.9	13.5	10.2
		MCDB	13.5	14.7	18.7	22.4	26.9	31.0	32.5	31.7	27.8	23.9	17.3	13.6
	5%	WB	8.5	8.9	11.3	13.7	16.8	19.0	20.4	20.4	18.7	16.0	12.2	9.3
		MCDB	12.2	13.2	17.7	20.7	25.7	30.0	32.2	31.0	26.6	22.9	16.3	12.4
	10%	WB	7.6	8.0	10.4	12.7	15.8	18.2	19.7	19.7	18.0	15.3	11.2	8.5
		MCDB	10.7	12.3	16.2	19.1	24.2	29.0	31.7	30.3	25.5	22.1	15.5	11.2
Mean Daily Temperature Range	5% DB	MDBR	7.9	8.7	10.0	10.8	11.7	12.7	13.3	13.4	11.4	10.1	8.2	7.3
		MCDBR	11.0	11.7	12.6	14.0	13.7	13.9	14.1	14.9	13.2	12.2	10.4	9.6
		MCWBR	6.2	5.9	5.5	6.0	4.8	4.5	4.5	4.8	4.3	4.3	4.9	5.5
	5% WB	MCDBR	9.9	10.0	11.6	12.7	13.1	14.1	13.6	13.8	11.7	10.2	9.1	8.4
		MCWBR	6.0	5.7	5.7	6.0	5.4	5.1	5.1	5.2	4.6	4.2	4.9	5.2
Clear-Sky Solar Irradiance	taub	0.290	0.309	0.364	0.397	0.432	0.440	0.485	0.454	0.423	0.376	0.330	0.299	
	taud	2.513	2.455	2.282	2.200	2.119	2.108	1.973	2.068	2.171	2.304	2.426	2.508	
	Ebn at Noon	916	933	901	885	855	845	804	822	828	840	853	880	
	Edh at Noon	80	95	124	143	157	159	180	161	138	110	87	76	
All-Sky Solar Radiation	RadAvg	2.58	3.37	4.64	5.73	6.66	7.63	7.65	6.78	5.23	4.02	2.81	2.32	
	RadStd	0.27	0.33	0.37	0.43	0.46	0.24	0.18	0.23	0.27	0.27	0.20	0.21	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (8 neighbors)	N/A	N/A	N/A	N/A	+0.34	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page