

ARZEW, Algeria

WMO: 604520

Lat: 35.817N

Lon: 0.267W

Elev: 4

StdP: 101.28

Time Zone: 1.00 (E01)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.8	8.0	0.9	4.0	10.3	2.5	4.5	11.4	12.9	15.9	12.0	15.3	3.0	220	0.423

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.8	32.6	21.1	30.6	21.5	29.0	22.4	25.7	28.0	25.2	27.5	24.7	27.0	4.8	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.0	20.1	27.5	24.5	19.4	27.0	24.0	18.8	26.6	79.4	28.1	76.9	27.5	75.0	27.2	32.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.3	9.9	8.6	4.6	38.0	1.2	2.1	3.7	39.6	3.0	40.8	2.3	42.0	1.4	43.6		
			2.7	26.7	1.4	1.0	1.6	27.4	0.8	28.0	0.0	28.5	-1.1	29.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.2	13.1	13.4	15.4	17.0	19.8	23.1	26.0	26.4	24.0	21.2	16.9	14.3
	DBStd	5.09	1.91	2.34	2.17	1.87	1.90	1.95	1.94	1.72	1.72	2.14	2.51	2.18
	HDD10.0	4	2	1	1	0	0	0	0	0	0	0	0	1
	HDD18.3	641	163	138	94	49	7	0	0	0	3	59	127	
	CDD10.0	3378	98	97	167	209	303	394	495	509	420	347	206	133
	CDD18.3	973	0	1	2	8	52	144	237	251	170	92	14	2
	CDH23.3	6210	0	4	5	14	96	621	1968	2293	949	229	28	3
CDH26.7	1228	0	2	1	1	13	113	457	511	99	28	3	0	
Wind	WSAvg	4.1	4.0	4.2	4.6	4.6	4.4	4.0	3.9	3.7	3.9	3.6	4.1	4.0
Precipitation	PrecAvg	356	52	43	34	33	20	3	1	2	17	34	61	55
	PrecMax	530	110	97	130	148	59	26	6	15	65	131	193	155
	PrecMin	259	4	1	3	0	1	0	0	0	5	4	7	
	PrecStd	70	27	24	27	31	15	5	2	3	16	26	39	35
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.0	22.4	23.7	25.2	28.5	32.2	35.7	35.6	31.4	29.8	25.8	22.9
		MCWB	13.8	14.9	15.4	16.9	17.5	19.3	20.2	21.5	21.4	19.6	17.1	15.2
	2%	DB	18.3	19.9	21.4	22.9	25.6	29.4	32.8	32.3	28.8	26.8	23.7	20.2
		MCWB	13.8	14.1	15.3	16.0	18.0	20.3	21.2	21.7	21.7	20.5	17.1	15.0
	5%	DB	17.3	18.1	20.0	21.4	24.1	27.6	30.7	30.4	27.6	25.3	22.1	18.9
		MCWB	13.5	13.8	14.9	15.9	18.0	20.6	21.3	22.6	22.6	20.5	16.9	14.5
	10%	DB	16.3	16.9	18.8	20.3	23.0	26.3	28.8	28.9	26.7	24.4	20.8	17.7
		MCWB	13.1	13.5	14.7	15.7	17.9	20.8	22.3	23.6	22.5	20.3	16.6	14.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.4	16.0	17.3	18.5	21.1	24.4	26.2	27.2	25.2	23.0	20.1	16.8
		MCDB	17.9	19.4	20.1	21.5	24.0	27.2	28.5	29.4	27.5	25.2	23.3	19.9
	2%	WB	14.6	15.1	16.4	17.7	20.2	23.4	25.4	26.1	24.6	22.2	19.1	16.0
		MCDB	17.1	18.1	19.3	20.5	22.9	25.9	27.8	28.3	26.8	24.6	21.7	18.8
	5%	WB	14.0	14.5	15.8	17.1	19.6	22.8	24.9	25.5	24.0	21.6	18.2	15.1
		MCDB	16.6	17.2	18.7	19.8	22.2	25.2	27.3	27.8	26.2	24.1	20.8	18.1
	10%	WB	13.5	13.9	15.2	16.6	19.1	22.2	24.4	25.1	23.5	21.0	17.1	14.5
		MCDB	16.0	16.4	17.9	19.1	21.6	24.6	26.7	27.3	25.7	23.6	20.0	17.4
Mean Daily Temperature Range	5% DB	MDBR	6.2	6.2	6.0	5.7	5.2	4.8	5.1	4.8	5.0	5.7	6.2	6.0
		MCDBR	7.3	7.5	8.1	8.3	7.4	7.5	8.9	7.9	6.3	7.0	7.8	7.3
		MCWBR	4.6	4.4	4.4	4.6	3.9	3.9	4.8	4.8	4.0	4.1	4.6	4.5
	5% WB	MCDBR	6.4	6.3	6.5	6.1	5.1	4.4	4.4	4.5	4.7	5.3	6.1	6.3
		MCWBR	4.6	4.3	4.2	4.1	3.6	3.3	3.7	3.7	3.7	4.0	4.4	4.5
Clear-Sky Solar Irradiance	taub	0.332	0.358	0.418	0.434	0.466	0.490	0.538	0.512	0.472	0.421	0.374	0.340	
	taud	2.487	2.411	2.214	2.195	2.130	2.071	1.945	2.021	2.144	2.279	2.394	2.478	
	Ebn at Noon	865	878	847	852	827	804	762	773	785	795	803	828	
	Edh at Noon	84	101	134	144	156	165	186	169	142	114	92	80	
All-Sky Solar Radiation	RadAvg	2.71	3.56	4.79	5.82	6.71	7.48	7.33	6.61	5.28	4.05	2.83	2.42	
	RadStd	0.23	0.34	0.32	0.42	0.46	0.27	0.17	0.23	0.20	0.27	0.23	0.17	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (10 neighbors)	+0.22	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page