

MOSTAGANEM, Algeria

WMO: 604570

Lat: 35.883N

Lon: 0.117E

Elev: 138

StdP: 99.68

Time Zone: 1.00 (E01)

Period: 01-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.2	3.5	-0.4	3.7	7.6	0.9	4.1	7.5	10.3	13.7	9.1	12.6	0.2	40	0.357

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.1	35.3	21.7	33.2	21.3	31.6	21.4	25.0	29.1	24.4	28.4	23.8	27.9	3.2	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.9	19.1	27.0	23.2	18.3	26.3	22.6	17.6	25.9	76.9	29.1	74.2	28.5	72.0	27.9	28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.2	7.1	6.1	0.2	40.4	1.2	2.1	-0.7	41.9	-1.3	43.1	-2.0	44.3	-2.8	45.9		
			-0.2	26.3	1.1	1.3	-1.0	27.3	-1.6	28.0	-2.2	28.8	-3.0	29.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.0	11.0	11.6	13.3	15.6	18.9	22.8	25.9	26.1	23.2	20.1	15.0	12.0
	DBStd	5.93	2.30	2.79	2.62	2.46	2.59	2.71	2.14	2.15	2.24	2.61	2.88	2.47
	HDD10.0	42	15	13	5	1	0	0	0	0	0	0	1	8
	HDD18.3	999	227	189	156	87	23	1	0	0	0	11	108	197
	CDD10.0	2961	47	57	108	169	275	385	492	499	396	314	149	70
	CDD18.3	878	0	1	1	6	40	136	233	241	146	67	7	1
	CDH23.3	7649	0	4	15	63	308	1092	2244	2430	1062	392	37	3
	CDH26.7	2808	0	1	2	11	80	385	934	1002	290	97	5	0
Wind	WSAvg	2.0	1.9	2.4	2.2	2.4	2.4	2.2	1.9	1.8	1.8	1.6	1.8	1.7
Precipitation	PrecAvg	406	61	48	41	37	26	2	1	3	21	37	70	59
	PrecMax	565	116	112	140	92	81	24	6	28	105	93	174	177
	PrecMin	274	13	1	7	0	3	0	0	0	2	6	10	9
	PrecStd	79	29	27	28	27	20	5	2	6	21	21	38	40
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.4	22.2	25.3	28.0	31.9	36.4	38.9	38.2	34.3	32.4	27.0	22.6
		MCWB	13.5	14.1	15.6	16.9	19.3	21.8	21.8	21.7	21.2	19.2	16.6	15.2
	2%	DB	18.2	19.6	22.0	25.1	28.7	32.9	35.3	35.1	31.5	29.4	23.9	19.7
		MCWB	13.0	13.5	15.2	16.7	18.3	20.5	21.5	22.3	21.3	19.3	16.2	13.9
	5%	DB	16.8	17.9	20.1	22.8	26.7	30.7	32.9	32.9	29.6	27.0	21.8	18.0
		MCWB	12.8	13.1	14.5	15.8	17.9	20.1	21.2	21.8	21.1	19.4	16.1	13.4
	10%	DB	15.7	16.4	18.6	20.9	24.7	28.7	31.2	31.3	28.1	25.2	20.0	16.7
		MCWB	12.3	12.6	14.1	15.4	17.5	19.7	21.6	22.0	21.1	19.3	15.3	12.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.0	15.7	17.2	18.6	21.4	24.5	25.5	26.3	24.5	22.6	19.5	16.2
		MCDB	17.5	20.3	22.6	24.0	28.6	30.8	29.7	30.7	28.4	26.1	23.0	20.4
	2%	WB	14.1	14.6	16.1	17.6	20.1	23.0	24.7	25.3	23.6	21.6	17.9	14.9
		MCDB	16.9	18.0	20.3	22.4	25.5	28.3	28.9	29.2	27.1	25.1	21.0	18.3
	5%	WB	13.3	13.8	15.3	16.8	19.2	22.1	24.2	24.6	22.9	20.8	16.9	14.1
		MCDB	16.1	16.9	18.9	21.2	24.0	26.7	28.4	28.5	26.6	24.4	20.2	17.1
	10%	WB	12.6	13.1	14.5	16.0	18.4	21.4	23.6	24.1	22.4	20.0	16.0	13.3
		MCDB	15.3	15.9	17.7	19.6	22.7	25.8	27.8	28.0	26.1	23.9	19.0	16.1
Mean Daily Temperature Range	5% DB	MDBR	9.3	8.9	9.5	9.6	9.5	10.3	10.2	10.1	9.8	10.1	9.1	8.9
		MCDBR	11.3	10.9	12.7	13.9	14.4	14.6	14.0	13.7	12.4	13.1	11.9	10.8
		MCWBR	7.0	6.1	7.0	6.9	6.3	5.4	4.8	5.0	5.2	5.7	6.3	6.3
	5% WB	MCDBR	9.7	9.2	10.7	10.7	10.9	10.7	9.9	9.2	9.5	9.8	9.6	9.5
		MCWBR	6.6	5.8	6.6	6.0	5.3	4.6	4.3	4.4	4.7	5.3	6.0	6.3
Clear-Sky Solar Irradiance	taub	0.323	0.347	0.404	0.420	0.451	0.471	0.518	0.491	0.455	0.407	0.363	0.331	
	taud	2.498	2.429	2.247	2.224	2.162	2.113	1.980	2.063	2.177	2.308	2.415	2.493	
	Ebn at Noon	876	890	861	865	840	820	778	791	800	810	815	841	
	Edn at Noon	83	99	129	139	151	158	179	162	137	111	89	79	
All-Sky Solar Radiation	RadAvg	2.68	3.52	4.76	5.79	6.68	7.50	7.37	6.64	5.27	4.06	2.81	2.39	
	RadStd	0.24	0.35	0.32	0.44	0.47	0.27	0.16	0.24	0.22	0.28	0.23	0.17	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page