

TEBESSA, Algeria

WMO: 604750

Lat: 35.432N

Lon: 8.121E

Elev: 811

StdP: 91.95

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.0	0.2	-6.1	2.5	11.3	-4.5	2.8	9.6	14.4	7.7	13.0	8.3	1.5	300	0.491

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.1	39.0	19.4	37.6	19.1	36.0	19.0	22.2	33.4	21.2	32.1	20.5	31.1	6.0	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.1	15.3	25.8	18.1	14.4	24.8	17.2	13.5	24.2	69.4	33.3	65.7	32.4	62.8	31.2	29.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.2	10.5	9.3	DB	-3.3	41.2	1.3	1.0	-4.2	41.9	-4.9	42.4	-5.6	43.0	-6.5	43.7
			WB	-4.1	23.8	1.2	1.7	-4.9	25.1	-5.6	26.1	-6.3	27.1	-7.2	28.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	16.6	7.3	7.9	11.1	14.4	19.3	24.1	27.5	26.8	22.3	18.0	12.1	8.3	(6)
(7)		DBStd	7.86	2.76	3.20	3.79	3.73	3.99	3.89	2.99	2.88	3.34	3.55	3.22	2.68	(7)
(8)		HDD10.0	281	91	72	32	6	0	0	0	0	0	14	66	(8)	
(9)		HDD18.3	1581	341	291	227	128	37	3	0	5	49	188	311	(9)	
(10)		CDD10.0	2707	8	14	66	137	287	422	542	369	249	77	13	(10)	
(11)		CDD18.3	966	0	0	2	9	66	176	283	263	125	40	1	0	(11)
(12)		CDH23.3	12291	0	3	36	166	886	2336	3886	3297	1259	404	16	1	(12)
(13)	CDH26.7	6582	0	1	5	35	354	1262	2348	1904	546	126	2	0	(13)	
(14)	Wind	WSAvg	3.3	3.2	3.8	3.8	3.9	3.6	3.3	3.2	2.9	2.8	2.6	3.0	3.2	(14)
(15)	Precipitation	PrecAvg	386	30	21	37	39	35	27	16	24	42	37	33	28	(15)
(16)		PrecMax	590	100	73	140	112	96	92	58	72	150	94	117	77	(16)
(17)		PrecMin	286	0	0	5	1	0	0	0	1	3	2	1	0	(17)
(18)		PrecStd	75	22	21	27	29	23	23	15	20	31	26	29	23	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	20.1	22.7	26.9	30.0	35.9	39.2	41.0	40.2	36.1	32.6	25.2	20.9	(19)	
(20)		MCWB	10.7	11.3	13.3	15.8	17.1	18.8	20.5	19.9	19.0	18.0	14.3	12.1	(20)	
(21)		DB	17.4	19.4	23.8	27.2	32.6	37.2	39.4	38.5	34.0	30.0	22.6	17.6	(21)	
(22)		MCWB	9.5	10.3	12.1	14.1	16.5	18.6	19.7	19.4	19.1	16.8	13.1	10.3	(22)	
(23)		DB	15.1	17.0	21.2	25.1	30.2	35.5	38.0	37.0	32.1	27.8	20.5	15.8	(23)	
(24)		MCWB	8.8	9.4	11.5	13.6	16.3	18.3	19.2	19.2	18.6	16.3	12.5	9.7	(24)	
(25)		DB	13.1	14.9	19.1	23.0	28.2	33.4	36.2	35.2	30.0	25.2	18.4	14.0	(25)	
(26)		MCWB	7.9	8.5	10.9	13.0	15.8	17.9	19.1	19.3	18.1	15.5	11.9	9.0	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	11.9	13.4	15.1	17.1	20.0	21.6	24.0	23.2	22.2	19.7	16.6	13.0	(27)	
(28)		MCDWB	17.4	19.1	22.6	25.7	29.8	33.7	35.6	33.6	30.9	28.8	22.2	18.4	(28)	
(29)		WB	10.5	11.4	13.6	15.7	18.6	20.5	22.5	22.0	20.9	18.4	14.7	11.3	(29)	
(30)		MCDWB	15.8	17.6	21.0	23.9	28.8	32.7	34.5	33.1	28.8	26.1	19.5	15.9	(30)	
(31)		WB	9.2	9.9	12.5	14.7	17.5	19.7	21.4	21.1	20.1	17.5	13.5	10.3	(31)	
(32)		MCDWB	13.9	15.8	19.5	22.5	26.9	31.6	33.2	31.6	28.2	24.7	18.2	14.6	(32)	
(33)		WB	8.3	8.8	11.4	13.6	16.6	18.8	20.5	20.4	19.2	16.6	12.6	9.4	(33)	
(34)		MCDWB	12.3	14.1	18.0	21.0	25.6	30.3	32.1	30.8	26.8	23.1	17.2	13.2	(34)	
(35)	Mean Daily Temperature Range	MDBR	10.1	10.7	12.1	12.8	14.2	15.2	16.1	15.2	13.0	12.1	10.7	9.9	(35)	
(36)		5% DB	14.6	15.3	16.1	16.6	16.7	17.1	17.6	17.2	15.7	15.2	14.2	14.0	(36)	
(37)		MCWBR	8.4	8.1	7.6	7.0	6.1	5.6	5.7	5.4	5.4	5.9	7.2	8.2	(37)	
(38)		5% WB	13.1	13.7	14.4	14.8	15.6	16.5	16.8	15.8	14.0	13.2	11.8	11.8	(38)	
(39)		MCWBR	8.2	7.9	7.6	7.2	6.7	6.3	6.5	5.8	5.6	6.0	6.7	7.4	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.297	0.318	0.388	0.433	0.470	0.451	0.486	0.468	0.445	0.396	0.341	0.305	(40)	
(41)		taud	2.456	2.390	2.168	2.059	1.983	2.063	1.975	2.015	2.086	2.200	2.354	2.450	(41)	
(42)		Ebn at Noon	909	923	877	853	823	836	804	811	808	819	841	873	(42)	
(43)		Edh at Noon	85	103	140	165	180	166	180	170	150	123	94	81	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.72	3.54	4.71	5.83	6.65	7.49	7.53	6.68	5.20	4.03	2.99	2.44	(44)	
(45)		RadStd	0.23	0.25	0.33	0.38	0.34	0.33	0.24	0.31	0.24	0.19	0.18	0.21	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	+0.86	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page