

MASCARA MATEMORE, Algeria

WMO: 605060

Lat: 35.330N

Lon: 0.210E

Elev: 1562

StdP: 13.89

Time Zone: 1.00 (E01)

Period: 88-08

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.5	33.0	21.4	17.0	51.9	24.9	20.0	51.3	29.7	58.9	26.1	55.8	0.1	250	0.446

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 28.0	(c) 101.6	(d) 68.1	(e) 98.1	(f) 68.3	(g) 95.1	(h) 67.7	(i) 73.1	(j) 90.3	(k) 71.7	(l) 88.5	(m) 70.3	(n) 87.4	(o) 10.0	(p) 0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.4	110.7	79.5	66.5	103.5	78.7	64.8	97.5	77.6	37.7	90.1	36.3	87.8	35.1	87.6	80.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 23.8	(b) 20.4	(c) 17.5	(e) 26.2	(f) 106.9	(g) 2.1	(h) 2.9	(i) 24.7	(j) 109.0	(k) 23.5	(l) 110.7	(m) 22.3	(n) 112.3	(o) 20.8	(p) 114.3		
			DB													
			WB													
				25.3	76.5	2.0	1.6	23.8	77.6	22.6	78.5	21.5	79.4	20.0	80.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	62.5	48.1	49.4	54.1	56.8	64.9	73.3	79.5	80.2	72.5	64.2	55.7	50.1
	DBStd	12.48	4.86	4.44	5.40	4.92	6.63	6.01	5.19	4.96	5.70	5.83	5.88	5.27
	HDD50	254	94	57	19	4	0	0	0	0	0	0	17	63
	HDD65	2480	523	436	342	250	83	6	0	0	9	86	282	463
	CDD50	4814	37	41	145	208	461	700	916	935	676	441	189	65
	CDD65	1561	0	0	3	4	78	256	451	470	234	61	4	0
	CDH74	19555	0	3	87	149	1069	3122	5932	6159	2393	592	44	5
	CDH80	10020	0	0	13	19	377	1527	3394	3533	1001	155	1	0
Wind	WSAvg	5.4	4.9	4.6	5.7	6.8	6.1	6.1	5.6	5.4	5.2	4.5	5.0	5.0
Precipitation	PrecAvg	13.6	1.7	1.5	1.4	1.6	1.1	0.4	0.1	0.3	0.7	1.3	2.0	1.5
	PrecMax	21.2	3.8	4.2	6.5	5.2	3.5	2.2	0.6	1.6	1.9	4.3	5.6	3.4
	PrecMin	7.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.0
	PrecStd	3.3	1.1	0.9	1.3	1.2	0.8	0.6	0.2	0.4	0.6	0.9	1.1	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	69.7	73.7	80.7	82.7	95.6	101.7	106.1	104.7	96.3	89.1	78.8	71.8
		MCWB	52.3	53.3	58.1	58.5	67.9	67.6	67.7	68.5	67.5	61.8	58.0	52.9
	2%	DB	64.9	69.1	76.1	78.4	88.0	97.0	102.2	101.4	92.5	84.5	74.5	66.5
		MCWB	50.0	51.4	56.1	56.6	62.9	67.3	67.8	68.6	66.0	61.5	56.9	52.9
	5%	DB	61.4	65.4	71.9	74.6	84.0	93.0	98.1	98.1	89.4	80.5	70.9	63.3
		MCWB	49.2	50.9	54.2	56.1	61.4	66.2	68.0	68.8	65.4	61.1	56.4	52.3
	10%	DB	58.2	61.7	67.8	70.8	79.8	88.6	94.6	95.2	86.1	76.8	67.3	60.1
		MCWB	48.4	50.0	53.2	55.0	60.6	64.4	67.6	68.2	66.1	60.8	55.4	51.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.6	57.0	61.2	61.8	68.2	72.9	74.0	76.5	72.8	67.3	62.0	58.4
		MCDB	62.3	68.5	74.4	76.0	89.2	93.6	93.0	94.0	84.5	77.3	70.6	65.0
	2%	WB	53.0	54.2	58.2	59.5	65.3	69.9	72.3	73.9	70.8	65.3	60.1	55.7
		MCDB	59.7	63.0	71.5	73.0	83.0	88.9	91.8	90.7	82.8	75.9	69.7	61.7
	5%	WB	51.2	52.4	56.0	57.9	63.7	68.0	70.8	72.3	69.3	63.9	58.4	54.0
		MCDB	58.5	60.9	67.7	70.0	78.6	85.6	90.0	88.7	81.6	74.4	67.0	60.4
	10%	WB	49.6	50.9	54.3	56.3	62.0	66.3	69.4	70.9	67.8	62.5	56.9	52.4
		MCDB	56.5	59.7	64.7	67.1	75.7	83.5	87.9	87.6	80.3	73.0	64.5	58.7
Mean Daily Temperature Range	5% DB	MDBR	20.4	23.1	23.6	24.0	24.7	26.5	28.2	28.0	24.2	22.3	20.0	19.5
		MCDBR	25.9	32.5	33.1	32.5	31.7	33.4	33.5	32.4	29.6	28.4	26.6	24.4
		MCWBR	14.0	17.2	15.8	14.8	12.2	12.7	12.2	12.1	11.3	11.1	12.8	13.3
	5% WB	MCDBR	20.4	25.2	27.0	26.8	26.4	28.5	28.4	26.6	23.9	21.4	20.8	18.8
		MCWBR	12.5	14.9	14.9	13.8	11.7	12.1	12.5	12.9	10.8	9.9	11.5	11.9
Clear-Sky Solar Irradiance	taub		0.306	0.334	0.396	0.417	0.450	0.474	0.528	0.495	0.455	0.400	0.351	0.316
	taud		2.484	2.405	2.200	2.165	2.095	2.031	1.885	1.977	2.095	2.244	2.386	2.479
	Ebn at Noon		285	288	276	276	267	259	244	250	254	259	264	274
	Edh at Noon		27	32	43	47	51	55	63	56	47	37	29	25
All-Sky Solar Radiation	RadAvg		874	1136	1533	1853	2136	2412	2379	2146	1700	1326	923	784
	RadStd		86	119	100	151	148	82	48	78	85	89	74	62

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)		N/A	N/A	N/A	N/A	+0.72	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page