

BISKRA, Algeria

WMO: 605250

Lat: 34.793N

Lon: 5.738E

Elev: 88

StdP: 100.27

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.4	5.8	-5.5	2.4	14.3	-3.9	2.7	14.2	15.1	13.9	13.9	13.1	2.2	10	0.511

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.1	44.1	21.9	42.6	21.6	41.0	21.4	24.0	38.0	23.3	37.4	22.7	36.8	4.2	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.0	14.9	29.3	19.0	13.9	29.1	18.0	13.1	29.4	72.3	38.1	69.6	37.3	67.2	36.8	31.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.1	12.5	11.0	1.7	46.5	1.3	0.9	0.8	47.2	0.1	47.7	-0.6	48.2	-1.6	48.8		
(5)			-0.1	25.9	1.0	1.8	-0.9	27.2	-1.5	28.3	-2.0	29.3	-2.8	30.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	22.9	12.3	13.6	17.4	21.2	26.4	31.3	34.7	33.9	29.0	23.7	17.1	13.1	(6)
(7)		DBStd	8.43	2.29	2.82	3.19	3.32	3.60	3.41	2.53	2.51	3.39	3.07	2.88	2.41	(7)
(8)		HDD10.0	13	6	3	0	0	0	0	0	0	0	0	0	4	(8)
(9)		HDD18.3	609	188	133	56	10	0	0	0	0	0	2	56	164	(9)
(10)		CDD10.0	4708	76	106	229	334	507	640	766	742	569	426	214	99	(10)
(11)		CDD18.3	2261	0	2	27	94	249	390	508	483	319	168	19	0	(11)
(12)		CDH23.3	32578	1	17	233	901	3051	5977	8596	7962	4258	1484	96	1	(12)
(13)	CDH26.7	20413	0	3	46	314	1590	3846	6136	5518	2389	559	12	0	(13)	
(14)	Wind	WSAvg	4.1	4.0	4.4	4.9	5.3	5.1	4.3	3.7	3.5	3.6	3.3	3.8	3.6	(14)
(15)	Precipitation	PrecAvg	112	12	7	12	12	12	5	1	4	13	13	15	9	(15)
(16)		PrecMax	252	77	37	49	68	57	24	34	34	51	80	74	37	(16)
(17)		PrecMin	45	0	0	0	0	0	0	0	0	0	0	0	0	(17)
(18)		PrecStd	51	18	8	12	15	16	7	5	8	13	17	17	10	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.0	25.2	30.9	34.9	40.9	44.5	46.2	45.1	41.0	36.0	28.1	22.0	(19)
MCWB			12.6	13.7	16.0	17.4	19.7	21.3	22.7	22.1	21.8	20.0	17.1	13.3	(20)	
2%		DB	20.0	23.0	27.6	32.0	37.8	42.4	44.5	43.5	39.0	33.6	25.8	20.5	(21)	
		MCWB	12.1	12.8	14.6	17.0	19.4	20.8	22.1	21.9	21.5	19.2	16.2	12.8	(22)	
5%		DB	18.8	21.1	25.9	30.1	35.8	40.4	43.0	42.0	37.1	31.4	24.1	19.2	(23)	
		MCWB	11.3	12.0	13.9	16.3	18.9	20.4	21.8	21.8	21.3	18.9	15.1	12.2	(24)	
10%		DB	17.2	19.6	24.1	28.1	33.9	38.8	41.2	40.3	35.5	29.8	22.6	18.0	(25)	
		MCWB	10.6	11.3	13.4	15.5	18.3	20.3	21.6	21.8	21.0	18.6	14.3	11.6	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.3	15.3	17.2	19.0	21.5	23.3	24.9	25.3	24.6	22.2	18.7	15.0	(27)
MCD B			20.0	23.5	25.5	29.7	35.5	38.3	40.8	37.1	35.4	30.6	25.9	19.6	(28)	
2%		WB	12.7	13.7	15.8	17.9	20.4	22.2	23.8	24.1	23.4	21.0	17.1	13.7	(29)	
		MCD B	18.4	21.2	25.5	29.1	34.0	37.4	40.2	37.5	34.5	29.5	23.9	18.7	(30)	
5%		WB	11.8	12.7	14.7	17.1	19.6	21.5	23.0	23.5	22.6	20.1	16.0	12.9	(31)	
		MCD B	17.3	19.8	24.2	27.6	33.0	36.8	39.0	37.3	33.7	28.3	22.6	17.9	(32)	
10%		WB	11.0	11.7	13.9	16.2	18.9	20.9	22.3	22.8	21.9	19.3	15.0	12.1	(33)	
		MCD B	16.3	18.4	22.9	26.0	31.8	36.1	38.3	36.9	32.5	27.6	21.1	17.2	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.8	10.4	11.2	11.3	11.6	12.0	12.1	11.7	10.6	10.4	9.8	9.4	(35)
MCDBR			11.4	12.3	13.3	13.4	13.5	13.3	13.9	13.2	12.0	12.2	11.1	10.7	(36)	
MCWBR			6.3	6.3	5.9	5.5	5.1	4.7	4.8	4.7	4.6	5.1	5.4	5.9	(37)	
5% WB		MCDBR	10.4	11.4	11.9	12.0	12.3	12.4	12.4	11.6	10.8	10.3	10.3	9.6	(38)	
		MCWBR	6.2	6.3	5.8	5.4	5.1	5.0	5.1	5.0	4.7	4.9	5.5	5.7	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.329	0.357	0.438	0.487	0.543	0.551	0.604	0.569	0.531	0.464	0.388	0.342	(40)	
taud		2.357	2.262	1.999	1.896	1.791	1.785	1.688	1.762	1.859	1.995	2.177	2.311	(41)		
Ebn at Noon		868	878	827	805	765	756	713	728	732	747	781	822	(42)		
Edh at Noon		96	118	167	194	219	220	241	220	190	152	114	95	(43)		
(44)	All-Sky Solar Radiation	RadAvg	3.10	4.05	5.27	6.36	7.15	7.82	7.76	6.90	5.55	4.37	3.29	2.76	(44)	
(45)		RadStd	0.21	0.20	0.27	0.32	0.25	0.22	0.14	0.22	0.19	0.27	0.14	0.18	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		+0.45	N/A	N/A	N/A	+0.64	+0.78	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	+0.27	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page