

MECHERIA, Algeria

WMO: 605490

Lat: 33.536N

Lon: 0.242W

Elev: 1175

StdP: 87.98

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.3	0.1	-11.1	1.7	12.5	-8.8	2.1	11.8	15.3	5.4	14.3	7.3	2.4	260	0.559

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.0	38.3	19.6	37.2	19.0	36.1	18.6	22.6	34.3	21.5	33.0	20.6	31.8	7.0	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	16.0	29.0	18.0	14.9	27.0	16.9	14.0	26.2	73.0	34.6	68.7	33.4	64.9	31.8	26.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
13.4	11.6	10.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			DB												
			WB	-5.1	24.3	3.8	2.0	-7.8	25.7	-10.0	26.9	-12.1	28.1	-14.8	29.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.3	6.7	9.0	12.4	15.5	20.0	25.6	29.6	28.0	22.9	18.2	11.3	8.1		
	DBStd	8.41	3.34	3.34	3.75	3.99	4.36	3.70	2.59	2.48	3.55	3.40	3.59	2.85		
	HDD10.0	284	111	52	18	4	1	0	0	0	0	0	28	71		
	HDD18.3	1529	361	263	186	104	34	1	0	0	6	45	212	318		
	CDD10.0	2954	8	22	93	168	311	467	607	558	388	254	66	11		
	CDD18.3	1157	0	0	3	18	86	217	349	299	143	41	1	0		
	CDH23.3	14172	0	0	33	213	922	2667	4873	3768	1424	269	2	0		
	CDH26.7	7480	0	0	4	47	351	1410	2945	2072	604	47	0	0		
(14) Wind	WSAvg	4.8	4.7	4.9	4.9	5.8	5.4	5.0	5.2	4.6	4.4	3.9	4.6	4.1		
(15) Precipitation	PrecAvg	242	17	17	27	23	23	10	6	12	31	35	25	16		
	PrecMax	420	53	43	128	57	61	62	20	42	76	171	152	42		
	PrecMin	147	0	0	3	0	1	0	0	1	9	0	0	1		
	PrecStd	62	14	11	28	15	17	13	5	10	18	36	31	9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.1	21.2	26.8	30.0	34.8	38.5	40.6	39.0	36.3	29.9	23.2	18.9		
		MCWB	9.8	10.0	11.6	13.9	16.6	17.5	20.7	21.7	18.1	15.1	13.3	10.2		
	2%	DB	16.4	19.0	23.8	28.0	32.1	36.6	39.1	37.2	34.2	28.0	21.6	16.6		
		MCWB	8.2	9.1	10.9	13.1	16.2	17.9	19.8	19.9	18.0	14.4	12.6	9.0		
	5%	DB	14.3	17.0	21.8	25.9	30.2	35.2	38.0	36.1	32.2	26.2	19.8	15.0		
		MCWB	7.4	8.3	10.5	12.9	15.6	17.8	19.4	19.0	17.4	14.3	11.5	8.5		
	10%	DB	12.5	15.3	20.0	23.7	28.3	33.9	37.0	34.9	30.2	24.6	17.8	13.3		
		MCWB	6.5	7.7	10.0	12.2	14.8	17.4	19.0	18.7	16.8	14.3	10.8	8.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.9	11.7	13.9	16.3	20.2	21.7	24.1	24.0	22.1	18.3	14.9	11.9		
		MCDB	16.2	18.1	21.9	25.4	29.7	33.7	36.6	36.7	32.0	24.0	21.2	16.4		
	2%	WB	9.4	10.3	12.5	15.0	18.4	20.3	22.8	22.5	20.2	17.0	13.6	10.4		
		MCDB	14.9	16.9	20.2	23.6	28.0	32.6	35.3	33.6	29.3	23.7	19.5	14.6		
	5%	WB	8.2	9.3	11.5	13.9	17.0	19.3	21.6	21.5	19.0	16.1	12.5	9.5		
		MCDB	12.8	15.3	19.5	22.0	26.9	31.0	34.3	32.1	27.4	22.4	18.3	13.4		
	10%	WB	7.2	8.3	10.6	13.0	15.9	18.4	20.6	20.6	18.1	15.3	11.4	8.7		
		MCDB	11.3	14.0	18.3	21.0	25.4	30.0	33.3	30.5	26.7	21.6	16.6	12.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.1	10.2	11.5	11.9	12.5	13.2	14.0	13.1	12.1	10.6	9.4	9.3		
		MCDBR	12.1	13.2	14.4	14.5	14.1	14.4	15.1	14.4	13.8	12.3	11.5	12.3		
	5% WB	MCWBR	6.7	6.6	6.1	5.7	5.6	5.5	5.7	5.4	5.3	4.8	5.7	6.6		
		MCWBR	10.9	11.4	13.0	13.5	13.6	14.5	15.6	14.2	12.6	10.9	11.0	10.4		
(40) Clear-Sky Solar Irradiance	taub		0.264	0.293	0.362	0.388	0.431	0.464	0.532	0.490	0.443	0.381	0.315	0.275		
	taud		2.467	2.380	2.170	2.112	2.011	1.918	1.758	1.866	1.992	2.162	2.368	2.460		
	Ebn at Noon		964	961	909	899	859	827	769	795	816	843	886	928		
	Edh at Noon		86	105	141	157	176	193	225	199	167	130	95	82		
(44) All-Sky Solar Radiation	RadAvg		3.35	4.29	5.53	6.60	7.30	7.90	7.63	6.94	5.69	4.61	3.49	3.01		
	RadStd		0.24	0.25	0.24	0.31	0.30	0.22	0.20	0.24	0.34	0.30	0.23	0.18		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page