

EL BAYADH, Algeria

WMO: 605500

Lat: 33.717N

Lon: 1.083E

Elev: 4419

StdP: 12.50

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.2	28.8	11.7	11.7	53.4	15.0	13.8	51.8	30.0	40.9	27.9	41.6	4.3	0	0.491

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.2	96.8	61.2	95.0	60.8	93.2	60.2	64.2	84.7	63.0	85.2	62.1	85.0	11.3	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.5	86.4	68.8	56.5	80.3	68.0	54.7	75.1	67.4	31.7	85.2	30.8	85.5	30.0	85.0	70.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
25.7	22.5	19.8	DB	21.9	100.1	3.3	2.2	19.5	101.7	17.6	102.9	15.7	104.2	13.3	105.8
			WB	21.0	66.8	3.4	1.7	18.5	68.0	16.6	69.0	14.7	69.9	12.2	71.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	59.8	41.2	43.5	49.5	55.6	64.8	74.6	82.5	80.4	70.8	61.5	49.1	42.9	(6)
	DBStd	15.62	5.53	6.43	6.88	7.62	8.10	6.92	4.40	4.54	6.45	6.49	6.24	5.35	(7)
	HDD50	918	275	194	92	31	3	0	0	0	0	4	90	229	(8)
	HDD65	3562	737	601	481	295	107	9	0	0	21	147	478	686	(9)
	CDD50	4496	3	13	77	198	462	739	1009	941	624	359	63	8	(10)
	CDD65	1662	0	0	1	11	101	297	544	476	195	37	0	0	(11)
	CDH74	19718	0	0	6	107	999	3447	7305	5792	1817	243	2	0	(12)
	CDH80	9375	0	0	0	6	274	1535	3995	2922	606	37	0	0	(13)
(14) Wind	WSAvg	7.7	7.1	7.9	8.3	9.4	8.7	8.4	8.4	7.2	7.3	6.3	6.8	6.5	(14)
(15) Precipitation	PrecAvg	12.0	0.9	0.8	1.4	1.3	0.8	0.7	0.3	0.5	1.3	1.5	1.1	1.2	(15)
	PrecMax	20.9	3.4	2.5	4.3	4.6	2.7	3.4	1.4	1.7	3.4	7.1	4.6	2.8	(16)
	PrecMin	5.0	0.0	0.0	0.3	0.1	0.0	0.0	0.0	0.0	0.3	0.0	0.0	0.2	(17)
	PrecStd	3.5	0.8	0.6	1.0	1.0	0.8	0.7	0.3	0.4	0.9	1.6	1.1	0.7	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.5	67.3	73.9	80.7	89.8	96.5	99.0	98.0	91.6	84.6	71.8	64.4	(19)
		MCWB	45.7	47.5	48.9	53.0	57.2	60.2	61.5	61.9	60.0	57.2	52.0	47.3	(20)
	2%	DB	58.2	62.3	69.2	77.1	86.2	93.6	97.5	95.8	88.9	79.7	66.8	59.1	(21)
		MCWB	43.8	45.5	48.1	52.5	56.2	59.6	61.3	61.4	59.3	55.7	50.2	46.0	(22)
	5%	DB	54.5	58.4	65.9	73.8	82.9	91.1	96.0	94.1	86.3	76.4	63.2	55.4	(23)
		MCWB	42.2	44.1	47.1	51.2	55.1	58.9	60.9	60.9	59.0	54.7	48.8	44.9	(24)
	10%	DB	51.2	55.1	62.7	70.1	79.8	88.6	94.2	92.2	83.7	73.4	60.3	52.2	(25)
		MCWB	41.3	42.7	45.7	49.8	54.3	58.4	60.5	60.5	58.3	53.9	47.9	43.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.7	49.4	52.7	55.9	60.1	63.4	65.6	66.4	64.3	60.4	56.4	50.4	(27)
		MCDB	56.7	60.8	63.9	71.0	80.0	87.0	87.6	85.1	79.2	72.1	66.9	58.0	(28)
	2%	WB	45.6	47.5	50.7	54.0	58.1	61.6	63.7	64.6	62.5	58.7	53.2	47.9	(29)
		MCDB	54.1	58.9	62.6	70.1	77.8	85.0	88.1	83.7	78.8	70.8	61.5	56.5	(30)
	5%	WB	44.0	45.5	48.9	52.7	56.7	60.4	62.6	63.5	61.2	57.4	51.3	45.9	(31)
		MCDB	51.9	55.5	61.2	68.7	76.1	84.2	88.5	84.2	78.2	68.9	60.0	53.2	(32)
	10%	WB	42.3	43.8	47.3	51.3	55.5	59.4	61.7	62.4	60.1	56.1	49.1	44.3	(33)
		MCDB	49.4	52.5	60.0	66.2	74.4	82.2	88.3	84.7	77.2	68.3	58.0	50.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	15.9	16.9	19.0	19.8	21.1	21.9	22.2	22.1	20.1	18.3	15.9	14.8	(35)
		MCDBR	22.6	22.8	24.0	23.7	23.8	23.0	23.2	23.2	22.7	21.1	20.7	21.2	(36)
	5% WB	MCWBR	11.5	10.9	10.1	9.0	8.1	7.1	6.9	6.6	7.1	7.5	9.5	11.4	(37)
		MCWBR	19.1	19.5	20.5	21.4	22.3	22.5	22.6	22.6	20.9	17.5	17.0	18.1	(38)
(40) Clear-Sky Solar Irradiance	taub		0.260	0.289	0.358	0.388	0.432	0.464	0.530	0.491	0.445	0.379	0.312	0.270	(40)
		taud	2.493	2.408	2.190	2.117	2.012	1.921	1.764	1.865	1.984	2.167	2.383	2.481	(41)
	Ebn at Noon		307	306	290	285	272	262	244	252	258	268	282	296	(42)
		Edh at Noon	27	32	44	49	56	61	71	63	53	41	30	25	(43)
(44) All-Sky Solar Radiation	RadAvg		1043	1343	1744	2093	2322	2507	2440	2208	1807	1461	1100	937	(44)
	RadStd		78	89	79	95	108	79	61	81	106	96	67	69	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page