

EL BAYADH, Algeria

WMO: 605500

Lat: 33.717N

Lon: 1.083E

Elev: 1347

StdP: 86.16

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.2	-1.8	-11.3	1.7	11.9	-9.4	2.0	11.0	13.4	4.9	12.5	5.4	1.9	0	0.491

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.4	36.0	16.2	35.0	16.0	34.0	15.7	17.9	29.3	17.2	29.5	16.7	29.5	5.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.7	12.3	20.5	13.6	11.5	20.0	12.6	10.7	19.7	56.0	29.5	53.8	29.7	52.0	29.4	21.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.5	10.0	8.8	-5.6	37.8	1.9	1.2	-6.9	38.7	-8.0	39.4	-9.1	40.1	-10.4	41.0		
(5)			-6.1	19.3	1.9	0.9	-7.5	20.0	-8.6	20.5	-9.6	21.1	-11.0	21.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.4	5.1	6.4	9.7	13.1	18.2	23.7	28.1	26.9	21.6	16.4	9.5	6.0		
	DBStd	8.68	3.07	3.57	3.82	4.24	4.50	3.85	2.44	2.52	3.58	3.60	3.47	2.97		
	HDD10.0	510	153	108	51	17	2	0	0	0	0	2	50	127		
	HDD18.3	1979	409	334	267	164	59	5	0	0	12	82	266	381		
	CDD10.0	2498	2	7	43	110	257	411	561	523	347	199	35	4		
	CDD18.3	923	0	0	1	6	56	165	302	264	108	21	0	0		
	CDH23.3	10954	0	0	3	59	555	1915	4058	3218	1009	135	1	0		
	CDH26.7	5208	0	0	0	3	152	853	2219	1623	337	21	0	0		
(14) Wind	WSAvg	3.4	3.2	3.5	3.7	4.2	3.9	3.8	3.7	3.2	3.2	2.8	3.0	2.9		
(15) Precipitation	PrecAvg	304	24	20	35	34	21	17	7	13	34	39	29	31		
	PrecMax	530	87	64	110	116	69	87	36	42	87	181	116	72		
	PrecMin	126	1	0	8	3	0	1	1	1	7	1	0	5		
	PrecStd	90	20	15	25	25	21	19	8	10	24	41	29	18		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.0	19.6	23.3	27.1	32.1	35.8	37.2	36.7	33.1	29.2	22.1	18.0		
		MCWB	7.6	8.6	9.4	11.7	14.0	15.6	16.4	16.6	15.5	14.0	11.1	8.5		
	2%	DB	14.5	16.8	20.7	25.1	30.1	34.2	36.4	35.4	31.6	26.5	19.3	15.1		
		MCWB	6.5	7.5	8.9	11.4	13.4	15.3	16.3	16.3	15.2	13.2	10.1	7.8		
	5%	DB	12.5	14.7	18.8	23.2	28.3	32.9	35.5	34.5	30.2	24.6	17.3	13.0		
		MCWB	5.7	6.7	8.4	10.7	12.8	14.9	16.1	16.1	15.0	12.6	9.3	7.2		
	10%	DB	10.6	12.9	17.1	21.2	26.6	31.4	34.5	33.4	28.7	23.0	15.7	11.2		
		MCWB	5.2	5.9	7.6	9.9	12.4	14.7	15.8	15.8	14.6	12.2	8.8	6.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.7	9.7	11.5	13.3	15.6	17.4	18.6	19.1	17.9	15.8	13.6	10.2		
		MCDB	13.7	16.0	17.7	21.7	26.7	30.5	30.9	29.5	26.2	22.3	19.4	14.5		
	2%	WB	7.6	8.6	10.4	12.2	14.5	16.4	17.6	18.1	17.0	14.8	11.8	8.9		
		MCDB	12.3	15.0	17.0	21.2	25.5	29.4	31.2	28.7	26.0	21.6	16.4	13.6		
	5%	WB	6.7	7.5	9.4	11.5	13.7	15.8	17.0	17.5	16.2	14.1	10.7	7.7		
		MCDB	11.0	13.1	16.2	20.4	24.5	29.0	31.4	29.0	25.7	20.5	15.6	11.8		
	10%	WB	5.7	6.6	8.5	10.7	13.1	15.2	16.5	16.9	15.6	13.4	9.5	6.8		
		MCDB	9.7	11.4	15.6	19.0	23.6	27.9	31.3	29.3	25.1	20.2	14.5	10.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.8	9.4	10.6	11.0	11.7	12.2	12.4	12.3	11.2	10.2	8.8	8.2		
		MCDBR	12.5	12.7	13.3	13.2	13.2	12.8	12.9	12.9	12.6	11.7	11.5	11.8		
	5% WB	MCWBR	6.4	6.0	5.6	5.0	4.5	3.9	3.8	3.7	4.0	4.2	5.3	6.3		
		MCWBR	10.6	10.8	11.4	11.9	12.4	12.5	12.6	12.6	11.6	9.7	9.4	10.1		
(40) Clear-Sky Solar Irradiance	taub		0.260	0.289	0.358	0.388	0.432	0.464	0.530	0.491	0.445	0.379	0.312	0.270		
	taud		2.493	2.408	2.190	2.117	2.012	1.921	1.764	1.865	1.984	2.167	2.383	2.481		
	Ebn at Noon		969	966	913	898	859	827	770	794	813	844	889	934		
	Edh at Noon		84	102	138	156	176	192	224	199	168	129	93	80		
(44) All-Sky Solar Radiation	RadAvg		3.29	4.23	5.50	6.60	7.32	7.90	7.69	6.96	5.70	4.61	3.47	2.95		
	RadStd		0.25	0.28	0.25	0.30	0.34	0.25	0.19	0.25	0.33	0.30	0.21	0.22		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page