

BECHAR, Algeria

WMO: 605710

Lat: 31.646N

Lon: 2.270W

Elev: 811

StdP: 91.95

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.1	2.5	-12.4	1.4	14.0	-10.3	1.7	14.8	14.4	11.6	12.7	11.9	1.0	350	0.515

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.8	42.0	19.8	41.1	19.5	40.1	19.2	22.1	36.4	21.2	36.0	20.5	35.4	5.0	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.7	14.0	27.8	16.2	12.7	27.3	15.1	11.8	27.4	68.7	36.6	65.3	36.2	62.5	35.3	26.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
13.5	11.4	9.8	DB	-1.1	43.6	1.5	0.8	-2.2	44.2	-3.1	44.7	-3.9	45.2	-5.0	45.8
			WB	-2.8	23.6	1.5	1.4	-3.9	24.6	-4.8	25.5	-5.6	26.3	-6.7	27.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.7	10.2	12.4	16.6	20.8	25.5	30.4	34.4	33.3	28.2	22.4	15.3	11.0
	DBStd	8.83	2.48	2.89	3.32	3.42	3.72	2.77	1.91	2.06	3.35	3.11	3.28	2.50
	HDD10.0	58	28	11	0	0	0	0	0	0	0	0	1	18
	HDD18.3	844	253	168	73	15	1	0	0	0	0	5	101	228
	CDD10.0	4348	33	77	206	323	480	613	756	721	546	384	161	49
	CDD18.3	2092	0	1	21	88	223	363	497	463	296	131	11	0
	CDH23.3	31572	2	14	249	938	2881	5642	8713	7732	4031	1267	102	1
	CDH26.7	19772	0	2	52	321	1463	3572	6276	5335	2285	454	13	0
Wind	WSAvg	3.8	2.7	3.5	4.1	4.9	4.9	4.4	4.2	4.0	3.9	3.3	3.0	2.4
Precipitation	PrecAvg	87	8	8	8	8	5	3	2	3	8	12	10	9
	PrecMax	244	80	53	74	47	27	41	14	35	76	153	44	58
	PrecMin	16	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	52	14	12	14	11	8	7	3	5	12	25	12	13
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.2	25.2	30.9	34.0	38.2	41.2	43.2	42.2	39.7	34.2	28.3	23.0
		MCWB	10.3	12.0	13.4	15.1	17.8	19.4	19.9	20.0	19.4	17.5	15.2	11.5
	2%	DB	20.5	22.8	28.0	31.9	36.6	40.1	42.2	41.3	38.2	32.2	26.1	20.9
		MCWB	9.7	10.5	12.5	14.9	17.2	18.9	19.8	19.7	18.9	16.2	13.8	10.9
	5%	DB	18.9	21.1	26.0	30.1	35.0	39.0	41.8	40.7	37.0	30.9	24.1	19.1
		MCWB	9.3	9.9	12.1	14.4	16.6	18.5	19.7	19.5	18.4	16.1	12.9	10.2
	10%	DB	17.1	19.5	24.2	28.3	33.2	37.9	40.9	39.8	35.6	29.2	22.3	17.2
		MCWB	8.5	9.4	11.4	13.6	15.9	18.2	19.4	19.2	18.0	15.6	12.1	9.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.1	13.7	15.3	18.3	20.2	21.8	23.1	23.3	22.7	20.1	17.0	13.8
		MCDB	19.9	21.6	24.9	28.5	32.4	36.6	39.1	37.5	34.1	31.2	26.9	18.9
	2%	WB	11.0	12.0	13.9	16.8	18.6	20.5	21.9	22.0	21.2	18.6	15.2	12.1
		MCDB	18.6	20.4	24.4	27.7	31.6	35.3	38.4	35.9	33.0	27.7	22.5	18.4
	5%	WB	9.9	11.0	12.9	15.5	17.5	19.6	21.0	21.2	20.2	17.6	13.9	11.1
		MCDB	17.1	18.7	23.2	26.7	30.6	34.5	38.2	35.6	32.0	26.6	22.1	17.3
	10%	WB	8.9	10.0	11.9	14.3	16.6	18.7	20.1	20.4	19.4	16.8	12.8	10.1
		MCDB	15.8	17.6	22.3	25.5	29.9	33.9	37.3	35.3	31.1	25.9	21.4	16.2
Mean Daily Temperature Range	5% DB	MDBR	13.0	12.7	12.6	12.3	12.3	12.7	12.8	12.3	11.9	11.8	12.0	12.3
		MCDBR	16.2	15.2	14.9	14.0	13.6	14.0	13.6	13.1	13.1	13.5	13.8	14.9
		MCWBR	8.6	7.3	6.4	5.9	5.3	5.1	5.0	4.7	4.9	5.4	6.5	7.6
	5% WB	MCDBR	14.5	13.1	13.5	12.4	12.7	12.9	12.6	12.3	11.6	11.6	12.4	13.1
		MCWBR	8.3	6.7	6.4	5.9	5.5	5.3	5.5	5.0	5.0	5.2	6.5	7.1
Clear-Sky Solar Irradiance	taub	0.289	0.328	0.404	0.438	0.485	0.528	0.614	0.569	0.506	0.437	0.351	0.302	
	taud	2.463	2.334	2.068	1.989	1.884	1.788	1.618	1.722	1.867	2.030	2.292	2.441	
	Ebn at Noon	943	928	872	856	816	777	710	736	765	793	853	905	
	Edh at Noon	90	113	159	179	201	220	220	260	231	192	152	106	88
All-Sky Solar Radiation	RadAvg	3.84	4.80	6.00	7.01	7.64	8.04	7.72	7.04	5.84	4.85	3.94	3.47	
	RadStd	0.23	0.27	0.27	0.28	0.27	0.25	0.16	0.24	0.31	0.31	0.20	0.16	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.41	N/A	N/A	+0.36	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page