

OUARGLA, Algeria

WMO: 605800

Lat: 31.917N

Lon: 5.413E

Elev: 492

StdP: 14.44

Time Zone: 1.00 (E01)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	36.6	39.0	17.2	13.4	61.8	20.8	15.8	62.0	26.8	59.3	23.3	59.1	2.2	320	0.523

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.3	115.8	73.5	113.3	73.0	110.9	72.1	77.0	106.3	75.4	105.4	74.2	103.7	10.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.2	105.5	89.1	66.2	98.4	89.4	64.4	92.1	89.3	40.6	106.5	39.1	105.3	37.9	103.5	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.7	21.6	19.2	DB	32.2	119.6	2.4	1.7	30.5	120.8	29.1	121.8	27.7	122.8	26.0	124.1	(4)
(5)			WB	29.1	79.2	2.2	3.0	27.6	81.4	26.3	83.1	25.1	84.8	23.6	87.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	74.8	53.2	56.9	65.1	73.5	82.3	90.9	97.1	95.1	87.4	76.5	62.9	54.9	(6)
(7)		DBStd	16.33	4.36	5.69	6.61	6.69	6.64	5.91	4.53	4.22	6.34	6.28	5.60	4.79	(7)
(8)		HDD50	34	17	6	0	0	0	0	0	0	0	0	1	10	(8)
(9)		HDD65	1111	365	235	81	7	0	0	0	0	0	2	104	317	(9)
(10)		CDD50	9070	117	200	470	704	1000	1228	1459	1399	1123	822	387	161	(10)
(11)		CDD65	4672	0	9	85	261	535	778	994	934	673	359	41	3	(11)
(12)		CDH74	73661	16	154	1124	3267	7606	12929	17749	16160	10066	4109	448	33	(12)
(13)		CDH80	49246	1	36	396	1604	4562	8978	13316	11749	6446	2044	109	5	(13)
(14)	Wind	WSAvg	8.5	6.4	8.0	9.0	10.3	11.0	10.4	8.9	9.0	9.1	7.3	6.1	5.9	(14)
(15)	Precipitation	PrecAvg	1.6	0.3	0.0	0.2	0.2	0.2	0.0	0.0	0.1	0.2	0.1	0.2	0.2	(15)
(16)		PrecMax	4.5	2.1	0.9	0.9	1.1	1.9	0.1	0.1	0.5	0.6	1.3	1.5	1.3	(16)
(17)		PrecMin	0.4	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	1.1	0.5	0.2	0.3	0.2	0.4	0.0	0.0	0.1	0.2	0.3	0.3	0.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.5	84.6	93.4	102.5	110.0	116.0	119.8	117.0	112.9	102.6	87.9	78.0	(19)
(20)			MCWB	56.1	59.3	63.6	65.6	69.6	72.8	74.2	73.5	71.9	68.9	64.0	57.5	(20)
(21)		2%	DB	71.4	78.6	88.4	97.2	105.7	113.0	116.9	114.5	109.0	98.7	82.8	72.9	(21)
(22)			MCWB	54.1	56.9	61.6	64.2	68.9	72.2	73.6	73.7	70.9	67.1	61.4	56.2	(22)
(23)		5%	DB	68.0	73.7	84.3	93.3	101.7	109.8	114.7	111.5	105.7	94.6	79.0	69.4	(23)
(24)			MCWB	53.2	54.9	60.1	63.2	67.5	71.1	73.7	72.9	70.0	66.2	60.1	54.9	(24)
(25)		10%	DB	64.8	69.9	80.3	89.3	98.2	106.4	111.6	109.1	102.1	90.4	75.4	66.2	(25)
(26)			MCWB	51.2	52.9	57.8	61.7	66.3	69.8	72.3	71.9	69.9	65.6	58.7	53.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.3	62.2	67.3	69.8	73.7	78.5	79.7	78.8	77.1	73.3	67.4	60.1	(27)
(28)			MCD B	71.1	80.8	85.6	94.2	100.0	105.6	107.3	107.8	100.6	91.1	84.0	73.5	(28)
(29)		2%	WB	55.9	58.3	64.1	66.3	71.3	75.1	77.0	76.4	75.0	70.8	64.0	57.6	(29)
(30)			MCD B	68.3	75.4	83.5	89.5	97.6	104.3	108.8	106.2	99.4	89.4	78.7	69.6	(30)
(31)		5%	WB	54.1	55.7	61.6	64.3	69.3	73.1	75.4	75.0	73.4	69.1	61.6	55.8	(31)
(32)			MCD B	65.7	71.3	80.2	87.2	95.0	103.0	107.9	105.0	96.6	87.2	75.8	67.1	(32)
(33)		10%	WB	52.1	53.7	59.1	62.7	67.6	71.4	74.0	73.7	72.0	67.5	59.4	53.9	(33)
(34)			MCD B	63.0	68.1	77.6	85.2	92.4	100.9	106.3	103.5	95.1	85.6	72.9	64.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	23.6	24.5	25.7	25.6	25.6	26.2	26.3	25.5	24.4	24.6	23.5	23.0	(35)
(36)			MCDBR	27.6	29.9	31.1	30.8	29.2	30.3	29.7	28.8	28.7	29.0	27.1	26.5	(36)
(37)			MCWBR	15.2	15.7	14.5	12.9	11.5	11.3	11.0	10.3	10.1	11.7	13.0	14.4	(37)
(38)		5% WB	MCDBR	25.1	27.0	28.8	27.1	25.9	26.7	26.3	25.7	24.5	24.3	25.0	24.1	(38)
(39)			MCWBR	14.8	15.1	14.9	12.6	11.9	11.9	11.2	10.6	10.2	11.3	13.2	13.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.361	0.389	0.496	0.538	0.599	0.606	0.635	0.605	0.594	0.514	0.417	0.374	(40)	
(41)		taud	2.142	2.051	1.762	1.697	1.594	1.592	1.557	1.619	1.649	1.793	1.993	2.103	(41)	
(42)		Ebn at Noon	266	270	248	244	230	228	220	225	219	226	242	252	(42)	
(43)		Edh at Noon	39	48	69	76	85	85	88	81	76	61	45	39	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1174	1470	1812	2136	2299	2447	2431	2222	1867	1520	1212	1047	(44)	
(45)		RadStd	49	61	74	82	76	64	33	48	60	63	43	48	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (3 neighbors)		+0.61	N/A	N/A	N/A	-0.65	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page