

EL MENIA, Algeria

WMO: 605900

Lat: 30.571N

Lon: 2.860E

Elev: 398

StdP: 96.63

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.8	2.1	-8.8	1.9	13.2	-7.0	2.2	13.7	13.9	13.1	11.8	14.1	1.5	350	0.508

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.9	44.8	21.5	43.5	21.2	42.3	20.9	23.2	39.8	22.4	39.5	21.8	39.0	4.2	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.0	13.6	30.1	16.9	12.6	30.0	15.8	11.8	30.0	70.6	39.7	67.5	39.4	65.1	39.2	30.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.4	10.3	9.0	-2.2	46.6	1.4	0.8	-3.2	47.2	-4.1	47.7	-4.8	48.1	-5.9	48.7
			-3.9	25.8	1.3	1.9	-4.9	27.1	-5.6	28.2	-6.4	29.3	-7.4	30.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	22.7	10.4	12.8	17.3	21.8	27.1	31.9	35.0	34.2	30.1	23.7	16.0	11.5
	DBStd	9.15	2.52	3.22	3.60	3.51	3.41	2.71	1.97	1.95	3.24	3.50	3.34	2.66
	HDD10.0	50	26	9	1	0	0	0	0	0	0	0	1	14
	HDD18.3	774	246	157	63	8	0	0	0	0	0	2	87	213
	CDD10.0	4690	38	88	227	355	529	658	776	751	604	425	180	61
	CDD18.3	2373	0	2	31	113	271	408	517	492	354	169	16	1
	CDH23.3	37001	2	54	472	1434	3758	6624	9075	8401	5106	1878	185	10
	CDH26.7	24129	0	12	152	656	2163	4461	6638	5982	3166	858	41	1
Wind	WSAvg	3.5	2.9	3.6	3.8	4.4	4.4	4.1	3.5	3.4	3.4	3.1	2.8	2.8
Precipitation	PrecAvg	44	8	2	7	4	4	0	0	1	5	6	5	2
	PrecMax	138	70	20	42	36	37	4	1	11	45	34	30	18
	PrecMin	6	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	29	15	4	11	7	8	1	0	2	11	9	8	4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.0	28.1	33.2	37.2	41.9	44.7	46.3	45.2	42.9	38.2	30.2	24.8
		MCWB	12.4	13.7	15.9	17.5	19.5	21.4	21.8	21.6	21.1	19.9	16.8	13.4
	2%	DB	20.8	24.6	30.2	34.9	39.7	43.1	45.1	44.0	41.1	35.4	27.6	21.5
		MCWB	11.0	12.4	14.8	16.9	19.2	20.8	21.6	21.5	20.6	18.7	15.4	12.1
	5%	DB	19.0	22.3	28.0	32.8	37.8	41.8	44.1	42.9	39.8	33.2	25.4	19.7
		MCWB	10.3	11.5	14.3	16.2	18.6	20.5	21.2	21.3	20.4	18.2	14.5	11.3
	10%	DB	17.3	20.3	25.9	30.7	35.8	40.1	42.9	41.8	38.0	31.2	23.2	18.0
		MCWB	9.6	10.6	13.2	15.5	17.9	20.1	21.0	20.9	20.1	17.8	13.4	10.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.4	14.9	17.5	19.6	21.5	24.2	24.4	24.3	23.6	21.7	18.3	14.7
		MCDB	20.5	25.4	27.7	32.5	35.9	41.0	41.1	40.6	37.7	34.3	27.5	21.8
	2%	WB	11.9	13.3	15.9	17.8	20.2	22.4	23.0	23.0	22.4	20.3	16.6	13.2
		MCDB	19.0	23.1	27.1	30.7	34.9	39.2	41.5	40.0	36.8	31.1	24.8	19.6
	5%	WB	10.8	12.1	14.7	16.8	19.2	21.3	22.2	22.2	21.6	19.4	15.3	12.2
		MCDB	17.6	21.2	26.4	29.8	34.5	38.6	41.2	39.5	36.0	29.9	23.7	18.4
	10%	WB	9.9	11.0	13.6	15.7	18.3	20.6	21.5	21.6	20.9	18.5	14.1	11.3
		MCDB	16.6	19.6	24.7	28.5	33.2	37.9	40.5	38.9	34.8	29.0	22.1	17.3
Mean Daily Temperature Range	5% DB	MDBR	13.8	14.0	14.5	14.4	14.4	14.6	14.9	14.5	13.7	13.4	13.7	13.2
		MCDBR	16.3	16.7	18.3	17.9	17.2	17.2	17.1	16.4	16.2	15.8	15.8	15.4
		MCWBR	8.9	8.3	8.4	7.6	6.3	6.5	6.1	6.0	6.1	6.5	7.5	8.4
	5% WB	MCDBR	14.6	15.6	16.8	15.6	15.1	15.3	15.7	14.6	13.8	13.5	14.0	13.6
		MCWBR	8.4	8.1	8.2	7.2	6.4	6.7	6.3	5.9	6.0	6.3	7.3	8.0
Clear-Sky Solar Irradiance	taub	0.337	0.368	0.467	0.506	0.561	0.590	0.622	0.591	0.576	0.499	0.391	0.346	
	taud	2.202	2.090	1.808	1.742	1.640	1.596	1.551	1.623	1.659	1.797	2.041	2.181	
	Ebn at Noon	879	882	813	798	756	731	705	721	709	733	802	844	
	Edh at Noon	118	146	208	230	257	267	279	256	238	194	138	115	
All-Sky Solar Radiation	RadAvg	4.01	4.91	6.03	7.00	7.45	7.93	7.83	7.21	6.07	5.05	4.12	3.61	
	RadStd	0.16	0.19	0.27	0.25	0.25	0.18	0.14	0.17	0.22	0.22	0.17	0.15	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.25	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page