

TIMIMOUN, Algeria

WMO: 606070

Lat: 29.237N

Lon: 0.276E

Elev: 313

StdP: 97.62

Time Zone: 1.00 (E01)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.1	4.3	-14.8	1.1	14.1	-12.8	1.3	14.9	14.6	13.3	12.9	13.5	3.4	30	0.577

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.0	46.8	21.7	45.8	21.4	44.8	21.1	22.6	40.0	21.8	40.0	21.2	40.0	4.1	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.2	12.8	28.7	15.8	11.6	29.2	14.0	10.4	30.8	67.8	39.7	64.8	39.6	62.4	39.9	26.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.4	11.7	10.2	0.0	48.1	1.7	0.6	-1.2	48.6	-2.2	49.0	-3.1	49.3	-4.3	49.8		
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.8	12.2	14.9	19.8	24.3	29.2	33.9	37.2	36.1	32.2	26.1	18.0	13.2	
	DBStd	9.18	2.45	3.35	3.70	3.50	3.41	2.57	1.98	1.92	3.09	3.39	3.41	2.57	
	HDD10.0	13	7	3	0	0	0	0	0	0	0	0	0	3	
	HDD18.3	529	192	105	27	2	0	0	0	0	0	0	44	159	
	CDD10.0	5420	74	139	304	430	595	716	844	809	665	498	241	104	
	CDD18.3	2893	0	8	72	182	337	466	586	551	415	240	36	2	
	CDH23.3	47345	10	135	979	2423	5093	8092	10833	9884	6539	2933	405	19	
CDH26.7	32701	0	31	398	1292	3258	5824	8362	7419	4407	1579	128	1		
Wind	WSAvg	4.6	4.1	4.7	5.0	5.4	5.4	5.0	4.8	4.6	4.4	4.2	3.9	4.1	
Precipitation	PrecAvg	13	1	1	3	2	1	0	0	1	3	3	1	2	
	PrecMax	36	10	19	27	33	10	0	4	19	23	27	7	23	
	PrecMin	0	0	0	0	0	0	0	0	0	0	0	0	0	
	PrecStd	11	2	4	6	6	2	0	1	4	5	5	2	5	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.9	30.1	36.0	40.1	43.1	46.2	48.1	47.0	44.2	40.0	33.2	25.2	
		MCWB	11.8	14.0	15.7	18.5	20.1	21.3	22.7	21.5	20.7	18.7	16.0	12.6	
	2%	DB	22.4	27.0	33.0	37.1	41.9	45.1	47.1	45.9	43.1	37.6	30.2	23.1	
		MCWB	10.6	12.3	15.5	17.3	19.8	21.5	21.9	21.3	20.3	17.9	14.8	11.7	
	5%	DB	20.9	24.8	30.9	35.2	40.1	44.0	46.2	45.0	42.0	36.0	27.6	21.4	
		MCWB	9.7	11.6	14.3	16.6	18.9	20.8	21.6	21.1	20.1	17.3	13.9	11.0	
	10%	DB	19.1	22.9	28.8	33.5	38.1	42.6	45.4	43.9	40.8	34.1	25.2	19.9	
		MCWB	9.0	10.8	13.6	15.7	18.0	20.0	21.3	20.7	19.7	17.0	12.9	10.3	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.8	14.3	18.1	19.1	21.7	23.4	23.6	23.6	22.7	20.8	17.1	13.9
			MCDB	22.1	24.4	26.2	33.1	36.3	39.3	43.5	39.9	33.7	31.8	28.9	22.9
2%		WB	11.4	13.1	15.6	17.6	20.2	21.3	22.4	22.5	21.7	19.3	15.8	12.5	
		MCDB	20.5	23.1	27.1	32.2	35.0	39.5	43.1	40.4	36.6	31.7	27.3	21.2	
5%		WB	10.4	12.0	14.4	16.7	19.1	20.4	21.6	21.7	21.0	18.4	14.7	11.6	
		MCDB	19.2	22.0	27.3	31.4	34.9	39.5	42.8	40.4	36.9	31.7	25.8	20.2	
10%		WB	9.3	11.0	13.3	15.7	18.2	19.6	20.9	21.0	20.2	17.7	13.6	10.7	
		MCDB	18.0	21.1	25.8	30.1	34.6	38.9	42.3	40.4	36.4	31.5	23.9	18.8	
Mean Daily Temperature Range		5% DB	MDBR	13.9	14.3	15.1	15.3	15.4	16.0	16.0	15.2	14.4	14.2	13.7	13.1
			MCDBR	15.9	16.7	17.9	17.6	17.1	17.4	16.4	16.1	16.1	15.9	15.6	14.6
	MCWBR		7.6	7.5	7.5	7.0	5.8	7.1	5.6	5.2	5.6	5.7	6.4	6.8	
	5% WB	MCDBR	14.6	14.2	14.6	14.5	14.4	14.6	15.0	13.6	13.3	13.7	13.7	13.4	
		MCWBR	7.5	6.9	6.9	6.3	6.1	6.2	5.5	5.2	5.3	5.5	6.3	6.7	
Clear-Sky Solar Irradiance	taub	0.359	0.401	0.490	0.530	0.581	0.618	0.661	0.629	0.606	0.525	0.413	0.366		
	taud	2.125	1.993	1.764	1.694	1.611	1.555	1.493	1.567	1.615	1.753	1.991	2.119		
	Ebn at Noon	859	852	797	781	742	711	679	695	690	716	787	828		
	Edh at Noon	130	163	219	243	265	279	296	272	251	205	148	126		
All-Sky Solar Radiation	RadAvg	4.14	5.04	6.10	6.94	7.45	7.83	7.73	7.13	6.05	5.11	4.28	3.77		
	RadStd	0.17	0.23	0.27	0.22	0.26	0.22	0.13	0.21	0.26	0.24	0.17	0.16		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	+0.22	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page