

TAGUENTOUR, Algeria

WMO: 606190

Lat: 28.467N

Lon: 2.517E

Elev: 636

StdP: 93.91

Time Zone: 1.00 (E01)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.1	2.5	-16.3	1.0	21.8	-14.7	1.1	21.4	15.3	11.5	13.9	12.9	3.1	10	0.602

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.8	43.6	17.6	42.7	17.5	41.7	17.4	19.5	35.4	18.8	36.3	18.3	37.0	4.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.0	11.5	23.7	13.1	10.1	24.2	11.2	8.9	25.3	58.2	34.5	55.7	35.7	54.0	36.6	23.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
14.3	12.3	11.0	-1.7	44.9	1.3	0.6	-2.6	45.3	-3.3	45.7	-4.1	46.0	-5.0	46.5		
			-4.0	20.7	1.3	1.4	-4.9	21.7	-5.7	22.5	-6.4	23.3	-7.3	24.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.2	11.6	13.7	18.1	23.4	27.8	32.1	34.5	33.2	30.5	24.1	17.1	12.0
	DBStd	8.81	3.06	4.27	4.32	3.87	3.34	2.77	2.25	1.96	2.92	3.56	3.77	3.36
	HDD10.0	44	18	12	1	0	0	0	0	0	0	0	1	14
	HDD18.3	684	210	141	58	5	0	0	0	0	2	68	200	
	CDD10.0	4871	67	114	251	402	553	663	758	718	616	438	214	77
	CDD18.3	2468	1	9	51	157	294	413	500	460	366	182	32	4
	CDH23.3	38515	15	133	676	2081	4264	6842	8831	7699	5468	2121	343	42
	CDH26.7	25064	0	29	244	1069	2592	4696	6441	5351	3497	1034	103	7
Wind	WSAvg	5.1	4.3	4.9	5.1	5.8	5.9	5.8	5.2	5.1	4.5	4.7	4.7	5.2
Precipitation	PrecAvg	46	6	3	6	5	3	2	0	2	6	4	4	4
	PrecMax	96	35	13	27	34	12	9	4	11	28	25	17	15
	PrecMin	17	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	19	9	3	6	7	4	3	1	2	7	6	4	4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.3	29.9	34.7	38.5	41.0	44.0	44.8	43.7	41.9	37.5	32.3	27.9
		MCWB	10.3	12.1	13.2	15.7	16.4	17.3	17.6	18.1	17.4	16.6	15.0	12.7
	2%	DB	22.9	26.7	31.4	35.9	39.7	42.9	44.0	42.4	40.8	35.6	29.7	23.7
		MCWB	10.1	11.2	12.9	14.6	16.1	17.2	17.6	17.9	17.3	15.8	13.9	11.5
	5%	DB	20.9	24.8	29.6	34.4	38.4	41.7	43.3	41.5	39.9	34.2	27.2	21.1
		MCWB	9.2	10.5	12.4	14.1	15.8	16.9	17.6	17.7	17.0	15.5	12.9	10.4
	10%	DB	18.9	22.3	27.2	32.6	36.7	40.4	42.3	40.6	38.7	32.3	24.9	19.1
		MCWB	8.3	9.6	11.5	13.6	15.2	16.7	17.5	17.6	17.0	15.3	12.2	9.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.0	13.8	16.5	16.7	18.6	19.0	19.2	21.0	20.6	18.0	16.0	13.7
		MCDB	16.8	26.6	22.7	31.1	29.8	36.5	40.4	32.3	30.9	29.3	29.4	22.7
	2%	WB	10.9	12.4	14.5	16.0	17.5	18.2	18.6	19.8	19.3	17.2	14.6	12.1
		MCDB	21.5	24.0	25.9	31.6	33.1	37.5	40.6	36.8	31.4	30.6	27.0	21.3
	5%	WB	9.6	11.2	13.3	15.0	16.7	17.7	18.1	19.0	18.6	16.6	13.5	11.1
		MCDB	19.9	22.7	27.0	30.9	34.7	38.0	40.8	38.0	32.6	30.3	24.9	19.7
	10%	WB	8.8	10.2	12.3	14.1	16.0	17.2	17.8	18.4	18.0	15.9	12.6	10.0
		MCDB	18.8	21.4	26.6	31.3	34.6	38.4	40.6	38.0	34.0	29.3	23.8	18.2
Mean Daily Temperature Range	5% DB	MDBR	13.9	13.9	14.7	14.9	14.8	14.9	14.8	14.4	13.9	13.8	13.5	13.4
		MCDBR	15.4	15.1	15.8	16.0	15.6	15.6	14.7	14.5	15.0	14.8	14.3	14.5
		MCWBR	7.5	7.0	6.9	6.5	5.7	5.5	4.9	4.9	4.9	5.4	5.8	7.0
	5% WB	MCDBR	14.0	13.4	13.8	14.0	13.7	14.4	14.4	13.2	12.7	13.4	13.2	13.1
		MCWBR	7.2	6.5	6.5	5.8	5.2	5.0	4.8	4.3	4.2	5.0	5.6	6.4
Clear-Sky Solar Irradiance	taub	0.338	0.370	0.469	0.506	0.573	0.593	0.590	0.575	0.572	0.500	0.386	0.345	
	taud	2.278	2.162	1.864	1.799	1.678	1.646	1.659	1.712	1.722	1.862	2.141	2.268	
	Ebn at Noon	895	891	819	802	749	730	730	738	720	746	828	866	
	Edh at Noon	113	138	199	219	248	255	251	236	226	185	129	110	
All-Sky Solar Radiation	RadAvg	4.31	5.13	6.13	6.89	7.22	7.65	7.59	7.12	6.10	5.24	4.45	3.91	
	RadStd	0.17	0.23	0.28	0.23	0.34	0.28	0.18	0.21	0.27	0.24	0.16	0.15	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	+0.24	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page