

ILLIZI TAKHAMALT, Algeria

WMO: 606400

Lat: 26.724N

Lon: 8.623E

Elev: 542

StdP: 94.98

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.0	4.4	-9.7	1.8	15.5	-8.1	2.0	16.2	12.9	16.7	10.7	17.6	1.6	90	0.505

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.9	44.0	20.9	43.0	20.6	42.0	20.5	23.2	38.7	22.4	38.6	21.7	38.4	4.8	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.5	14.3	29.3	16.9	12.9	30.6	15.3	11.6	31.8	71.8	38.8	68.3	38.2	65.6	38.5	27.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.1	9.8	8.6	0.3	45.8	1.5	1.0	-0.8	46.5	-1.7	47.0	-2.5	47.6	-3.6	48.3		
			-2.0	25.3	1.2	1.4	-2.8	26.3	-3.6	27.1	-4.3	27.9	-5.2	28.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	24.9	13.0	15.5	20.2	25.6	30.5	33.6	34.2	33.8	31.8	26.2	19.4	14.4
	DBStd	8.34	3.28	3.88	4.33	4.07	3.07	2.36	1.96	1.71	2.17	3.19	3.35	3.39
	HDD10.0	13	8	2	1	0	0	0	0	0	0	0	0	3
	HDD18.3	453	169	96	31	2	0	0	0	0	0	0	26	130
	CDD10.0	5452	100	157	315	468	635	708	752	738	653	502	283	141
	CDD18.3	2851	3	17	88	220	377	458	493	479	403	244	59	9
	CDH23.3	45953	88	308	1256	3149	5855	7826	8662	8282	6486	3142	756	144
	CDH26.7	30281	16	101	559	1809	3808	5536	6247	5872	4317	1712	268	36
(14) Wind	WSAvg	4.0	3.4	3.9	4.2	4.4	4.7	4.5	4.4	4.2	3.9	3.7	3.2	3.1
(15) Precipitation	PrecAvg	22	2	2	3	1	1	2	0	0	3	3	2	2
	PrecMax	62	18	38	29	18	16	21	1	3	38	22	36	13
	PrecMin	1	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	16	4	7	7	4	3	5	0	1	8	6	7	4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.4	32.4	36.4	40.9	43.1	45.0	45.2	44.1	42.6	39.0	33.8	30.2
		MCWB	13.9	15.6	17.3	18.6	20.9	20.9	21.0	21.1	20.6	20.8	17.4	14.2
	2%	DB	25.8	29.7	34.3	38.8	41.6	43.8	44.1	43.0	41.8	37.1	31.7	27.0
		MCWB	12.9	14.3	16.4	17.9	20.4	20.6	20.8	20.8	20.5	19.1	16.1	13.5
	5%	DB	23.4	27.1	32.1	37.0	40.1	42.6	43.1	42.0	40.7	35.9	29.9	24.5
		MCWB	11.9	13.2	15.7	17.6	19.6	20.3	20.6	20.8	20.2	18.8	15.7	12.6
	10%	DB	21.1	24.4	30.0	35.1	38.8	41.2	42.0	41.0	39.4	34.4	27.9	22.1
		MCWB	10.9	12.1	14.8	17.0	19.2	20.1	20.4	20.4	19.9	18.5	14.7	11.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.0	16.9	19.3	21.2	23.5	23.5	23.6	23.8	24.1	24.4	20.0	16.0
		MCDB	25.0	29.7	32.6	34.1	39.0	40.2	41.3	38.9	37.5	34.3	31.2	25.2
	2%	WB	13.9	15.0	17.5	19.3	22.0	22.2	22.5	22.6	22.7	21.5	17.9	14.4
		MCDB	23.3	27.3	31.0	34.5	37.9	39.0	40.7	39.7	37.2	32.1	28.8	24.5
	5%	WB	12.5	13.7	16.2	18.2	20.9	21.4	21.6	21.8	21.7	20.3	16.4	13.3
		MCDB	21.9	25.0	29.9	34.1	36.9	38.8	40.6	39.6	36.5	32.0	27.6	23.0
	10%	WB	11.3	12.5	15.1	17.3	19.9	20.6	20.9	21.1	20.9	19.3	15.1	12.2
		MCDB	20.3	23.2	28.4	33.3	36.2	38.6	40.3	39.0	36.4	31.7	26.4	21.4
(35) Mean Daily Temperature Range	5% DB	MDBR	15.0	15.2	15.6	15.4	14.5	14.3	14.9	14.5	14.5	14.3	14.8	14.4
		MCDBR	17.7	18.1	17.9	17.5	16.0	15.2	15.6	15.1	15.6	15.6	16.7	16.9
		MCWBR	9.1	9.0	8.2	7.3	6.7	5.9	6.0	6.0	6.1	6.5	7.9	8.4
	5% WB	MCDBR	16.4	16.8	16.2	15.9	14.4	14.2	14.9	14.3	14.2	13.9	15.6	15.6
		MCWBR	9.3	8.9	8.2	7.4	7.1	6.3	6.6	6.3	6.3	6.5	8.1	8.3
(40) Clear-Sky Solar Irradiance	taub		0.354	0.391	0.498	0.574	0.639	0.627	0.516	0.524	0.555	0.507	0.415	0.365
	taud		2.190	2.074	1.791	1.652	1.556	1.593	1.823	1.822	1.754	1.845	2.035	2.174
	Ebn at Noon		882	875	798	751	702	706	788	780	740	748	804	850
	Edh at Noon		126	153	216	255	281	269	213	212	221	191	147	123
(44) All-Sky Solar Radiation	RadAvg		4.46	5.22	6.29	6.93	7.25	7.65	7.97	7.42	6.51	5.38	4.52	4.06
	RadStd		0.20	0.25	0.33	0.31	0.28	0.30	0.17	0.17	0.24	0.29	0.16	0.20

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	-1.36	N/A	-1.13	-1.53	N/A	N/A	N/A	N/A

Nomenclature: See separate page