

TINDOUF, Algeria

WMO: 606560

Lat: 27.700N

Lon: 8.167W

Elev: 1453

StdP: 13.94

Time Zone: 1.00 (E01)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	39.8	42.6	13.5	11.5	60.5	16.1	13.1	62.1	33.9	62.9	30.5	60.0	6.5	20	0.593

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	30.0	113.4	69.5	112.0	69.1	110.3	68.5	71.9	100.4	70.6	100.8	69.5	100.7	9.5	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.1	97.9	78.0	62.3	88.6	77.9	59.3	79.6	78.1	36.5	99.4	35.3	100.0	34.3	100.7	77.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
31.4	27.8	24.9	35.3	116.6	2.9	1.9	33.2	117.9	31.5	119.0	29.8	120.0	27.7	121.4
			29.7	75.1	3.0	1.6	27.5	76.3	25.8	77.2	24.1	78.1	22.0	79.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	75.3	56.7	60.8	68.3	73.5	78.7	86.2	95.7	94.7	86.3	77.3	66.3	58.5
	DBStd	14.25	4.27	4.83	5.62	6.21	7.42	7.30	5.95	5.34	6.21	5.98	5.82	4.20
	HDD50	5	4	1	0	0	0	0	0	0	0	0	0	0
	HDD65	685	258	133	30	5	0	0	0	0	1	53	205	
	CDD50	9253	211	302	568	705	890	1085	1417	1385	1090	848	488	264
	CDD65	4459	1	14	133	260	426	635	952	920	640	384	90	4
	CDH74	69285	56	297	1754	3493	6285	10124	16700	15759	9314	4459	976	68
	CDH80	46005	3	49	647	1768	3794	6975	12579	11586	5996	2294	308	6
Wind	WSAvg	12.0	10.0	11.1	12.4	14.9	15.2	14.8	12.0	11.7	12.6	10.3	10.0	9.5
Precipitation	PrecAvg	2.2	0.1	0.3	0.1	0.0	0.1	0.0	0.0	0.2	0.2	0.7	0.2	0.2
	PrecMax	7.3	0.9	3.2	1.4	0.6	1.2	0.4	0.4	1.0	2.1	6.9	1.7	1.2
	PrecMin	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	1.8	0.2	0.7	0.3	0.1	0.2	0.1	0.1	0.3	0.5	1.7	0.4	0.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.0	85.0	95.1	99.6	107.1	112.7	116.2	114.4	110.0	100.6	91.7	79.4
		MCWB	54.4	56.3	60.9	63.0	66.1	69.5	70.1	70.2	68.5	64.3	61.2	56.8
	2%	DB	75.1	80.6	89.8	96.5	104.1	109.8	114.6	112.9	107.5	97.4	87.5	75.4
		MCWB	52.7	54.9	59.7	62.2	65.6	68.5	70.1	69.4	67.8	63.9	59.7	54.7
	5%	DB	72.0	77.4	86.4	93.4	100.6	107.4	113.1	111.2	104.6	95.0	83.8	73.0
		MCWB	51.5	53.4	57.5	61.1	64.3	67.6	69.3	69.0	66.8	63.3	58.8	53.9
	10%	DB	69.5	74.8	83.5	90.0	97.0	104.3	111.4	109.4	101.8	91.7	79.9	69.9
		MCWB	50.6	52.5	56.5	59.7	62.7	66.6	68.7	68.3	66.2	62.7	57.1	52.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.9	60.3	64.5	66.1	69.6	72.6	72.2	74.4	72.9	69.0	65.0	61.0
		MCDB	71.3	74.3	83.0	90.6	90.9	103.7	108.7	100.3	89.4	83.0	85.4	71.0
	2%	WB	55.1	57.5	61.5	63.6	66.8	70.0	70.8	72.4	70.7	67.3	62.2	58.0
		MCDB	69.1	73.4	82.7	89.4	93.5	101.3	107.9	99.6	92.8	84.3	80.0	70.0
	5%	WB	53.4	55.5	59.4	61.6	65.0	68.5	69.6	71.0	69.2	65.9	60.2	55.8
		MCDB	68.4	72.0	81.1	87.5	93.1	100.0	106.7	100.4	94.0	84.8	78.5	68.3
	10%	WB	51.5	53.8	57.6	60.0	63.4	67.1	68.6	69.7	67.9	64.7	58.5	53.9
		MCDB	66.7	71.1	79.1	85.3	91.5	98.2	105.3	101.2	94.8	84.3	76.5	67.2
Mean Daily Temperature Range	5% DB	MDBR	25.3	26.1	27.1	28.5	30.2	31.8	30.0	27.6	26.4	24.8	24.6	23.5
		MCDBR	29.0	30.0	30.6	31.4	31.6	29.7	29.2	27.9	28.1	27.3	27.7	26.4
		MCWBR	13.4	12.8	11.7	10.7	10.5	8.5	8.1	8.1	8.8	9.2	10.9	12.2
	5% WB	MCDBR	26.3	26.4	27.4	29.7	29.6	29.7	28.7	25.5	24.9	23.2	24.9	23.4
		MCWBR	12.6	11.8	11.1	10.6	10.0	9.3	8.3	7.8	8.5	8.7	10.9	11.7
Clear-Sky Solar Irradiance	taub	0.348	0.401	0.467	0.473	0.495	0.556	0.679	0.652	0.566	0.478	0.396	0.369	
	taud	2.190	2.009	1.828	1.842	1.805	1.685	1.474	1.540	1.708	1.889	2.077	2.141	
	Ebn at Noon	280	273	261	264	257	240	212	216	231	245	260	266	
	Edh at Noon	40	51	66	67	69	78	96	89	73	57	44	40	
All-Sky Solar Radiation	RadAvg	1371	1642	1981	2265	2437	2486	2387	2209	1934	1646	1404	1230	
	RadStd	65	89	72	72	100	76	46	51	104	90	53	64	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.74	N/A	-3.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page